



Monthly Operating Report

JUNE 2018



0217327.00

So. Sangamon

July 13, 2018

woodardcurran.com
COMMITMENT & INTEGRITY DRIVE RESULTS

TABLE OF CONTENTS



SECTION	PAGE NO.
Executive Summary.....	ES-1
1. SAFETY	1-1
1.1 Safety Training	1-1
1.2 Lost time Accidents	1-1
1.3 Safety Audit	1-1
1.4 Miscellaneous Safety.....	1-1
2. COMPLIANCE, FLOWS AND LOADINGS	2-2
2.1 Compliance	2-2
2.2 Influent flows and loadings	2-2
2.3 Effluent Concentrations	2-2
2.4 Lagoon Discharge Concentrations	2-3
3. OPERATIONS.....	3-1
3.1 Events impacting operations	3-1
3.2 Emergency & Service calls.....	3-1
3.3 Emergency Call-outs	3-1
3.4 Customer Inquiries	3-1
4. MAINTENANCE AND REPAIR.....	4-3
4.1 Preventative and predictive maintenance.....	4-3
4.2 Corrective repairs	4-3
5. PROJECT MANAGEMENT & SUPPORT.....	5-1
5.1 Staffing & Training.....	5-1
5.2 Corporate Support.....	5-1
5.3 Budget.....	5-2
6. CAPITAL PLANNING	6-1
6.1 Approved CIP Projects Current status.....	6-1
6.2 Draft Capital Improvement Plan	6-1



LIST OF TABLES

TABLE	PAGE NO.
Table 2.2 Influent Concentrations and Flow.....	2-2
Table 2.3 Finished Water Quality.....	2-2
Table 2.4 Weekly Grab Sample Analysis Results.....	2-3
Table 4.1 Budget Table.....	5-2



EXECUTIVE SUMMARY

Safety. Safety is the number one priority at Woodard and Curran. We continue to provide monthly training for operations staff at the plant, provide weekly safety updates and safety videos are assigned to all employees. The safety topic for this month was “Incident Reporting and Evaluation”. There were no lost time accidents in the month of June 2018. 100 percent of the items identified in the combined list of safety items have been completed.

Compliance. The finished water quality was within regulatory limits and all reporting and sampling requirements were met for the month. A copy of the Operations Report submitted to the Illinois Environmental Protection Agency is available at www.sswc.us.

During the month of June 2018, the plant pumped 43.915 million gallons from the well field and 34.04 million gallons of finished water. For the period of July 2017 through June 2018, the plant has pumped 5.198 Million gallons less water then during the same period one year ago.

The SSWC plant has been placed on Critical Review status. Systems on Critical Review will be evaluated for sufficient capacity before issuance of water main extension permits.

Operations. There was 3 emergency call-outs for the month. There were 1 customer inquiries for the month.

Maintenance and Repair. For the month of June 2018, there were 10 inspections, 4 preventative and 14 corrective maintenance activities completed.

Budget. Through the end of the third year plus two month of the contract extension, we are \$27,221 under budget for the period. Please note that not all expenses for the 2017-2018 timeframe have been added to this summary.

Capital Planning. Woodard and Curran is working with MECO Engineering to update and prioritize the Capital Improvement Plan. The CIP is a planning document that includes all projects anticipated to exceed \$5,000 in cost over the next five years. The CIP is an ongoing process and will be refined from time to time as projects are completed and new issues are identified.



1. SAFETY

1.1 SAFETY TRAINING

Woodard and Curran continue to provide safety training for personnel at the plant. This is accomplished by requiring daily safety meetings, weekly safety updates are available to the plant, and safety videos are assigned to all employees and are required to be completed.

1.2 LOST TIME ACCIDENTS

There were 0 lost time accidents in the month of June 2018.

1.3 SAFETY AUDIT

Since Woodard and Curran assumed operational responsibility for the SSWC plant, two safety audits have been completed. The first audit was conducted in May 2015 and identified 89 items needing to be addressed. Approximately 86 percent of those items identified had been addressed when a second audit occurred in November 2016.

The finding for these two audits were combined to produce a list of 40 items needing to be addressed. As of November 30, 2017, 100 percent of the items have been addressed.

1.4 MISCELLANEOUS SAFETY

There were no Miscellaneous Safety items for the month.

2. COMPLIANCE, FLOWS AND LOADINGS

2.1 COMPLIANCE

The finished water quality was within regulatory limits and all reporting and sampling requirements were met for April. A copy of the Operations Report to the Illinois Environmental Protection Agency (IEPA) is available on the SSWC website.

2.2 INFLUENT FLOWS AND LOADINGS

The total gallons pumped from the well field was 43.915 MG. The influent parameters were all within the normal range.

The influent flow and loadings are summarized below in Table 2.2

Table 2.2 Influent Concentrations and Flow								
	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Well Flow Gals (k)
Max.	7.71	16.6	1.71	0.242	-	370	300	1.747
Min.	6.82	13.9	0.29	0.183	-	356	270	0.963
Avg.	7.27	15.2	0.82	0.211	-	363	282	1.417
Total	-	-	-	-	-	-	-	42.511

2.3 EFFLUENT CONCENTRATIONS

The facility filtered 34.04 MG during the month with a daily average of 1.134 MG and a min/max of 0.993/1.812 MG.

Table 2.3 Finished Water Quality										
	Free CL2	Total CL2	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Phosphate
Max.	1.8	2.0	7.86	20.6	0.003	0.036	1.34	240	280	2.03
Min.	.9	1.0	7.03	14.4	0.00	0.001	0..35	110	260	1.04
Avg.	1.4	1.5	7.44	15.5	0.00	0.012	0..78	131	272	1.34
MCL	-	-	-	-	1.00	-	4.00	-	-	-
SMCL	-	-	-	-	0.30	0.050	2.00	-	-	-

Finished Water Flow Comparison for FY 2018

Time Period	2017-2018	2016-2017	2015-2016
July-June	390,598,135	398,320,645	373,765,957
Increase for the same period last year		-5,895,000	

FINISHED WATER PUMPING HISTORY						
	2017-2018	2016-2017	2015-2016	2014-2015	2013-2014	2012-2013
July	42,164,927	35,378,396	33,123,375	38,674,894	40,908,704	57,780,876
August	38,760,634	35,401,490	38,109,033	33,748,543	42,999,243	42,398,528
September	39,896,986	36,325,215	36,546,171	29,763,075	37,597,085	32,510,603
October	33,506,605	34,374,820	34,783,455	28,803,052	33,916,594	30,278,765
November	28,617,333	30,478,309	27,217,293	28,426,579	31,615,459	27,114,479
December	28,808,037	32,525,530	27,788,637	28,656,869	32,697,551	29,014,035
January	30,556,824	30,449,215	28,510,121	30,346,721	32,499,427	28,007,432
February	25,617,914	27,373,232	26,095,228	26,336,077	28,745,378	25,763,807
March	28,217,699	30,068,363	27,851,811	28,729,919	31,217,486	28,130,190
April	27,110,578	29,625,797	29,292,618	29,270,184	31,690,073	27,991,597
May	33,304,196	32,120,873	33,349,391	33,371,016	31,157,411	29,592,356
June	34,040,000	39,931,402	41,541,321	31,092,539	38,462,951	36,530,691
	-----	-----	-----	-----	-----	-----
Totals	390,601,733	394,052,642	384,208,454	367,219,468	418,880,652	395,113,359
Average	1,070,141	1,079,596	1,052,625	1,006,080	1,147,618	1,082,502
Maximum	2,220,362	2,061,098	2,177,926	1,837,344	2,010,587	2,546,901
Minimum	423,165	275,315	-	349,690	363,767	142,411

2.4 LAGOON DISCHARGE CONCENTRATIONS

The results for the NPDES lagoon discharge permit are summarized below.

Table 2.4 Weekly Grab Sample Analysis Results

Lagoon Effluent Results						
Date	Fe (mg/l)	Mn (mg/l)	Chloride (mg/l)	Cl² (mg/l)	pH (S.U.)	TSS (mg/l)
						0
Minimum						
Maximum						
Average						
Monthly Avg Limit	2.000	1.000				15
Daily Limit	4.000	2.000	500	0.05	6.0-9.0	30

The Chloride sample for the month of May 2018, performed by the Springfield Metropolitan Sanitary District, was unknown as of June 15, 2018. The limit for chloride discharge to the sanitary district is 30,000 mg/L.

3. OPERATIONS

3.1 EVENTS IMPACTING OPERATIONS

Rehabilitation of Chatham Ground Storage tank- Although the rehabilitation of the Chatham Ground Storage Reservoir did not directly affect the operation of the plant, customers may have experienced fluctuations in pressure. Some customers may have experienced taste and odor issues due to the mixing of sub-par CWLP chloramine water with the SSWC produced water.

This project was completed on June 15, 2018.

SCADA Shut Down- During the month of June there were several instances of the Ultra -filters going off line and the plant SCADA shutting down. Do to this failure, on one occasion, the plant pressure dropped low enough that an emergency boil order had to be ordered.

Tonka Screen/Softener -On June 27th the softener control SCADA quit responding. We contacted SCADASERV to trouble shoot the system. After 3 days of trouble shooting the issue was resolved and the Tonka Control Module was operating normally.

Woodard & Curran believes that both instances of the system shutdowns were occurring because of power surges on the plant power. The power utility was notified, and they put on a line sensor to monitor the surges, although the utility states no issues were noted the surging has stopped and the systems have remained online.

3.2 EMERGENCY & SERVICE CALLS

Service Calls:

- There were no emergency call outs for the month.

3.3 EMERGENCY CALL-OUTS

There was 3 emergency call-out for the month requiring operational personnel at the plant after normal business hours.

3.4 CUSTOMER INQUIRIES

There were 1 customer inquiry for the month of June

OTHER WORK PERFORMED

Well #1 was chemically treated and flushed by Layne Well Service. After passing required bacteriological testing well #1 was placed back in service. Currently all Wells are in service and operating normally.



4. MAINTENANCE AND REPAIR

4.1 PREVENTATIVE AND PREDICTIVE MAINTENANCE

For the month of June 2018, there were 10 inspections, 5 preventative and 1 corrective maintenance activity completed.

4.2 CORRECTIVE REPAIRS

Filter Train 1 Backwash Valve. On June 1st, employees of Henson Robinson were on site to install fittings that we assembled earlier in the week for the leak on Train 1. As planned the reengineered fittings were able to relieve the strain at the joint.

Ultra-filters- In the month of May SSWC received a partial shipment of replacement Ultra-filter Modules. As June 30th we are still awaiting the final shipment of Ultra-filter Modules. The Modules have been shipped from overseas and are in route.

5. PROJECT MANAGEMENT & SUPPORT

5.1 STAFFING & TRAINING

- Woodard and Curran continue to train and provide staffing to the plant as needed. With Stephen Bivin providing training and support to Operator in Training Kevin Canham

5.2 CORPORATE SUPPORT

The following individuals, either on-site or remotely, aided in operation and/or maintenance of the plant during the month.

- Marc Thomas
- Ray Giguere
- Stephen Bivin
- Greg Frieden
- David Kraus
- Dan Held

5.3 BUDGET

Table 5.3 below is a breakdown of the current budget as of June 29, 2018. Please note that the final contract year has been extended to August 31, 2018.

Table 5.3 Budget Table

Budget Category	Month Budget	Month Actual	YTD Budget	YTD Actual	Annual Budget
Labor (D.L. + OH)	\$24,213	\$16,198	\$338,977	\$292,938	\$387,408
Utilities	\$8,150	\$14,927	\$114,100	\$123,697	\$130,400
Chemicals	\$14,583	\$24,896	\$204,162	\$213,439	\$233,328
Maintenance & Repair	\$9,102	\$3,004	\$118,327	\$144,053	\$145,632
Chloride	\$13,522	\$15,081	\$189,308	\$166,987	\$216,352
Lab Supplies and Equipment	\$1,882	\$808	\$26,348	\$17,869	\$30,112
Office Supplies	\$216	\$5	\$3,024	\$3,974	\$3,456
Miscellaneous Expenses	\$1,141	\$1,222	\$15,974	\$16,627	\$18,256
Other Operating Costs	\$1,398	\$6,099	\$19,572	\$25,481	\$22,368
Subtotal of Costs for Contract Year 3	\$74,206	\$82,240	\$1,029,812	\$1,005,065	\$1,187,312
Fixed Fee for Contract Year 3	\$7,421	\$8,224	\$102,981	\$100,507	\$118,731
Year One Transition			\$17,755	\$17,755	\$17,755
Total	\$81,627	\$90,464	\$1,150,548	\$1,123,327	\$1,323,798



6. CAPITAL PLANNING

6.1 APPROVED CIP PROJECTS CURRENT STATUS

No new information is available.

6.2 DRAFT CAPITAL IMPROVEMENT PLAN

The CIP is a planning document that includes all projects anticipated to exceed \$5,000 in cost over the next five years. The CIP is an ongoing process and will be refined from time to time as projects are completed and new issues are identified.

The most recent Capital List was included in the Year 2 Annual Report.





MONTHLY IRON REMOVAL AND ION EXCHANGE SOFTENING REPORT
ON South Sangamon Water Commission
FOR MONTH OF June 2018

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES

Time Date	Hours Meter Read	Pumping Totals		Chemicals Applied						UF Filters				Softeners				Soft. Regen				Chloride														
		UF Gal	Water Filtered (M gal)	Plant Water (M gal)	Chlorine Used (lbs.)	Fluoride Used (lbs.)	Phosphate Used (lbs.)	Nalim04 Used (lbs.)	Am't Used (lbs.)	Calc mg/l	Am't Used (lbs.)	Calc mg/l	Bi-Sulfite mg/l	Wash Gal. (M gal)	Water Softened Gal.	Bypassed Gal.	Water Gal. (M gal)	Each day indicates total number of hours since previous regeneration. If regeneration is mid-day, indicate hours previous.	1	2	3	4	Salt Used (lbs.)	Washed Water Gal.	In mg/L	IEX 1	IEX 2	IEX 3	IEX 4							
1	7:00	16.0	1.114	0.968	0.012	2.390	3.22	36.0	1.47	23.0	0.94	30.00	2.97				0.66	0.66	0.66	0.66	0.66	0.133	0.735	0.379	2,110	2,309										
2	7:00	18.3	1.168	1.084	0.011	2.190	2.81	37.0	1.35	29.0	1.06	29.00	2.72				0.66	0.66	0.66	0.66	0.66	0.137	0.771	0.397	433	602										
3	7:00	19.0	1.437	1.151	0.017	2.460	2.57	41.0	1.41	39.0	1.34	33.00	3.00				0.66	0.66	0.66	0.66	0.66	0.188	0.948	0.489	1,634	1,357	1,801	2,308								
4	7:00	20.4	1.439	1.255	0.018	2.180	2.27	41.0	1.29	29.00	2.24						0.66	0.66	0.66	0.66	0.66	0.173	0.950	0.489	1,440											
5	7:00	21.2	1.446	1.213	0.008	2.210	2.29	39.0	1.27	43.0	1.40	30.00	2.35				0.66	0.66	0.66	0.66	0.66	0.162	0.954	0.492	407	812	644	2,125								
6	7:00	21.6	1.444	1.244	0.018	2.160	2.24	35.0	1.11	40.0	1.27	29.00	2.27				0.66	0.66	0.66	0.66	0.66	0.164	0.953	0.491	1,452	3,081	1,043									
7	7:00	20.4	1.443	1.187	0.011	2.050	2.13	36.0	1.20	41.0	1.37	23.00	1.78				0.66	0.66	0.66	0.66	0.66	0.162	0.952	0.491		431										
8	7:00	19.0	1.348	1.150	0.004	2.110	2.35	36.0	1.24	9.0	0.31	29.00	2.20				0.66	0.66	0.66	0.66	0.66	0.155	0.890	0.458	407	540										
9	7:00	19.3	1.394	1.177	0.015	1.490	1.60	26.0	0.87	12.0	0.40	21.00	1.61				0.66	0.66	0.66	0.66	0.66	0.114	0.702	0.474	1,902	2,107										
10	7:00	15.2	1.064	0.914	0.010	1.610	2.27	24.0	1.04	13.0	0.56	23.00	2.42				0.66	0.66	0.66	0.66	0.66	0.150	0.791	0.408	1,544	402										
11	7:00	13.0	0.885	0.761	0.009	1.580	2.68	26.0	1.35	19.0	0.99	22.00	2.74				0.66	0.66	0.66	0.66	0.66	0.106	0.584	0.301		433										
12	7:00	14.1	0.977	0.793	0.004	1.590	2.44	26.0	1.30	22.0	1.10	22.00	2.58				0.66	0.66	0.66	0.66	0.66	0.124	0.645	0.332	2,107	753	1,938									
13	7:00	16.6	1.063	0.943	0.014	2.040	2.88	36.0	1.51	35.0	1.47	26.00	2.85				0.66	0.66	0.66	0.66	0.66	0.126	0.702	0.361		724										
14	7:00	16.1	1.085	1.000	0.004	2.420	3.34	42.0	1.66	46.0	1.82	33.00	3.39				0.66	0.66	0.66	0.66	0.66	0.130	0.716	0.369	1,335	806	1,606	1,126								
15	7:00	21.2	1.595	1.403	0.018	1.440	1.35	32.0	0.90	38.0	1.07	19.00	1.35				0.66	0.66	0.66	0.66	0.66	0.178	1.053	0.542		1,822										
16	7:00	16.6	1.595	1.336	0.008	2.590	2.42	41.0	1.21	47.0	1.39	35.00	3.12				0.66	0.66	0.66	0.66	0.66	0.178	1.053	0.542		910	1,037									
17	7:00	16.8	2.568	1.017	0.009	2.650	1.55	38.0	1.48	51.0	1.98	31.00	2.68				0.66	0.66	0.66	0.66	0.66	0.267	1.695	0.873	1,802	1,602	1,928	521								
18	7:00	19.3	1.513	1.263	0.017	1.830	1.81	26.0	0.81	16.0	0.50	21.00	1.59				0.66	0.66	0.66	0.66	0.66	0.169	0.899	0.514		654	935	1,352	1,158							
19	7:00	20.8	1.575	1.346	0.005	2.240	2.13	36.0	1.06	19.0	0.56	28.00	2.00				0.66	0.66	0.66	0.66	0.66	0.182	1.040	0.536		146	18	1,146								
20	7:00	15.1	1.161	1.096	0.016	2.000	2.58	33.0	1.19	20.0	0.72	28.00	2.77				0.66	0.66	0.66	0.66	0.66	0.173	0.943	0.486												
21	7:00	18.5	1.429	1.129	0.009	2.160	2.27	39.0	1.37	26.0	0.91	30.00	2.38				0.66	0.66	0.66	0.66	0.66	0.153	0.880	0.453	1,058	1,941	2,221	1,737								
22	7:00	19.4	1.532	1.316	0.018	2.210	2.16	40.0	1.20	42.0	1.26	30.00	2.23				0.66	0.66	0.66	0.66	0.66	0.174	1.011	0.521												
23	7:00	15.9	1.245	1.162	0.000	2.590	3.12	45.0	1.53	49.0	1.67	34.00	3.14				0.66	0.66	0.66	0.66	0.66	0.136	0.822	0.423												
24	7:00	21.2	1.638	1.486	0.013	1.960	1.79	31.0	0.83	5.0	0.13	26.00	1.78				0.66	0.66	0.66	0.66	0.66	0.180	1.081	0.557	1,136	2,252	900									
25	7:00	18.9	1.452	1.110	0.018	2.550	2.63	42.0	1.50	22.0	0.78	32.00	2.56				0.66	0.66	0.66	0.66	0.66	0.178	0.958	0.494		1,327										
26	7:00	19.4	1.358	1.218	0.004	2.620	2.89	40.0	1.30	28.0	0.91	32.00	2.62				0.66	0.66	0.66	0.66	0.66	0.152	0.896	0.462	1,201	37	841	2,208								
27	7:00	20.9	1.617	1.418	0.013	2.640	2.45	40.0	1.12	35.0	0.98	31.00	2.15				0.66	0.66	0.66	0.66	0.66	0.192	1.067	0.550												
28	7:00	20.4	1.466	1.225	0.004	2.520	2.58	39.0	1.26	41.0	1.32	30.00	2.35				0.66	0.66	0.66	0.66	0.66	0.177	0.968	0.488	518	1,211	236	900								
29	7:00																0.66	0.66	0.66	0.66	0.66															
30	7:00																0.66	0.66	0.66	0.66	0.66															
31	7:00																0.66	0.66	0.66	0.66	0.66															
Total																																				
Max																																				
Min																																				
Ave.																																				

Enter Final Reading Last Month: 34.41
RTW Sample: 1.49 °C, 0.76 TDS, 1.15 pH, Sulfate mg/L

CHLORINATION: Type of Chlorine Used
Chlorine Gas _____
Calcium Hypochlorite _____
Sodium Hypochlorite 12.5 % _____
Chlorine Test Kit Used: _____

FLUORIDATION: Type of Fluoride Used
Hydrofluosilicic Acid .23 % F _____
Sodium Fluoride _____
Other _____
Type of Test Instrument Used: _____

METER LOCATION:
1. 12.5 % Chlorine Solution Fed _____
2. 23 % Fluoride Solution Fed _____
3. 40 % Bisulfite Solution Fed _____
4. 33 % Phosphate Solution Fed _____
5. 20 % Sodium Permanganate Fed _____
Bacterials Sent: _____
Date: _____

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES
MONTHLY IRON REMOVAL AND ION EXCHANGE SOFTENING REPC
ON
South Sangamon Water Commission
FOR MONTH OF
June 2018

Date	Time Meter Filler Ran	Pumping Totals			Raw			Pre Filter			Post Filter			Chemical Test			Membrane Integrity Test																		
		Hours	Total Well (M gal)	UF Filtered (M gal)	Plant Treated Water (M gal)	Total	Hard.	Alk.	Total	Total	Fe	Mn	Total	Total	Mem	Turb.	Fe	Mn	Total	Total	Fe	Mn	Total	Dist. Cl Res F = Free T = Total	F mg/L	T mg/L	Bank 1	Bank 2	Bank 3						
1	7:00	16.0	1,262	1,114	0,968	0,012	7.04	15.1	290	362	0.55	0.195	0.348	0.016	0.031	0.36	7.03	270	126	0.01	0.006	0.85	1.3	1.4	1.24										
2	7:00	18.3	1,332	1,168	1,084	0,011	7.47	14.8	280	360	0.95	0.183	0.351	0.010	0.022	0.46	7.54	270	130	0.00	0.009	1.12	1.8	1.9	1.31										
3	7:00	19.0	1,412	1,437	1,151	0,017	7.71	15.1	290	360	0.88	0.210	0.354	0.016	0.021	0.36	7.77	268	124	0.01	0.018	0.76	1.5	1.5	1.36										
4	7:00	20.4	1,620	1,439	1,255	0,018	7.28	14.0	286	358	1.64	0.208	0.347	0.013	0.025	0.31	7.49	274	120	0.00	0.005	0.76	1.6	1.6	1.39										
5	7:00	21.2	1,582	1,446	1,213	0,008	7.03	15.3	290	358	0.58	0.197	0.371	0.016	0.035	0.43	7.04	270	136	0.00	0.007	0.75	1.1	1.2	1.04										
6	7:00	21.6	1,590	1,444	1,244	0,018	7.24	13.9	290	368	0.58	0.194	0.357	0.016	0.021	0.22	7.47	274	122	0.00	0.007	0.83	1.5	1.5	1.12					Pass					
7	7:00	20.4	1,602	1,443	1,187	0,011	7.29	14.1	292	360	0.68	0.198	0.360	0.020	0.024	0.38	7.54	274	120	0.01	0.005	0.82	1.3	1.4	1.24					Pass					
8	7:00	19.0	1,474	1,348	1,150	0,004	7.35	15.2	300	364	0.86	0.207	0.360	0.031	0.033	0.23	7.80	280	120	0.00	0.011	0.89	1.5	1.5	1.22										
9	7:00	16.7	1,266	1,199	1,059	0,011	7.45	15.9	290	356	0.46	0.204	0.362	0.028	0.024	0.31	7.39	278	120	0.00	0.012	1.12	1.4	1.4	1.79										
10	7:00	16.7	1,266	1,199	1,059	0,011	7.45	15.9	290	356	0.46	0.204	0.360	0.028	0.024	0.31	7.39	278	120	0.00	0.012	1.12	1.4	1.4	1.79										
11	7:00	15.2	1,171	1,064	0,914	0,010	7.03	15.5	280	368	0.51	0.206	0.330	0.023	0.032	0.40	7.59	280	120	0.02	0.014	1.34	1.0	1.1	2.03										
12	7:00	13.0	0,983	0,885	0,761	0,009	7.17	15.7	286	364	1.00	0.220	0.345	0.028	0.018	0.31	7.49	270	128	0.00	0.004	0.74	1.5	1.6	1.40										
13	7:00	14.1	1,061	0,977	0,793	0,004	7.03	15.0	290	370	1.20	0.223	0.375	0.029	0.035	0.29	7.03	276	128	0.00	0.029	0.77	1.4	1.5	1.34					Pass					
14	7:00	16.6	1,222	1,063	0,943	0,014	7.20	15.7	280	366	1.39	0.212	0.352	0.020	0.031	0.30	7.51	270	130	0.01	0.013	0.87	1.4	1.5	1.20					Pass					
15	7:00	16.1	1,223	1,085	1,000	0,004	7.29	14.8	282	370	1.71	0.234	0.365	0.053	0.050	0.30	7.50	272	132	0.00	0.017	0.85	1.4	1.5	1.25										
16	7:00	21.2	1,760	1,595	1,403	0,018	7.36	14.9	286	380	1.27	0.217	0.391	0.026	0.036	0.33	7.26	276	136	0.00	0.011	0.69	1.5	1.5	1.36										
17	7:00	16.6	1,388	1,595	1,336	0,008	7.34	16.6	280	370	0.85	0.218	0.360	0.020	0.030	0.35	7.26	276	136	0.00	0.020	0.35	1.4	1.4	1.96										
18	7:00	16.8	1,419	2,568	1,017	0,009	7.27	16.2	280	360	0.89	0.219	0.366	0.016	0.032	0.31	7.57	270	118	0.00	0.014	0.42	1.4	1.5	1.29					Pass					
19	7:00	20.3	1,655	1,513	1,263	0,017	7.04	14.9	272	366	0.97	0.213	0.370	0.021	0.029	0.33	7.03	268	130	0.00	0.014	0.72	1.5	1.7	1.37					Pass					
20	7:00	20.4	1,575	1,346	0,005	7.04	15.1	280	360	0.80	0.213	0.370	0.023	0.034	0.44	7.52	270	126	0.00	0.009	0.74	1.2	1.4	1.22					Pass						
21	7:00	15.1	1,272	1,161	1,096	0,016	7.22	15.1	274	362	0.58	0.200	0.346	0.020	0.035	0.44	7.57	274	128	0.00	0.020	0.76	1.7	1.7	1.31										
22	7:00	18.5	1,576	1,429	1,129	0,009	7.22	15.1	280	360	0.80	0.224	0.353	0.031	0.053	0.47	7.55	260	120	0.00	0.018	0.68	1.2	1.4	1.28										
23	7:00	18.2	1,459	1,333	1,088	0,009	7.34	15.0	274	364	0.71	0.206	0.351	0.022	0.036	0.51	7.27	266	124	0.00	0.012	0.76	1.4	1.4	1.27										
24	7:00	19.4	1,677	1,532	1,316	0,018	6.82	15.6	274	366	0.52	0.224	0.360	0.025	0.049	0.38	7.14	272	128	0.00	0.013	0.64	1.3	1.5	1.23										
25	7:00	15.9	1,352	1,245	1,162	0,000	7.30	14.7	270	362	0.29	0.204	0.361	0.024	0.040	0.40	7.52	270	160	0.00	0.009	1.05	0.9	1.0	1.29										
26	7:00	21.2	1,812	1,638	1,486	0,013	7.56	14.5	280	360	0.69	0.236	0.361	0.024	0.044	0.39	7.86	270	180	0.00	0.011	0.65	1.1	1.6	1.29										
27	7:00	18.9	1,550	1,452	1,110	0,018	7.34	15.5	270	364	0.53	0.209	0.360	0.021	0.044	0.28	7.52	270	120	0.00	0.004	0.53	1.3	1.4	1.18					Pass					
28	7:00	19.4	1,520	1,358	1,218	0,004	7.24	15.1	280	360	0.73	0.202	0.353	0.012	0.030	0.26	7.51	270	110	0.00	0.001	0.66	1.7	1.6	1.49					Pass					
29	7:00	20.9	1,793	1,617	1,418	0,013	7.54	14.8	278	364	0.77	0.206	0.345	0.015	0.039	0.40	7.25	268	122	0.01	0.005	0.56	1.4	2.0	1.41					Pass					
30	7:00	20.4	1,596	1,466	1,225	0,004	7.31	15.4	280	360	0.59	0.242	0.407	0.042	0.083	0.44	7.75	270	240	0.01	0.036	0.78	1.1	1.3	1.18										
31	7:00																																		
Total																																			
Max																																			
Min																																			
Ave.																																			

*Enter Final Reading Last Month

POINT OF APPLICATION

METER LOCATION:

1. 12.5 % Chlorine Solution Fed
 2. 23 % Fluoride Solution Fed
 3. 40 % Bisulfite Solution Fed
 4. 33 % Phosphate Solution Fed
 5. 20 % Sodium Permanganate Fed

I certify that the information in this report is complete and accurate to the best of my knowledge
 Reported by: _____ Cart or Req: _____
 Bacterials Sent: _____ Date: _____

CHLORINATION
 Type of Chlorine Used _____
 Chlorine Gas _____
 Calcium Hypochlorite _____ %
 Sodium Hypochlorite _____ 12.5 %
 Chlorine Test Kit Used: _____

FLUORIDATION
 Type of Fluoride Used _____
 Hydrofluosilicic Acid _____ 23 %
 Sodium Fluoride _____ %
 Other _____
 Type of Test Instrument Used: _____