



Monthly Operating Report

AUGUST 2018



0217327.00

So. Sangamon

September 26, 2018

woodardcurran.com
COMMITMENT & INTEGRITY DRIVE RESULTS

TABLE OF CONTENTS



SECTION	PAGE NO.
Executive Summary.....	ES-1
1. SAFETY	1-1
1.1 Safety Training	1-1
1.2 Lost time Accidents	1-1
1.3 Safety Audit	1-1
1.4 Miscellaneous Safety.....	1-1
2. COMPLIANCE, FLOWS AND LOADINGS	2-2
2.1 Compliance	2-2
2.2 Influent flows and loadings	2-2
2.3 Effluent Concentrations	2-2
2.4 Lagoon Discharge Concentrations	2-3
3. OPERATIONS.....	3-1
3.1 Events impacting operations	3-1
3.2 Emergency & Service calls.....	3-1
3.3 Emergency Call-outs	3-1
3.4 Customer Inquiries	3-1
4. MAINTENANCE AND REPAIR.....	4-4
4.1 Preventative and predictive maintenance.....	4-4
4.2 Corrective repairs	4-4
5. PROJECT MANAGEMENT & SUPPORT	5-1
5.1 Staffing & Training.....	5-1
5.2 Corporate Support.....	5-1
5.3 Budget.....	5-2
6. CAPITAL PLANNING	6-1
6.1 Approved CIP Projects Current status.....	6-1
6.2 Draft Capital Improvement Plan	6-1



LIST OF TABLES

TABLE	PAGE NO.
Table 2.2 Influent Concentrations and Flow.....	2-2
Table 2.3 Finished Water Quality.....	2-2
Table 2.4 Weekly Grab Sample Analysis Results.....	2-3
Table 4.1 Budget Table.....	5-2



EXECUTIVE SUMMARY

Safety. Safety is the number one priority at Woodard and Curran. We continue to provide monthly training for operations staff at the plant, provide weekly safety updates and safety videos are assigned to all employees. The safety topic for this month was “Incident Reporting and Evaluation”. There were no lost time accidents in the month of August 2018. 100 percent of the items identified in the combined list of safety items have been completed.

Compliance. The finished water quality was within regulatory limits and all reporting and sampling requirements were met for the month. A copy of the Operations Report submitted to the Illinois Environmental Protection Agency is available at www.sswc.us.

During the month of August 2018, the plant pumped 52.453 million gallons from the well field and 41.178 million gallons of finished water. For the period of September 2017 through August 2018, the plant has pumped 11.224 Million gallons less gallons of water than during the same period one year ago.

The SSWC plant has been placed on Critical Review status. Systems on Critical Review will be evaluated for sufficient capacity before issuance of water main extension permits.

Operations. There was 8 emergency call-outs for the month. There were 0 customer inquiries for the month.

Maintenance and Repair. For the month of August 2018, there were 10 inspections, 4 preventative and 14 corrective maintenance activities completed.

Budget. The final cost information will be provided when the expenses are finalized.

Capital Planning. Woodard and Curran is working with MECO Engineering to update and prioritize the Capital Improvement Plan. The CIP is a planning document that includes all projects anticipated to exceed \$5,000 in cost over the next five years. The CIP is an ongoing process and will be refined from time to time as projects are completed and new issues are identified.



1. SAFETY

1.1 SAFETY TRAINING

Woodard and Curran continue to provide safety training for personnel at the plant. This is accomplished by requiring daily safety meetings, weekly safety updates are available to the plant, and safety videos are assigned to all employees and are required to be completed.

1.2 LOST TIME ACCIDENTS

There were 0 lost time accidents in the month of August 2018.

1.3 SAFETY AUDIT

Since Woodard and Curran assumed operational responsibility for the SSWC plant, two safety audits have been completed. The first audit was conducted in May 2015 and identified 89 items needing to be addressed.

The findings for these two audits were combined to produce a list of 40 items needing to be addressed. As of November 30, 2017, 100 percent of the items have been addressed.

1.4 MISCELLANEOUS SAFETY

There were no Miscellaneous Safety items for the month.

2. COMPLIANCE, FLOWS AND LOADINGS

2.1 COMPLIANCE

The finished water quality was within regulatory limits and all reporting and sampling requirements were met for August. A copy of the Operations Report to the Illinois Environmental Protection Agency (IEPA) is available on the SSWC website.

2.2 INFLUENT FLOWS AND LOADINGS

The total gallons pumped from the well field was 52.453 MG. The influent parameters were all within the normal range.

The influent flow and loadings are summarized below in Table 2.2

Table 2.2 Influent Concentrations and Flow								
	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Well Flow Gals (mgd).
Max.	7.90	16.9	1.6	.3	-	380	286	1.893
Min.	7.20	14.2	.50	.2	-	350	270	1.234
Avg.	7.40	14.9	1.0	0.250	-	358.3	280	1.692
Total	-	-	-	-	-	-	-	47.0

2.3 EFFLUENT CONCENTRATIONS

The facility filtered 47.769 MG during the month with a daily average of 1.541 MG and a min/max 1.163/1.719 MG.

Table 2.3 Finished Water Quality										
	Free CL2	Total CL2	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Phosphate
Max.	1.7	1.9	8.40	15.8	.000	0.024	1.3	180	370	1.5
Min.	1.2	1.4	7.04	14.3	0.00	0.006	0.6	110	206	.6
Avg.	1.5	1.8	7.50	15.2	0.00	0.015	0.8	128	282	1.28
MCL	-	-	-	-	1.00	-	4.00	-	-	-
SMCL	-	-	-	-	0.30	0.050	2.00	-	-	-

Finished Water Flow Comparison for FY 2018

Time Period	2017-2018	2016-2017	2015-2016
September-August	386,031,132	404,198,317	383,755,982
Increase for the same period last year		-18.167 MG	

FINISHED WATER PUMPING HISTORY						
	2017-2018	2016-2017	2015-2016	2014-2015	2013-2014	2012-2013
September	39,896,986	36,325,215	36,546,171	29,763,075	37,597,085	32,510,603
October	33,506,605	34,374,820	34,783,455	28,803,052	33,916,594	30,278,765
November	28,617,333	30,478,309	27,217,293	28,426,579	31,615,459	27,114,479
December	28,808,037	32,525,530	27,788,637	28,656,869	32,697,551	29,014,035
January	30,556,824	30,449,215	28,510,121	30,346,721	32,499,427	28,007,432
February	25,617,914	27,373,232	26,095,228	26,336,077	28,745,378	25,763,807
March	28,217,699	30,068,363	27,851,811	28,729,919	31,217,486	28,130,190
April	27,110,578	29,625,797	29,292,618	29,270,184	31,690,073	27,991,597
May	33,304,196	32,120,873	33,349,391	33,371,016	31,157,411	29,592,356
June	34,040,000	39,931,402	41,541,321	31,092,539	38,462,951	36,530,691
July	41,178,722	42,164,927	35,378,396	33,123,375	38,674,894	40,908,704
August	35,176,238	38,760,634	35,401,490	38,109,133	33,748,543	42,999,243
	-----	-----	-----	-----	-----	-----
Totals	386,031,132	404,198,317	383,755,932	366,028,539	402,022,852	378,841,902
Average	1,123,654	1,098,190	1,058,804	1,007,794	1,154,319	1,036,277
Maximum	2,220,362	2,061,098	2,177,926	1,837,344	2,010,587	2,546,901
Minimum	423,165	275,315	-	349,690	363,767	142,411

2.4 LAGOON DISCHARGE CONCENTRATIONS

The results for the NPDES lagoon discharge permit are summarized below.

Table 2.4 Weekly Grab Sample Analysis Results

Lagoon Effluent Results						
Date	Fe (mg/l)	Mn (mg/l)	Chloride (mg/l)	Cl ² (mg/l)	pH (S.U.)	TSS (mg/l)
						0
Minimum		.4	unknown			unknown
Maximum		.4	unknown			unknown
Average						
Monthly Avg Limit	2.000	1.000				15
Daily Limit	4.000	2.000	500	0.05	6.0-9.0	30

The Chloride sample for the month of July 2018, performed by the Springfield Metropolitan Sanitary District, was unknown as of August, 2018. The limit for chloride discharge to the sanitary district is 30,000 mg/L.



3. OPERATIONS

3.1 EVENTS IMPACTING OPERATIONS

PLANT SHUTDOWN - During the month of August the plant had a power surge that knocked out the SCADA system and caused the plant to shut down. In turn the high service pumps drained the clearwell and caused the system pressure to drop below acceptable EPA limits. On August 17th a boil order was issued, per EPA requirements, on August 18th, after receiving a negative coliform sample, the boil order was lifted.

3.2 EMERGENCY & SERVICE CALLS

Service Calls:

- There were no emergency call outs for the month.

3.3 EMERGENCY CALL-OUTS

There was 5 emergency call-out for the month requiring operational personnel at the plant after normal business hours

3.4 CUSTOMER INQUIRIES

There was 0 customer inquires for the month.

OTHER WORK PERFORMED

On August 7th compressor number 2 went down. Called HTE to do a service call. Was told to replace thermostat. Ordered and replaced thermostat. This did not fix the problem. While waiting for the service appointment, compressor number 2 went down. Had to make an emergency call to have them fixed.

Lagoon effluent pump 1 clogged. Called Henson Robinson to repair. Vacuumed out the pit, cleared pump 1 and repaired pump 2 that had been taken out of service the beginning of the year.



Drained and inspected East lagoon.

On August 24th a new UPS unit was installed in the Westech main panel in hopes of stopping surge-based shutdowns.

Due to the plant shutdown and SCADA failure HSP #3 damaged a seal. Pump 3 has been taken out of service and dismantled to perform diagnostics and repairs.

The week of August 20th new logic was written into the SCADA to prevent the HSPs from running dry and being damaged if a surge-based outage should occur again.

Repairs to the ExMark mower.



4. MAINTENANCE AND REPAIR

4.1 PREVENTATIVE AND PREDICTIVE MAINTENANCE

For the month of August 2018, there were 10 inspections, 5 preventative and 7 corrective maintenance activity completed.

4.2 CORRECTIVE REPAIR

Lagoon effluent pump- At the beginning of the year lagoon effluent pump #2 was taken out of service due to a malfunctioning flange and seal. This month there was an issue with the pump rate of pump #1. Henson Robinson was called and upon inspection found that pump #1 had sucked up a turtle and the shell was impeding the flow, but while in the pit, the repairs that pump #2 and we returned it back to service

SCADA ISSUES – There have been multiple issues with the SCADA programming that has been trouble shot by SCADASERV.

5. PROJECT MANAGEMENT & SUPPORT

5.1 STAFFING & TRAINING

- Woodard and Curran continue to train and provide staffing to the plant as needed. With Stephen Bivin providing training and support to Operator in Training Kevin Canham

5.2 CORPORATE SUPPORT

The following individuals, either on-site or remotely, provided assistance in operation and/or maintenance of the plant during the month.

- Marc Thomas
- Kevin Canham
- Ray Giguere
- Stephen Bivin
- Greg Frieden
- David Kraus



5.3 BUDGET

Table 5.3 is not available. Please note that final numbers will be available once all expenses are processed.

Table 5.3 Budget Table



6. CAPITAL PLANNING

6.1 APPROVED CIP PROJECTS CURRENT STATUS

No new information is available.

6.2 DRAFT CAPITAL IMPROVEMENT PLAN

The CIP is a planning document that includes all projects anticipated to exceed \$5,000 in cost over the next five years. The CIP is an ongoing process and will be refined from time to time as projects are completed and new issues are identified.

The most recent Capital List was included in the Year 2 Annual Report.



MENTAL PROTECTION AGENCY

DIVISION OF PUBLIC WATER SUPPLIES

MONTHLY IRON REMOVAL AND ION EXCHANGE SOFTENING REPORT
ON
South Sangamon Water Commission
FOR MONTH OF
August 2018

Pumpkin Totals	Raw											Pre-Filter				Post-Filter				Post-EX				Finished			
	UF	Total Gallons Filtered (M gal)	Water Treated (M gal)	Plant Water (M gal)	pH	Temp deg-C	Aux. Hard mg/L	Total mg/L	Total Fe mg/L	Total Mn mg/L	Total Total mg/L	Tot Fe mg/L	Tot Mn mg/L	Tot Total mg/L	Total Hard mg/L	Total Fe mg/L	Total Mn mg/L	Total Total mg/L	Total Hard mg/L	Total Fe mg/L	Total Mn mg/L	Total Total mg/L	F mg/L	F = Fines mg/L	Pd4.3 mg/L		
1584	1450	1273	0.013	7.30	14.4	284	380	154	0.230	0.354	0.029	0.041	0.47	7.62	284	180	0.09	0.015	0.84	1.6	1.7	1.02					
1629	1472	1164	0.013	7.31	14.2	280	356	114	0.179	0.263	0.025	0.023	0.42	7.52	284	190	0.09	0.022	0.98	1.5	1.8	1.26					
1573	1423	1196	0.013	7.27	15.3	280	352	120	0.226	0.380	0.029	0.023	0.25	7.67	280	110	0.01	0.015	0.96	1.6	1.9	1.33					
1643	1498	1324	0.018	7.43	14.6	282	384	114	0.226	0.359	0.018	0.041	0.38	7.59	282	120	0.01	0.012	0.89	1.7	1.8	1.26					
1738	1590	1412	0.010	7.24	14.5	282	356	109	0.274	0.371	0.014	0.025	0.44	7.74	280	118	0.01	0.014	0.87	1.6	1.7	1.52					
1717	1588	1398	0.007	7.40	15.0	280	354	101	0.218	0.370	0.023	0.027	0.49	7.61	284	118	0.01	0.017	0.94	1.7	1.8	1.26					
1689	1463	1098	0.014	7.25	14.6	286	350	153	0.228	0.356	0.023	0.032	0.42	8.10	282	118	0.01	0.016	0.64	1.5	1.8	1.16					
1446	1285	1104	0.011	7.25	14.8	286	362	124	0.217	0.361	0.028	0.025	0.53	7.58	272	120	0.02	0.013	0.81	1.7	1.9	1.27					
1583	1421	1260	0.010	7.30	14.7	286	370	187	0.222	0.379	0.032	0.041	0.39	7.64	280	130	0.01	0.006	0.77	1.4	1.8	1.20					
1882	1524	1329	0.020	7.26	14.4	280	354	106	0.206	0.407	0.024	0.042	0.28	7.45	208	180	0.02	0.024	0.91	1.2	1.6	1.32					
1750	1497	1374	0.012	7.26	14.6	280	354	106	0.206	0.407	0.024	0.042	0.28	7.56	270	130	0.02	0.010	0.95	1.6	1.9	1.36					
1707	1575	1418	0.011	7.38	14.9	274	350	117	0.203	0.390	0.028	0.027	0.49	7.66	272	120	0.01	0.011	0.86	1.5	1.7	1.33					
1763	1598	1332	0.015	7.35	14.8	270	350	140	0.204	0.355	0.016	0.026	0.27	7.80	270	130	0.01	0.006	0.77	1.5	1.8	1.32					
1668	1525	1280	0.024	7.32	15.2	276	360	104	0.222	0.346	0.011	0.022	0.41	7.65	280	120	0.01	0.011	0.85	1.6	1.8	1.32					
1538	1525	1325	0.003	7.39	15.3	280	350	150	0.214	0.360	0.018	0.026	0.46	7.40	280	130	0.01	0.019	0.86	1.2	1.6	1.18					
0.421	0.000	0.180	0.000	7.31	15.1	274	350	140	0.246	0.360	0.018	0.018	0.28	8.05	280	130	0.00	0.018	0.86	1.3	1.6	0.93					
0.973	0.812	0.788	0.015	7.31	14.9	282	350	140	0.222	0.360	0.014	0.018	0.26	7.66	272	120	0.00	0.003	0.98	1.5	1.7	1.33					
699	1524	1406	0.006	7.37	15.0	280	350	140	0.219	0.360	0.021	0.025	0.54	7.83	272	140	0.01	0.011	0.89	1.5	1.7	1.33					
1979	1453	1133	0.013	7.27	14.7	280	350	140	0.230	0.360	0.021	0.026	0.23	7.80	270	130	0.01	0.006	0.77	1.5	1.8	1.32					
1450	1308	1133	0.008	7.38	14.8	278	344	125	0.218	0.354	0.021	0.026	0.23	7.58	280	120	0.01	0.008	0.88	1.5	1.9	1.36					
373	1254	1098	0.013	7.58	16.9	270	354	113	0.219	0.360	0.015	0.047	0.28	7.51	272	1220	0.02	0.018	0.98	1.5	1.9	1.47					
489	1369	1163	0.016	7.59	16.3	276	360	113	0.221	0.360	0.015	0.047	0.28	7.85	278	120	0.01	0.011	0.92	1.6	1.8	1.28					
334	1226	1021	0.025	7.37	15.0	280	356	114	0.218	0.360	0.024	0.028	0.48	7.57	272	125	0.00	0.008	1.27	1.4	1.8	1.17					
428	1301	1174	0.012	7.35	15.0	274	360	104	0.215	0.360	0.024	0.031	0.37	7.56	278	122	0.00	0.013	0.75	1.3	1.7	1.27					
437	1306	1148	0.005	7.58	15.0	270	360	0.97	0.223	0.360	0.020	0.027	0.40	7.86	382	142	0.01	0.015	0.67	1.2	1.4	1.18					
1537	1508	1341	0.013	7.33	15.0	282	360	0.88	0.216	0.328	0.039	0.097	0.42	7.86	370	138	0.01	0.010	0.75	1.3	1.8	1.36					
1598	1454	1162	0.007	7.32	14.8	280	360	0.93	0.210	0.308	0.004	0.092	0.42	7.63	280	122	0.01	0.018	1.02	1.5	1.9	1.35					
417	1287	1075	0.007	7.49	14.5	286	370	138	0.221	0.294	0.023	0.092	0.34	7.90	270	120	0.01	0.018	0.73	1.5	1.7	1.34					
370	1238	1099	0.018	7.51	14.7	286	368	0.89	0.222	0.379	0.046	0.029	0.23	7.62	280	116	0.01	0.018	0.83	1.5	1.8	1.21					
47.0	42.5	36.7	0.3																								
1.8	1.6	1.4	0.0	7.9	16.9	286.0	380.0	1.6	0.3	0.0	0.4	0.1	0.0	8.1	370.0	##	0.0	0.0	1.3	1.7	1.9	1.5					
0.4	0.0	0.2	0.0	7.2	14.2	270.0	350.0	0.5	0.2	0.0	0.3	0.0	0.0	7.4	208.0	110.0	0.0	0.0	0.6	1.2	1.4	0.9					
1.5	1.4	1.2	0.0	7.4	14.9	279.5	358.3	1.0	0.2	0.0	0.4	0.0	0.0	7.7	281.7	##	0.0	0.0	0.8	1.5	1.8	1.3					

I certify that the information in this report is complete and accurate to the best of my knowledge.
 Reported by: _____
 Cell or Reg: _____
 Permanganate Fed Date: _____

Type of Chlorine Used
 Chlorine Gas _____
 Sodium Hypochlorite _____ %
 Sodium Hypochlorite _____ 12.5 %
 Chlorine Test Kit Used _____

Type of Fluoride Used
 Hydrofluosulfonic Acid _____ 23. _____ %
 Sodium Fluoride _____ %
 Other _____
 Type of Test Instrument Used _____

MONTHLY IRON REMOVAL AND ION EXCHANGE SOFTENING REPORT

South Sangamon Water Commission
August 2018

Page 1 of 2

WIRONMENTAL PROTECTION AGENCY

DIVISION OF PUBLIC WATER SUPPLIES

FOR MONTH OF

August 2018

Page 1 of 2

Pumping Totals	Pumping Totals		Chlorine		Fluoride		Phosphate		NaiMnO4		Bi-Sulfite		UF Filters				Softeners				Chlorine	
	Hours	Filter Ran	AMT	Calc	AMT	Calc	AMT	Calc	AMT	Calc	AMT	Calc	1	2	3	4	1	2	3	4	Temp	TDS
	(M gal)	(M gal)	lbs	mg/l	lbs	mg/l	lbs	mg/l	lbs	mg/l	lbs	mg/l	Indicate hours previous / hours	Indicate hours previous / hours	Indicate hours previous / hours	Indicate hours previous / hours	Gal	Gal	Gal	Gal	RTW Sample	Hydrochloric Acid
21.0	1,450	1,223	0.013	288.0	2.98	38.0	1.18	44.0	1.37	35.0	2.75	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	14.46	0.00
21.1	1,472	1,164	0.013	250.0	2.55	39.0	1.33	9.0	0.31	29.0	2.23	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	1.05	0.00
20.5	1,467	1,231	0.002	255.0	2.61	37.0	1.19	16.0	0.51	31.0	2.37	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.04	0.00
19.4	1,423	1,196	0.013	267.0	2.81	42.0	1.38	20.0	0.66	31.0	2.45	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
20.0	1,465	1,324	0.018	288.0	2.89	45.0	1.34	26.0	0.78	34.0	2.57	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
21.2	1,590	1,412	0.010	275.0	2.59	38.0	1.06	26.0	0.73	32.0	2.29	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
21.2	1,568	1,366	0.007	225.0	2.16	34.0	0.98	28.0	0.81	26.0	1.88	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
20.2	1,463	1,098	0.014	238.0	2.45	36.0	1.30	35.0	1.26	33.0	2.60	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
18.6	1,285	1,104	0.011	255.0	2.97	38.0	1.36	42.0	1.51	31.0	2.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
19.7	1,421	1,260	0.010	286.0	3.02	43.0	1.35	50.0	1.57	33.0	2.58	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
19.8	1,480	1,303	0.012	262.0	2.65	41.0	1.25	47.0	1.43	32.0	2.43	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
20.3	1,524	1,329	0.020	295.0	2.90	43.0	1.28	50.0	1.49	35.0	2.57	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
21.1	1,597	1,374	0.012	275.0	2.62	43.0	1.24	18.0	0.52	32.0	2.26	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
21.3	1,575	1,416	0.011	295.0	2.81	39.0	1.09	18.0	0.50	34.0	2.47	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
21.0	1,598	1,332	0.015	272.0	2.55	39.0	1.16	20.0	0.59	32.0	2.25	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
21.2	1,555	1,280	0.024	181.0	1.78	36.0	1.11	21.0	0.65	21.0	1.56	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
19.7	1,525	1,325	0.003	60.0	0.59	1.0	0.03	3.0	0.09	8.0	0.65	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
6.4	0.000	0.180	0.000	226.0	34.0	7.47	22.0	4.84	26.0	7.64	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
12.0	0.812	0.789	0.015	286.0	5.28	41.0	2.06	34.0	1.71	32.0	4.06	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
21.0	1,554	1,406	0.006	214.0	2.06	30.0	0.84	30.0	0.84	25.0	1.83	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
19.7	1,453	1,133	0.013	238.0	2.46	36.0	1.26	38.0	1.33	27.0	2.11	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
17.5	1,309	1,128	0.006	231.0	2.64	35.0	1.23	37.0	1.30	27.0	2.29	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
16.8	1,254	1,069	0.013	237.0	2.83	37.0	1.33	39.0	1.40	27.0	2.42	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
16.3	1,226	1,021	0.005	247.0	3.02	37.0	1.43	39.0	1.51	29.0	2.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
17.6	1,301	1,124	0.012	267.0	3.08	41.0	1.44	45.0	1.58	32.0	2.73	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
17.8	1,306	1,149	0.005	255.0	2.90	36.0	1.24	26.0	0.90	30.0	2.56	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
20.8	1,506	1,341	0.013	246.0	2.45	36.0	1.06	22.0	0.65	29.0	2.18	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
19.7	1,454	1,162	0.007	221.0	2.28	33.0	1.12	24.0	0.82	25.0	1.91	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
17.7	1,297	1,075	0.007	235.0	2.72	34.0	1.25	29.0	1.07	28.0	2.41	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00
17.4	1,238	1,069	0.018	247.0	2.99	36.0	1.30	37.0	1.33	29.0	2.58	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.00	0.00

I certify that the information in this report is complete and accurate to the best of my knowledge.

Reported by: _____ Cert or Req: _____

Backdrifted Sent: _____ Date: _____

% Chlorine Solution Fed _____

% Fluoride Solution Fed _____

% Bisulfite Solution Fed _____

% Phosphate Solution Fed _____

% Sodium Permanganate Fed _____