

Monthly Operating Report

December: 2019



So. Sangamon
Water Commission
January 21st, 2020

SSWC

9199 Buckhart Rd Rochester IL 62563

TABLE OF CONTENTS

SECTION		PAGE NO.
Executive Summary.....		ES-1
1. SAFETY		1-1
1.1 Safety Training		1-1
1.2 Lost time Accidents		1-1
1.3 Safety Audit		1-1
1.4 Miscellaneous Safety.....		1-1
2. COMPLIANCE, FLOWS AND LOADINGS		2-2
2.1 Compliance		2-2
2.2 Influent flows and loadings		2-2
2.3 Effluent Concentrations		2-2
2.4 Lagoon Discharge Concentrations		2-4
3. OPERATIONS.....		3-1
3.1 Events impacting operations		3-1
3.2 Emergency & Service calls.....		3-1
3.3 Emergency Call-outs		3-1
3.4 Customer Inquiries		3-1
4. MAINTENANCE AND REPAIR.....		4-7
4.1 Preventative and predictive maintenance.....		4-7
4.2 Corrective repairs		4-7
5. PROJECT MANAGEMENT & SUPPORT.....		5-1
5.1 Staffing & Training.....		5-1
5.2 Corporate Support.....		Error! Bookmark not defined.
5.3 Budget		5-3
6. CAPITAL PLANNING		6-1
6.1 Approved CIP Projects Current status.....		6-1
6.2 Draft Capital Improvement Plan		6-1

LIST OF TABLES

TABLE	PAGE NO.
Table 2.2 Influent Concentrations and Flow.....	2-2
Table 2.3 Finished Water Quality.....	2-2
Table 2.4 Weekly Grab Sample Analysis Results.....	2-4
Table 4.1 Budget Table.....	5-3

EXECUTIVE SUMMARY

Safety. Safety is the number one priority at South Sangamon. We have instituted a monthly safety meeting for operations staff at the plant. There were no lost time accidents in the month of December 2019.

Compliance. The finished water quality was within regulatory limits and all reporting and sampling requirements were met for the month. A copy of the Operations Report submitted to the Illinois Environmental Protection Agency is available at www.sswc.us.

During the month of December 2019, the plant pumped 39.1 million gallons from the well field and 30.775 million gallons of finished water. This is 1.155 million gallons less than December of 2018.

The SSWC plant has been placed on Critical Review status. Systems on Critical Review will be evaluated for sufficient capacity before issuance of water main extension permits.

Operations. There were 1 emergency call-outs for the month. There were 4 customer inquiries for the month.

Maintenance and Repair. For the month of December 2019, there were 31 inspections, 3 preventative and 3 corrective maintenance activity completed.

Budget. Passed at May 20th meeting.

Capital Planning.

Pigging Project

Chloramines Project

New Berlin Meter relocation.

1. SAFETY

1.1 SAFETY TRAINING

At South Sangamon we strive to provide a safe working environment for all employees. This is accomplished with daily safety meetings and open communication.

1.2 LOST TIME ACCIDENTS

There were 0 lost time accidents in the month of December 2019.

1.3 SAFETY AUDIT

No safety audits to date.

1.4 MISCELLANEOUS SAFETY

No usable Fall Arrestors for aerator on premises

2. COMPLIANCE, FLOWS AND LOADINGS

2.1 COMPLIANCE

The finished water quality was within regulatory limits and all Bacteriological testing was completed for the month of December. A copy of the Operations Report to the Illinois Environmental Protection Agency (IEPA) is available on the SSWC website.

2.2 INFLUENT FLOWS AND LOADINGS

The total gallons pumped from the well field were 39.1 MG. The influent parameters were all within the normal range.

The influent flow and loadings are summarized below in Table 2.2

Table 2.2 Influent Concentrations and Flow

	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Well Flow Gals (mgd).
Max.	7.70	16.6	1.92	.252	-	370	300	1.45
Min.	7.50	14.1	.10	.177	-	345	280	1.138
Avg.	7.62	15.3	.98	.213	-	355	287	1.261
Total	-	-	-	-	-	-	-	39.1

2.3 EFFLUENT CONCENTRATIONS

The facility filtered 34.99 MG during the month with a daily average of 1.129 MG and a min/max 1.002/ 1.259 MG.

Table 2.3 Finished Water Quality

	Free CL2	Total CL2	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Phosphate
Max.	1.8	1.9	8.20		0.04	0.039	0.89	380	300	2.33
Min.	1.3	1.4	8.00		0.01	0.001	0.35	100	240	1.05
Avg.	1.6	1.7	8.13		0.02	0.015	0.68	135	282	1.78
MCL	-	-	-	-	1.00	-	4.00	-	-	-
SMCL	-	-	-	-	0.30	0.050	2.00	-	-	-

Finished Water Flow Comparison for FY 2018

Time Period	2018-2019	2017-2018	2016-2017
Jan-Dec 2019	357,956,666	379,581,690	405,040,897
Increase for the same period last year	-21.6 MG		

FINISHED WATER PUMPING HISTORY						
	2019	2018	2017	2016	2015	2014
Jan	28,823,375	30,556,824	30,449,215	28,510,121	30,346,721	32,499,427
Feb	28,625,431	25,617,914	27,373,232	26,095,228	26,336,077	28,745,378
March	31,237,000	28,217,699	30,068,363	27,851,811	28,729,919	31,217,486
April	28,418,249	27,110,578	29,625,797	29,292,618	29,270,184	31,690,073
May	33,045,927	33,304,196	32,120,873	33,349,391	33,371,016	31,157,411
June	33,460,303	34,040,000	39,931,402	41,541,321	31,092,539	38,462,951
July	23,742,374	41,178,722	42,164,927	35,378,396	33,123,375	38,674,894
Aug	25,018,633	35,176,238	38,760,634	35,401,490	38,109,133	33,748,543
Sept	34,234,782	34,754,000	39,896,986	36,325,215	36,546,171	29,763,075
Oct	30,769,238	30,353,482	33,506,605	34,374,820	34,783,455	28,803,052
Nov	30,877,400	30,464,000	28,617,333	30,478,309	27,217,293	28,426,579
Dec	29,703,954	31,930,000	28,808,037	32,525,530	27,788,637	28,656,869
	-----	-----	-----	-----	-----	-----
Totals	357,956,666	379,581,690	405,040,897	386,387,357	377,582,752	389,075,300
Avg	.981 MGD	1.04 MGD	1.11 MGD	1.06 MGD	1.03 MGD	1.07 MGD

2.4 LAGOON DISCHARGE CONCENTRATIONS

The results for the NPDES lagoon discharge permit are summarized below.

Table 2.4 Weekly Grab Sample Analysis Results

Lagoon Effluent Results						
Date	Fe (mg/l)	Mn (mg/l)	Chloride (mg/l)	Cl ² (mg/l)	pH (S.U.)	TSS (mg/l)
December 7, 2019	.54	.202	250	.01	8.1	<4
Minimum	.54	.202	250	.01	8.1	<4
Maximum	.54	.202	250	.01	8.1	<4
Average	.54	.202	250	.01	8.1	<4
Monthly Avg Limit	2.000	1.000				15
Daily Limit	4.000	2.000	500	0.05	6.0-9.0	30

The Chloride sample for the month, performed by the Springfield Metropolitan Sanitary District, was below 30,000 mg/l for the month of December 2019. The limit for chloride discharge to the sanitary district is 30,000 mg/L.

3. OPERATIONS

3.1 EVENTS IMPACTING OPERATIONS

There were no incidents impacting plant operations for the month of December.

3.2 EMERGENCY & SERVICE CALLS

Service Calls:

- There were 0 emergency call outs for the month.

3.3 EMERGENCY CALL-OUTS

There was 1 emergency call-out for the month requiring operational personnel at the plant after normal business hours

3.4 CUSTOMER INQUIRIES

There were 4 customer inquiries.

OTHER WORK PERFORMED

Cleaned brine tank 1
Learned correct operating procedures for the new filter train
Trouble shooting of new train
Trouble shooting of CIP skid and CIP procedure
Plowed drive
Repaired chlorination system



Hydrant at Mansion Rd and Curran Rd was damaged, causing a leak.



Hydrant at Mansion Rd and Curran Rd is currently out of service until repairs can be performed.



Hach arrived to commission Monochloramine analyzer. Analyzer had a fatal error causing SSWC to push back monochloramine startup.



Westech Filter HMI shutdown and will not restart.



Installed backup computer to monitor and control UltraFilter control PLC.

4. MAINTENANCE AND REPAIR

4.1 PREVENTATIVE AND PREDICTIVE MAINTENANCE

For the month of December 2019, there were 31 inspections, 3 preventative and 3 corrective maintenance activity completed.

4.2 CORRECTIVE REPAIR

Pulling and cleaning pre filters on all 3 filter trains on weekly basis

CIP train 1,2 and 3

Drained brine tank 1 and cleaned it out.

5. PROJECT MANAGEMENT & SUPPORT

5.1 STAFFING & TRAINING

- With the addition of a new staff member training has been continuous and ongoing.
- Operator and Asst. Operator have been studying for EPA licensing test.

5.2 OPERATIONAL SUPPORT

The following individuals, either on-site or remotely, provided assistance in operation and/or maintenance of the plant during the month of December 2019.

- Kevin Canham
- Stephen Bivin
- Dave Wilson (Westech)
- Katie Krall
- Jamie Felicetti (Westech)
- Keslee Carson (Westech)

5.3 BUDGET

Table 5.3 Operating Budget

Table 5.3 Budget Table

Budget Category	Month Budget	Month Actual	YTD Budget	YTD Actual	Annual Budget
Labor (D.L. + OH)	\$13,909.06	?	\$68237	\$70128	\$163,768
Utilities	\$8,306.30		\$40,750	\$36,019	\$97,800
Chemicals	\$22,421		\$110,000	\$74,593	\$264,000
Maintenance & Repair	\$13,668.62		\$67,056	\$56,429	\$160,937*
Chloride	\$13,160		\$65,800	\$58,080	\$157,920
Lab Supplies and Equipment	\$1,918.09		\$9,410	\$5,987	\$22,584
Office Supplies	\$220.14		\$1080	\$627	\$2,592
Miscellaneous Expenses*	\$41		\$123	?	\$500
Other Operating Costs	\$1398	?	\$6990	\$6107	\$16,776
Engineering Fees	\$2,500		\$7500	\$5950	\$30,000
Office Equipment rental	\$65		\$542	\$325	\$780
Locates	\$378	0	\$1890	\$2,758	\$4536
Truck	\$3,333	0	\$33,333	\$35,560	\$40,000
Total	\$81,318.21	\$37337.12	\$377,488	\$349,805	\$962193

*as of September 30 2019

6. CAPITAL PLANNING

6.1 APPROVED CIP PROJECTS CURRENT STATUS

Chloramine conversion project- Hach arrived to commission analyzer. Mother board was damaged causing a fatal error to the equipment. Hach will commence startup of Monochloramine analyzer in January after parts arrive and repairs have been made.

New Berlin Meter master meter relocation project is commencing. Engineering and relocation plans have been finalized. Awaiting ground breaking.

6.2 DRAFT CAPITAL IMPROVEMENT PLAN

The CIP is a planning document that includes all projects anticipated to exceed \$5,000 in cost over the next five years. The CIP is an ongoing process and will be refined from time to time as projects are completed and new issues are identified.

