

Monthly Operating Report

December:2020



So. Sangamon
Water Commission
January 18th, 2021

SSWC

9199 Buckhart Rd Rochester IL 62563

TABLE OF CONTENTS

SECTION	PAGE NO.
Executive Summary	ES-1
1. SAFETY	1-1
1.1 Safety Training.....	1-1
1.2 Lost time Accidents.....	1-1
1.3 Safety Audit.....	1-1
1.4 Miscellaneous Safety.....	1-1
2. COMPLIANCE, FLOWS AND LOADINGS.....	2-2
2.1 Compliance	2-2
2.2 Influent flows and loadings.....	2-2
2.3 Effluent Concentrations.....	2-2
2.4 Lagoon Discharge Concentrations.....	2-4
3. OPERATIONS	3-1
3.1 Events impacting operations.....	3-1
3.2 Emergency & Service calls.....	3-1
3.3 Emergency Call-outs	3-1
3.4 Customer Inquiries.....	3-1
4. MAINTENANCE AND REPAIR.....	4-8
4.1 Preventative and predictive maintenance.....	4-8
4.2 Corrective repairs.....	4-8
5. PROJECT MANAGEMENT & SUPPORT.....	5-1
5.1 Staffing & Training.....	5-1
5.2 Corporate Support.....	5-2
5.3 Budget.....	5-2
6. CAPITAL PLANNING.....	6-1
6.1 Approved CIP Projects Current status.....	6-1
6.2 Draft Capital Improvement Plan.....	6-1

LIST OF TABLES

<u>TABLE</u>	<u>PAGENO.</u>
Table 2.2 Influent Concentrations and Flow.....	2-2
Table 2.3 Finished Water Quality.....	2-2
Table 2.4 Weekly Grab Sample Analysis Results	2-4
Table 4.1 Budget Table.....	5-2

EXECUTIVE SUMMARY

Safety. Safety is the number one priority at South Sangamon. We have instituted a monthly safety meeting for operations staff at the plant. There were no lost time accidents in the month of December 2020.

Compliance. The finished water quality was within regulatory limits and all reporting and sampling requirements were met for the month. A copy of the Operations Report submitted to the Illinois Environmental Protection Agency is available at www.sswc.us.

During the month of December 2020, the plant pumped 42.636 million gallons from the well field and 39.766 million gallons of finished water. This is 2.345 million gallons more than December of 2019.

The SSWC plant has been placed on Critical Review status. Systems on Critical Review will be evaluated for sufficient capacity before issuance of water main extension permits. The Critical Review is currently under review.

Operations. There was 0 emergency call-outs for the month. There were numerous customer inquiry for the month.

Maintenance and Repair. For the month of December 2020, there were 31 inspections, 3 preventative and 3 corrective maintenance activity completed.

Budget. Passed at May 18th 2020 meeting.

Capital Planning.

BOP CPU replacement

Chloramines Project

New Berlin Meter relocation.

Chatham emergency interconnect

1. SAFETY

1.1 SAFETY TRAINING

At South Sangamon we strive to provide a safe working environment for all employees. This is accomplished with daily safety meetings and open communication.

1.2 LOST TIME ACCIDENTS

There were 0 lost time accidents in the month of December 2020.

1.3 SAFETY AUDIT

No safety audits to date.

1.4 MISCELLANEOUS SAFETY

No notable safety issues

2. COMPLIANCE, FLOWS AND LOADINGS

2.1 COMPLIANCE

The finished water quality was within regulatory limits and all Bacteriological testing was completed for the month of December. A copy of the Operations Report to the Illinois Environmental Protection Agency (IEPA) is available on the SSWC website.

2.2 INFLUENT FLOWS AND LOADINGS

The total gallons pumped from the well field were 42.632 MG. The influent parameters were all within the normal range.

The influent flow and loadings are summarized below in Table 2.2

Table 2.2 Influent Concentrations and Flow

	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Well Flow Gals (MGD)
Max.	8.2	15.6	3.16	.335	-	370	290	1.640
Min.	8.0	14.0	.39	.209	-	235	270	1.074
Avg.	8.15	14.7	.83	.242	-	343	282	1.375
Total	-	-	-	-	-	-	-	42.636

2.3 EFFLUENT CONCENTRATIONS

The facility filtered 39.766 MG during the month with a daily average of 1.283 MG and a min/max 1.064/ 2.325 MG.

Table 2.3 Finished Water Quality

	Free CL2	Total CL2	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Phosphate
Max.	1.99	2.05	8.7		0.02	0.106	1.27	260	292	2.47
Min.	1.37	1.43	8.5		0.01	0.016	0.38	90	260	.25
Avg.	1.71	1.79	8.6		0.01	0.047	0.77	147	279	1.84
MCL	-	-	-	-	1.00	-	4.00	-	-	-
SMCL	-	-	-	-	0.30	0.050	2.00	-	-	-

Finished Water Flow Comparison for FY 2019-20

Time Period	2019-2020	2018-2019	2017-2018
Jan 2020-Dec 2020	392,017,339	360,182,712	379,581,690
Increase for the same period last year	35.9 MG	- 24.7 MG	

FINISHED WATER PUMPING HISTORY						
	2020	2019	2018	2017	2016	2015
Jan	30,073,516	28,823,375	30,556,824	30,449,215	28,510,121	30,346,721
Feb	28,797,693	28,625,431	25,617,914	27,373,232	26,095,228	26,336,077
Mar	30,339,298	31,237,000	28,217,699	30,068,363	27,851,811	28,729,919
Apr	31,542,650	28,418,249	27,110,578	29,625,797	29,292,618	29,270,184
May	34,673,848	33,045,927	33,304,196	32,120,873	33,349,391	33,371,016
June	17,414,377	33,460,303	34,040,000	39,931,402	41,541,321	31,092,539
July	44,237,066	23,742,374	41,178,722	42,164,927	35,378,396	33,123,375
Aug	39,638,063	25,018,633	35,176,238	38,760,634	35,401,490	38,109,133
Sept	38,674,095	34,234,782	34,754,000	39,896,986	36,325,215	36,546,171
Oct	34,597,739	30,769,238	30,353,482	33,506,605	34,374,820	34,783,455
Nov	32,325,040	30,877,400	30,464,000	28,617,333	30,478,309	27,217,293
Dec	31,582,311	29,703,954	31,930,000	28,808,037	32,525,530	27,788,637
	-----	-----	-----	-----	-----	-----
Totals	393,895,696	357,956,666	382,703,653	401,323,404	391,124,250	376,714,520
Avg	1.08 MGD	.981 MGD	1.05 MGD	1.10 MGD	1.07 MGD	1.03 MGD

2.4 LAGOON DISCHARGE CONCENTRATIONS

The results for the NPDES lagoon discharge permit are summarized below.

Table 2.4 Weekly Grab Sample Analysis Results

Lagoon Effluent Results						
Date	Fe (mg/l)	Mn (mg/l)	Chloride (mg/l)	Cl ² (mg/l)	pH (S.U.)	TSS (mg/l)
December 1 st 2020	.12	.186	420	0.02	8.7	<4
Minimum	.12	.186	420	0.02	8.7	<4
Maximum	.12	.186	420	0.02	8.7	<4
Average	.12	.186	420	0.02	8.7	<4
Monthly Avg Limit	2.000	1.000				15
Daily Limit	4.000	2.000	500	0.05	6.0-9.0	30

The Chloride sample for the month, performed by the Springfield Metropolitan Sanitary District, was below 30,000 mg/l for the month of December 2020. The limit for chloride discharge to the sanitary district is 30,000 mg/L.

3. OPERATIONS

3.1 EVENTS IMPACTING OPERATIONS

There was 1 incident that impacted the operation of the plant.

3.2 EMERGENCY & SERVICE CALLS

Service Calls:

- There was 0 emergency call out for the month.

3.3 EMERGENCY CALL-OUTS

There was 0 emergency call out for the month of December

3.4 CUSTOMER INQUIRIES

There were numerous customer inquiries.

OTHER WORK PERFORMED

Trouble shooting of new train

Trouble shooting of CIP skid and CIP procedure

Inspected distribution mains

Consulted with new customers.

Repaired generator and setup transfer switch

Replaced BW valve on train #2

Created customer info database


Inspected booster station



During the month of December an accident occurred causing downed power lines . These lines feed commercial power to the water plant. Although power was not lost at the time of the incident SSWC switched over to Chatham back feed for. This was done to ensure that service was not interupted while the power was repaired.



Ameren was onsite within a few hours to replace the damaged power pole. During this replacement power was disconnected for safety reasons.



During the month of December train #2 started to fault and shut down. After many days of research and investigation it was discovered that a valve was leaking around the stem. This leak caused water to push into the valve actuator and would fill the air system with water. This would, in turn, cause the system to malfunction.



The only fix is to replace the valve and purge the air system.



Assistant Operator Katie Krall reinstalling the air valves that trigger the actuators after purging the system of water and cleaning out the manifold.



New customer Sean Robinson having the new tap installed.

4. MAINTENANCE AND REPAIR

4.1 PREVENTATIVE AND PREDICTIVE MAINTENANCE

For the month of December 2020, there were 31 inspections, 3 preventative and 3 corrective maintenance activity completed.

4.2 CORRECTIVE REPAIR

Pulling and cleaning pre filters on all 3 filter trains on weekly basis

CIP train 1,2 and 3

Replaced manifold on train #3

Worked with SCADAware in learning our system.

Replaced Backwash valve

Purged air control system

5. PROJECT MANAGEMENT & SUPPORT

5.1 STAFFING & TRAINING

- With the addition of a new staff member training has been continuous and ongoing.
- Operator and Asst. Operator have been studying for EPA licensing test.

5.2 OPERATIONAL SUPPORT

The following individuals, either on-site or remotely, provided assistance in operation and/or maintenance of the plant during the month of December 2020.

- Kevin Canham
- Stephen Bivin
- Katie Krall
- Kevin Garman (SCADAware)
- Crosspoint Cummins
- Dan (SCADAware)
- Bodine Electric

5.3 BUDGET

Table 5.3 Operating Budget

Table 5.3 Budget Table

Budget Category	Month Budget	Month Actual	YTD Budget	YTD Actual	Annual Budget
Labor (D.L. + OH)	\$14,590.81	?	\$81,431	\$71,581	\$171,795
Utilities	\$8,30630		\$40,750	\$40,586	\$97,800
Chemicals	\$22,421.92		\$110,000	\$76,944	\$264,000
Maintenance & Repair	\$13,668.62		\$67,146	\$94,528	\$160,937
Chloride	\$12,979.73		\$65,800	\$61,400	\$157,920
Lab Supplies and Equipment	\$1,856.22		\$9,410	\$6,131	\$22,584
Office Supplies	\$213.04		\$1,080	\$264	\$2,592
Miscellaneous Expenses*	\$		\$?	\$500
Other Operating Costs	\$?	\$	\$6107	\$
Engineering Fees	\$2,547.95		\$12,500	\$5,430	\$30,000
Office Equipment rental	\$65		\$325	\$596	\$780
Locates	\$378.00	0	\$1,890	\$3,730	\$4536
Truck	\$3,287.67	0	\$6,667	\$131	\$40,000
Total	\$80,315.26	\$	\$396,999	\$367,428	\$953,444

*as of September 21th 2020

6. CAPITAL PLANNING

6.1 APPROVED CIP PROJECTS CURRENT STATUS

New Berlin Meter master meter relocation project is commencing. Engineering and relocation plans have been finalized. Awaiting ground breaking.

Pigging project construction complete. Awaiting first pigging before completely releasing contractor.

BOP CPU replace is in the planning phase

Benton and Assoc has initiated the planning phase of the Chatham Emergency interconnect. Construction permit has been applied for.

6.2 DRAFT CAPITAL IMPROVEMENT PLAN

The CIP is a planning document that includes all projects anticipated to exceed \$5,000 in cost over the next five years. The CIP is an ongoing process and will be refined from time to time as projects are completed and new issues are identified.

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES

MONTHLY IRON REMOVAL AND ION EXCHANGE SOFTENING REPORT
South Sangamon Water Commission - IL 1670080
December 2020

Time	Date Meter Read	Pumping Totals				Chemicals Applied						UF Filters						Softeners														
		Raw Well	UF Prod. (Mgal)	Pump. (Mgal)	HS Effluent (Mgal)	Lagoon	Sodium Permanganate	Sodium Ammonium Calc	Sodium Hypochlorite	Ammonium Sulfate	Fluorosilicic Acid	Phosphate	Sodium Bisulfite Pond	Hours since previous backwash	Wash Water	Water Softened	Water bypassed	Water Gal.	Water Gal.	Water Gal.	Each day indicate total number of regeneration hours since previous regeneration, if regeneration at mid-day indicate hours previous following.	Salt Washed										
Hours	File#	Raw (Mgal)	Prod. (Mgal)	Pumpage (Mgal)	Effluent (Mgal)	Am't Used	Calc	Used	Am't Used	Calc	Used	Am't Used	Calc	Am't Used	Calc	Bank #	Gal. (Mgal)	Gal. (Mgal)	Gal. (Mgal)	1	2	3	4	Ibs. Gal.								
1	7/00	15.6	1,388	1,249	0.008	1,089	0.084	15	0.26	0	0.00	208	2.50	0	0.00	26	0.54	56	0.66	0.66	0.66	0.66	0.66	0.070	0.816	0.433	42.0	35.0	47.0	6843	32550	
2	7/00	14.3	1,287	1,116	0.017	1,052	0.073	16	0.30	0	0.00	186	2.50	0	0.00	25	0.54	58	0.66	0.66	0.66	0.66	0.66	0.063	0.729	0.387	45.0	35.0	47.0	4682	21700	
3	7/00	14.7	1,316	1,177	0.009	1,043	0.067	17	0.31	0	0.00	196	2.50	0	0.00	27	0.59	58	0.22	17	12.25	0.66	0.66	0.057	0.769	0.408	44.0	42.0	46.0	4682	21700	
4	7/00	14.7	1,301	1,154	0.012	1,025	0.080	14	0.26	0	0.00	192	2.50	0	0.00	25	0.56	4	0.15	11	6.63	0.66	0.66	0.070	0.754	0.400	51.0	48.0	51.0	4682	21700	
5	7/00	13.9	1,251	1,261	0.010	0.985	0.083	17	0.33	0	0.00	210	2.50	0	0.00	26	0.60	8	0.32	12	6.97	0.66	0.66	0.073	0.824	0.437	45.0	52.0	46.0	4682	21700	
6	7/00	15.8	1,371	1,102	0.012	1,180	0.065	17	0.30	0	0.00	184	2.50	0	0.00	29	0.56	10	0.34	14	10.33	0.66	0.66	0.065	0.720	0.382	0	0	0	0	0	
7	7/00	16.8	1,475	1,286	0.005	1,130	0.104	14	0.23	0	0.00	220	2.60	0	0.00	24	0.48	9	0.32	16	7.37	0.66	0.66	0.085	0.829	0.439	36.0	43.0	37.0	9124	43400	
8	7/00	15.2	1,357	1,259	0.013	1,016	0.081	15	0.27	0	0.00	219	2.61	0	0.00	26	0.58	825	0.66	0.66	0.067	0.823	0.437	37.0	38.0	34.0	6843	32550				
9	7/00	14.5	1,286	1,109	0.009	1,028	0.077	12	0.22	0	0.00	193	2.61	0	0.00	24	0.53	10	0.38	11	6.89	0.66	0.66	0.067	0.725	0.384	42.0	42.0	46.0	4682	21700	
10	7/00	15.0	1,134	1,136	0.009	1,000	0.087	16	0.29	0	0.00	198	2.61	0	0.00	26	0.59	14	0.35	13	7.15	0.66	0.66	0.068	0.742	0.394	46.0	33.0	40.0	9124	43400	
11	7/00	14.7	1,327	1,271	0.017	1,034	0.084	11	0.20	0	0.00	221	2.61	0	0.00	24	0.53	19	0.73	15	8.61	0.66	0.66	0.074	0.831	0.440	24.0	34.0	34.0	4682	21700	
12	7/00	14.8	1,302	1,158	0.009	1,026	0.079	16	0.29	0	0.00	202	2.61	0	0.00	25	0.56	41	1.58	18	10.99	0.66	0.66	0.069	0.765	0.395	47.0	42.0	46.0	4682	21700	
13	7/00	15.0	1,329	1,064	0.012	1,113	0.073	19	0.34	0	0.00	185	2.61	0	0.00	22	0.45	63	2.24	12	7.91	0.66	0.66	0.068	0.826	0.439	30.0	22.0	28.0	10850	32550	
14	7/00	15.9	1,379	1,218	0.006	1,081	0.084	15	0.26	0	0.00	203	2.50	0	0.00	27	0.57	59	2.16	15	7.64	0.66	0.66	0.075	0.796	0.422	72.0	38.0	40.0	9124	43400	
15	7/00	17.3	1,588	1,373	0.020	1,228	0.089	17	0.26	0	0.00	229	2.50	0	0.00	29	0.54	63	2.03	15	8.10	0.66	0.66	0.084	0.897	0.476	33.0	22.0	28.0	10850	32550	
16	7/00	11.7	1,074	1,373	0.007	0.830	0.084	22	0.49	0	0.00	229	2.50	0	0.00	25	0.69	10	0.48	10	5.13	0.66	0.66	0.084	0.897	0.476	54.0	40.0	46.0	4682	21700	
17	7/00	17.6	1,074	1,629	1,896	0.008	1,271	1.127	14	0.21	0	0.00	316	2.50	0	0.00	24	0.43	5	0.16	14	0.60	0.66	0.66	1.117	1.239	0.657	73.0	52.0	46.0	4682	21700
18	7/00	13.4	1,174	1,164	0.011	0.961	0.080	14	0.29	0	0.00	186	2.40	0	0.00	26	0.62	8	0.33	12	6.37	0.66	0.66	0.076	0.761	0.403	40.0	24.0	45.0	6843	32550	
19	7/00	17.6	1,640	1,200	0.014	1,278	0.059	12	0.18	0	0.00	192	2.40	0	0.00	33	0.59	10	0.31	19	13.25	0.66	0.66	0.064	0.784	0.416	40.0	29.0	34.0	9124	43400	
20	7/00	14.3	1,284	1,233	0.008	1,037	0.070	18	0.34	0	0.00	197	2.40	0	0.00	29	0.64	10	0.38	15	10.31	0.66	0.66	0.065	0.806	0.427	45.0	22.0	28.0	10850	32550	
21	7/00	15.6	1,422	1,233	0.005	1,105	0.084	15	0.24	0	0.00	189	2.30	0	0.00	22	0.45	8	0.29	10	10.33	0.66	0.66	0.065	0.805	0.427	102.0	41.0	30.0	9124	43400	
22	7/00	17.2	1,579	1,143	0.022	1,169	0.089	14	0.21	0	0.00	217	2.30	0	0.00	27	0.53	11	0.37	10	5.40	0.66	0.66	0.084	0.924	0.489	35.0	22.0	28.0	10850	32550	
23	7/00	14.5	1,284	1,413	0.004	0.965	0.089	15	0.28	0	0.00	217	2.30	0	0.00	26	0.61	14	0.37	19	10.26	0.66	0.66	0.084	0.924	0.489	39.0	22.0	28.0	10850	32550	
24	7/00	15.6	1,427	2,225	0.005	1,174	0.143	12	0.20	0	0.00	355	2.29	0	0.00	29	0.56	18	0.61	6	2.01	0.66	0.66	0.124	0.805	0.630	42.0	34.0	73.0	9124	43400	
25	7/00	15.1	1,362	1,187	0.037	1,126	0.047	2	0.04	0	0.00	182	2.30	0	0.00	29	0.55	41	1.44	10	12.01	0.66	0.66	0.047	0.776	0.411	0	0	0	0	0	
26	7/00	15.8	1,449	1,363	0.006	1,058	0.088	6	0.10	0	0.00	287	2.18	0	0.00	27	0.58	59	2.21	13	7.06	0.66	0.66	0.074	0.884	0.480	40.0	39.0	40.0	6843	32550	
27	7/00	15.7	1,460	1,144	0.013	1,156	0.075	14	0.23	0	0.00	170	2.29	0	0.00	29	0.57	62	2.12	15	9.55	0.66	0.66	0.061	0.728	0.386	34.0	32.0	68.0	6843	32550	
Total		473.8	4,636	39,662	0.036	33,494	0.022	463	0.21	0	0	6470.87	75.73	0	0	822	17.42	980	35.73	414	2417.8	0.66	0.66	#D0100	3,280	23,991	13,775	732	757	732	6843	32550
Ave.		15.3	1,375	1,283	0.011	1,080	0.116	14.9	0.26	0	0	209	2.44	0	0.00	285	0.56	316	1.15	13.4	7.80	0.66	0.66	0.044	0.838	0.444	50.8	42.1	38.5	47.8	4829.9	
Max.		17.6	1,640	2,225	0.037	1,178	0.121	24.0	0.26	0	0	365	2.49	0	0.00	33	0.63	66	0.66	0.66	0.66	0.66	0.66	0.045	0.805	0.422	102.0	60.0	52.0	75.0	51.24	43400
Min.		11.7	1,074	1,064	0.000	0.830	0.047	2.0	0.04	0	0	147	1.72	0	0.00	22	0.43	4	0.15	6	0.60	0.66	0.66	0.047	0.855	0.369	16.0	34.0	24.0	25.0	0	0

1	20 % Sodium Permanganate	Pre-aerator	CHLORINATION	FLUORIDATION
2	40 % Bisulfite Solution	Membrane Backwash	Type of Chlorine Used	Sodium Hypochlorite 12.5%
3	12.5 % Sodium Hypochlorite Solution	Rust Softener	Type of Fluoride Used	Hydrofluosilic Acid 19% F
4	20 % Ammonium Sulfate Solution	Post Softener	Fluoride Analyzer Used	Hach 2220, SP/SDNS method
5	19 % Fluorosilic Acid Solution	Post Crayonell	Chlorine Analyzers Used	Hach CL17(2) & 5500Sc
6	33 % Phosphate Solution	Post Crayonell	Fluoride Analyzers Used	2440
7	40 % Bisulfite Solution	Lagron Etchant	Date Bacterials Sampled	

Identify that the information in this report is complete and accurate to the best of my knowledge.
Reported by:
Date:
Date Bacterials Sampled:

Illinois Operator Certification #:

25344999

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES

South Sangamon Water Commission - IL1670080
DECEMBER 2020

Physical and Chemical Tests																Membrane Integrity									
Date	Raw				Pre UF Membrane				Post UF Membrane				Post IX				Finished								
	Total pH	Total Alk.	Total Hard.	Total Fe	Total Mn	Total Mn	Total Fe	Total Chloride	Total Chloride	Total Chloride	Total Chloride	Total Chloride	Total Chloride	Total Chloride	Total Chloride	Total Chloride	F	T	Chlorine						
	deg C	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L		
1	8.20	14.0	27.0	342	1.05	0.233	0.265	0.073	0.58	0.042	0.22	8.60	0.39	27.0	90	0.020	0.030	0.78	1.91	0.00	0.03	1.69	1.71		
2	8.20	14.1	280	340	0.92	0.303	0.326	0.121	0.52	0.093	0.17	40.5	76.4	44.3	42.2	8.70	0.28	280	90	0.01	0.039	0.32	1.75		
3	8.20	14.4	280	340	0.63	0.422	0.343	0.144	0.61	0.097	0.20	8.60	0.35	280	110	0.01	0.030	0.70	1.77	0.00	0.00	1.56	1.86		
4	8.20	14.7	280	350	0.57	0.227	0.301	0.068	0.49	0.101	0.25	8.60	0.32	27.8	200	0.01	0.049	0.72	1.79	0.01	0.00	1.68	1.87		
5	8.20	14.5	285	350	0.61	0.219	0.343	0.160	0.49	0.114	0.20	8.60	0.35	280	160	0.01	0.036	0.65	1.59	0.00	0.00	1.75	1.80		
6	8.20	14.4	280	340	0.52	0.250	0.332	0.163	0.60	0.081	0.18	8.60	0.32	280	180	0.02	0.049	0.67	1.32	0.00	0.00	1.84	1.86		
7	8.20	14.1	285	340	1.04	0.241	0.333	0.197	0.45	0.047	0.18	8.60	0.32	27.0	250	0.01	0.050	0.84	1.30	0.00	0.00	1.77	1.59		
8	8.20	14.2	282	350	0.67	0.226	0.354	0.166	0.47	0.102	0.20	38.2	77.8	75	24.5	8.60	0.35	280	140	0.01	0.039	0.67	2.06		
9	8.20	14.8	285	345	0.77	0.322	0.286	0.195	0.49	0.013	0.19	8.60	0.30	27.5	100	0.01	0.045	0.79	2.04	0.00	0.06	1.99	2.05		
10	8.10	15.2	280	355	3.16	0.355	0.339	0.134	0.64	0.073	0.33	8.60	0.40	280	110	0.02	0.035	0.80	1.75	0.00	0.00	1.83	1.84		
11	8.10	14.9	280	342	1.36	0.256	0.300	0.175	0.88	0.099	0.28	8.60	0.60	280	100	0.02	0.048	0.79	2.12	0.00	0.00	1.83	1.86		
12	8.00	14.9	276	348	0.55	0.209	0.317	0.193	0.01	0.053	0.27	8.60	0.39	280	100	0.01	0.030	0.65	1.84	0.00	0.00	1.81	2.01		
13	8.00	15.6	285	350	0.39	0.221	0.333	0.161	0.65	0.071	0.27	8.60	0.28	280	110	0.01	0.021	0.67	2.06	0.00	0.00	1.87	1.89		
14	8.20	14.5	280	370	0.91	0.238	0.333	0.161	0.53	0.069	0.21	70.8	111.1	70.2	27.2	8.60	0.31	27.5	160	0.01	0.042	0.96	1.92		
15	8.10	14.6	280	355	1.12	0.219	0.319	0.132	0.49	0.052	0.21	8.60	0.29	27.0	100	0.02	0.016	0.82	1.82	0.00	0.00	1.88	1.93		
16	8.10	15.2	285	345	1.17	0.246	0.309	0.119	0.37	0.100	0.24	8.60	0.41	280	120	0.01	0.028	0.80	0.25	0.01	0.00	1.70	1.76		
17	8.10	15.1	280	340	0.82	0.255	0.349	0.127	0.47	0.048	0.20	8.60	0.31	280	140	0.02	0.035	0.69	1.82	0.01	0.00	1.68	1.86		
18	8.20	14.5	280	342	0.42	0.228	0.433	0.167	0.45	0.086	0.27	8.60	0.26	280	100	0.01	0.021	0.70	1.62	0.00	0.00	1.72	1.77		
19	8.10	14.9	285	340	0.46	0.235	0.242	0.158	0.51	0.215	0.28	8.60	0.30	280	105	0.01	0.036	0.59	1.91	0.00	0.00	1.83	1.84		
20	8.20	15.3	290	350	0.53	0.224	0.367	0.138	0.53	0.103	0.25	8.60	0.35	280	110	0.01	0.041	0.73	1.73	0.00	0.00	1.75	1.85		
21	8.20	14.5	280	342	0.58	0.223	0.331	0.137	0.45	0.084	0.27	8.60	0.35	280	140	0.01	0.033	0.75	1.89	0.00	0.00	1.71	1.81		
22	8.10	14.7	275	355	0.44	0.220	0.303	0.164	0.46	0.088	0.23	9.50	0.28	280	120	0.01	0.022	0.66	1.90	0.00	0.00	1.61	1.73		
23	8.10	14.7	280	340	0.52	0.256	0.343	0.117	0.50	0.089	0.24	37.3	93.6	69.3	33.1	8.50	0.30	280	160	0.01	0.033	0.88	1.82		
24	8.20	14.4	283	345	0.58	0.261	0.282	0.180	0.60	0.105	0.28	8.60	0.35	280	200	0.01	0.049	0.58	2.21	0.00	0.00	1.56	1.59		
25	8.20	14.2	290	360	0.69	0.445	0.248	0.205	0.01	0.168	0.23	8.60	0.45	292	160	0.01	0.072	1.27	1.31	0.00	0.00	1.63	1.70		
26	8.00	14.1	288	352	1.17	0.224	0.205	0.038	0.02	0.186	0.30	8.50	0.41	286	220	0.01	0.044	0.77	1.34	0.00	0.00	1.64	1.82		
27	8.20	14.5	290	356	0.78	0.236	0.287	0.222	0.01	0.205	0.29	8.50	0.38	280	230	0.01	0.073	0.92	1.36	0.00	0.00	1.46	1.56		
28	8.20	14.8	270	255	1.50	0.364	0.246	0.217	0.65	0.198	0.16	8.60	0.30	260	140	0.01	0.070	0.80	1.95	0.01	0.00	1.39	1.71		
29	8.00	14.3	282	360	0.53	0.228	0.250	0.181	0.01	0.181	0.25	21	49.5	19.1	29.8	8.60	0.40	276	260	0.01	0.066	0.70	1.38		
30	8.20	14.8	280	360	0.62	0.228	0.283	0.112	0.60	0.083	0.21	8.60	0.37	285	200	0.01	0.058	0.79	2.47	0.01	0.00	1.64	1.68		
31	8.10	15.4	280	360	0.44	0.267	0.355	0.094	0.32	0.083	0.27	8.50	0.31	280	140	0.01	0.076	0.94	1.88	0.01	0.00	1.37	1.43		
Ave.	8.15	14.7	282	343	0.83	0.242	#D/W01	0.320	0.154	0.43	0.100	0.24	41.6	81.7	55.6	31.4	8.59	0.35	27.9	147	0.01	0.047	0.77	1.84	
Max	8.20	15.6	290	370	3.16	0.335	0.00	0.00	0.493	0.358	0.88	0.215	0.33	71	111	75	42	8.70	0.60	292	260	0.02	0.106	1.27	2.47
Min	8.00	14.0	270	255	0.39	0.209	0.00	0.00	0.205	0.065	0.01	0.013	0.16	21	50	19	25	8.50	0.26	260	90	0.01	0.016	0.38	0.25
Lagoon Effluent Tests																Distribution Stability Test						Remarks:			
Monthly	pH	Temp	T Chlor	Mn	Chlorine	TSS										pH	Temp	TDS	Alkalinity	Calcium	Sulfate				
Date	12/1/2020	8.7	122	0.02	0.186	0.12										mg/L	mg/L	mg/L	mg/L	mg/L	mg/L				
Date																12/1/2020	8.6	15.6	450	280	46				
Date																									