

# Monthly Operating Report

January:2021



So. Sangamon  
Water Commission  
February 22nd, 2021

SSWC

9199 Buckhart Rd Rochester IL 62563

## TABLE OF CONTENTS

SECTION	PAGE NO.
<b>Executive Summary .....</b>	<b>ES-1</b>
<b>1. SAFETY .....</b>	<b>1-1</b>
1.1 Safety Training.....	1-1
1.2 Lost time Accidents.....	1-1
1.3 Safety Audit.....	1-1
1.4 Miscellaneous Safety.....	1-1
<b>2. COMPLIANCE, FLOWS AND LOADINGS.....</b>	<b>2-2</b>
2.1 Compliance .....	2-2
2.2 Influent flows and loadings.....	2-2
2.3 Effluent Concentrations.....	2-2
2.4 Lagoon Discharge Concentrations.....	2-4
<b>3. OPERATIONS .....</b>	<b>3-1</b>
3.1 Events impacting operations.....	3-1
3.2 Emergency & Service calls.....	3-1
3.3 Emergency Call-outs .....	3-1
3.4 Customer Inquiries.....	3-1
<b>4. MAINTENANCE AND REPAIR.....</b>	<b>4-9</b>
4.1 Preventative and predictive maintenance.....	4-9
4.2 Corrective repairs.....	4-9
<b>5. PROJECT MANAGEMENT &amp; SUPPORT.....</b>	<b>5-1</b>
5.1 Staffing & Training.....	5-1
5.2 Corporate Support.....	5-2
5.3 Budget.....	5-3
<b>6. CAPITAL PLANNING.....</b>	<b>6-1</b>
6.1 Approved CIP Projects Current status.....	6-1
6.2 Draft Capital Improvement Plan.....	6-1

## LIST OF TABLES

<u>TABLE</u>	<u>PAGENO.</u>
Table 2.2 Influent Concentrations and Flow.....	2-2
Table 2.3 Finished Water Quality.....	2-2
Table 2.4 Weekly Grab Sample Analysis Results .....	2-4
Table 4.1 Budget Table.....	5-3

## EXECUTIVE SUMMARY

**Safety.** Safety is the number one priority at South Sangamon. We have instituted a monthly safety meeting for operations staff at the plant. There were no lost time accidents in the month of January 2021.

**Compliance.** The finished water quality was within regulatory limits and all reporting and sampling requirements were met for the month. A copy of the Operations Report submitted to the Illinois Environmental Protection Agency is available at [www.sswc.us](http://www.sswc.us).

During the month of January 2021, the plant pumped 42.168 million gallons from the well field and 36.911 million gallons of finished water. This is 1.3 million gallons more than January of 2020.

The SSWC plant has been placed on Critical Review status. Systems on Critical Review will be evaluated for sufficient capacity before issuance of water main extension permits. The Critical Review is currently under review.

**Operations.** There was 0 emergency call-outs for the month. There were numerous customer inquiry for the month.

**Maintenance and Repair.** For the month of January 2021, there were 31 inspections, 3 preventative and 3 corrective maintenance activity completed.

**Budget.** Passed at May 18<sup>th</sup> 2020 meeting.

### **Capital Planning.**

BOP CPU replacement

Chloramines Project

New Berlin Meter relocation.

Chatham emergency interconnect

# **1. SAFETY**

## **1.1 SAFETY TRAINING**

At South Sangamon we strive to provide a safe working environment for all employees. This is accomplished with daily safety meetings and open communication.

## **1.2 LOST TIME ACCIDENTS**

There were 0 lost time accidents in the month of January 2021.

## **1.3 SAFETY AUDIT**

No safety audits to date.

## **1.4 MISCELLANEOUS SAFETY**

No notable safety issues

## 2. COMPLIANCE, FLOWS AND LOADINGS

### 2.1 COMPLIANCE

The finished water quality was within regulatory limits and all Bacteriological testing was completed for the month of January. A copy of the Operations Report to the Illinois Environmental Protection Agency (IEPA) is available on the SSWC website.

### 2.2 INFLUENT FLOWS AND LOADINGS

The total gallons pumped from the well field were 41.168 MG. The influent parameters were all within the normal range.

The influent flow and loadings are summarized below in Table 2.2

Table 2.2 Influent Concentrations and Flow

	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Well Flow Gals (MGD)
<b>Max.</b>	8.3	17.0	1.58	.318	-	370	300	1.625
<b>Min.</b>	8.1	13.7	.35	.196	-	330	272	1.175
<b>Avg.</b>	8.2	14.7	.67	.231	-	349	283	1.360
<b>Total</b>	-	-	-	-	-	-	-	41.168

### 2.3 EFFLUENT CONCENTRATIONS

The facility filtered 36.911 MG during the month with a daily average of 1.191 MG and a min/max 1.039/ 1.443 MG.

Table 2.3 Finished Water Quality

	Free CL2	Total CL2	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Phosphate
<b>Max.</b>	1.85	2.00	8.6		0.02	0.08	.92	370	292	2.31
<b>Min.</b>	1.38	1.45	8.4		0.01	0.005	0.38	100	220	1.77
<b>Avg.</b>	1.59	1.70	8.5		0.01	0.036	0.65	182	278	2.03
<b>MCL</b>	-	-	-	-	1.00	-	4.00	-	-	-
<b>SMCL</b>	-	-	-	-	0.30	0.050	2.00	-	-	-

## Finished Water Flow Comparison for FY 2020 -21

Time Period	2020-2021	2019-2020	2018-2019
Feb 2020- Jan 2021	395,279,167	359,206,807	380,970,204
Increase for the same period last year	36.1MG	- 21.8 MG	

FINISHED WATER PUMPING HISTORY						
	20-21	19-20	18-19	17-18	16-17	15-16
Feb	28,797,693	28,625,431	25,617,914	27,373,232	26,095,228	26,336,077
Mar	30,339,298	31,237,000	28,217,699	30,068,363	27,851,811	28,729,919
Apr	31,542,650	28,418,249	27,110,578	29,625,797	29,292,618	29,270,184
May	34,673,848	33,045,927	33,304,196	32,120,873	33,349,391	33,371,016
June	17,414,377	33,460,303	34,040,000	39,931,402	41,541,321	31,092,539
July	44,237,066	23,742,374	41,178,722	42,164,927	35,378,396	33,123,375
Aug	39,638,063	25,018,633	35,176,238	38,760,634	35,401,490	38,109,133
Sept	38,674,095	34,234,782	34,754,000	39,896,986	36,325,215	36,546,171
Oct	34,597,739	30,769,238	30,353,482	33,506,605	34,374,820	34,783,455
Nov	32,325,040	30,877,400	30,464,000	28,617,333	30,478,309	27,217,293
Dec	31,582,311	29,703,954	31,930,000	28,808,037	32,525,530	27,788,637
Jan	31,456,987	30,073,516	28,823,375	30,556,824	30,449,215	28,510,121
	-----	-----	-----	-----	-----	-----
Totals	395,279,167	359,206,807	380,970,204	401,431,013	393,063,344	374,877,920
Avg	1.08 MGD	.984 MGD	1.04 MGD	1.10 MGD	1.07 MGD	1.03 MGD

## 2.4 LAGOON DISCHARGE CONCENTRATIONS

The results for the NPDES lagoon discharge permit are summarized below.

Table 2.4 Weekly Grab Sample Analysis Results

Lagoon Effluent Results						
Date	Fe (mg/l)	Mn (mg/l)	Chloride (mg/l)	Cl <sup>2</sup> (mg/l)	pH (S.U.)	TSS (mg/l)
January 8 <sup>th</sup> , 2021	.52	.532	360	.01	8.5	4.8
Minimum	.52	.532	360	.01	8.5	4.8
Maximum	.52	.532	360	.01	8.5	4.8
Average	.52	.532	360			4.8
<b>Monthly Avg Limit</b>	<b>2.000</b>	<b>1.000</b>				<b>15</b>
<b>Daily Limit</b>	<b>4.000</b>	<b>2.000</b>	<b>500</b>	<b>0.05</b>	<b>6.0-9.0</b>	<b>30</b>

The Chloride sample for the month, performed by the Springfield Metropolitan Sanitary District, was below 30,000 mg/l for the month of January 2021. The limit for chloride discharge to the sanitary district is 30,000 mg/L.

## 3. OPERATIONS

### 3.1 EVENTS IMPACTING OPERATIONS

There was 1 incident that impacted the operation of the plant.

### 3.2 EMERGENCY & SERVICE CALLS

#### Service Calls:

- There was 0 emergency call out for the month.

### 3.3 EMERGENCY CALL-OUTS

There was 0 emergency call out for the month of January

- Kevin was on site when an issue arose and had to stay late

### 3.4 CUSTOMER INQUIRIES

There were numerous customer inquiries.

#### OTHER WORK PERFORMED

Trouble shooting of new train

Trouble shooting of CIP skid and CIP procedure

Inspected distribution mains

Consulted with new customers.

Repaired Train #2

Replaced BW valve on train #3

Flushed Train #3 air control system

Added to customer info database

Inspected booster station



In January we had another new customer hook onto South Sangamons water mains on Leach road.



While running the service line to our new customer the contractor discovered SSWCs waste effluent line. This line had not been located by USIC. USIC was called and it was then properly located.




On January 6<sup>th</sup> AAC arrived on site at SSWC to program for the New Berlin booster station. While adding the new program, AAC caused the Ultrafilter program to malfunction. This malfunction caused the LSPs to ramp up to max speed. This in turn caused a pressure surge that shut train 1 and 3 to shut down. It also caused damage to train 2. Some of the damage is this flange that burst.




This pressure surge caused this filter cartridge to burst



It also caused a filter cartridge to push up into the manifold, damaging it.



The damaged manifold and the flange after removal.



This pressure spike also caused the seal in the BW waste valve stem to fail. Causing the staff at SSWC to have to replace the valve and purge the air system of the water.

## **4. MAINTENANCE AND REPAIR**

### **4.1 PREVENTATIVE AND PREDICTIVE MAINTENANCE**

For the month of January 2021, there were 31 inspections, 3 preventative and 3 corrective maintenance activity completed.

### **4.2 CORRECTIVE REPAIR**

Pulling and cleaning pre filters on all 3 filter trains on weekly basis

CIP train 1,2 and 3

Replaced manifold on train #3

Worked with SCADAware in learning our system.

Replaced Backwash valve

Purged air control system

HTE arrived to repair compressors



## 5. PROJECT MANAGEMENT & SUPPORT

### 5.1 STAFFING & TRAINING

- Staff member training has been continuous and ongoing.
- Operator and Asst. Operator have been studying for EPA licensing test.

### 5.2 OPERATIONAL SUPPORT

The following individuals, either on-site or remotely, provided assistance in operation and/or maintenance of the plant during the month of December 2020.

- Kevin Canham
- Stephen Bivin
- Katie Krall
- Kevin Garman (SCADAware)
- Dan (SCADAware)
- HTE Compressor



## 5.3 BUDGET

Table 5.3 Operating Budget

Table 5.3 Budget Table

Budget Category	Month Budget	Month Actual	YTD Budget	YTD Actual	Annual Budget
Labor (D.L. + OH)	\$14,590.81	?	\$81,431	\$71,581	\$171,795
Utilities	\$8,30630		\$40,750	\$40,586	\$97,800
Chemicals	\$22,421.92		\$110,000	\$76,944	\$264,000
Maintenance & Repair	\$13,668.62		\$67,146	\$94,528	\$160,937
Chloride	\$12,979.73		\$65,800	\$61,400	\$157,920
Lab Supplies and Equipment	\$1,856.22		\$9,410	\$6,131	\$22,584
Office Supplies	\$213.04		\$1,080	\$264	\$2,592
Miscellaneous Expenses*	\$		\$	?	\$500
Other Operating Costs	\$	?	\$	\$6107	\$
Engineering Fees	\$2,547.95		\$12,500	\$5,430	\$30,000
Office Equipment rental	\$65		\$325	\$596	\$780
Locates	\$378.00	0	\$1,890	\$3,730	\$4536
Truck	\$3,287.67	0	\$6,667	\$131	\$40,000
<b>Total</b>	<b>\$80,315.26</b>	<b>\$</b>	<b>\$396,999</b>	<b>\$367,428</b>	<b>\$953,444</b>

\*as of September 21<sup>th</sup> 2020

## **6. CAPITAL PLANNING**

### **6.1 APPROVED CIP PROJECTS CURRENT STATUS**

New Berlin Meter master meter relocation project is commencing. Engineering and relocation plans have been finalized. Awaiting ground breaking.

Pigging project construction complete. Awaiting first pigging before completely releasing contractor.

BOP CPU replace is in the planning phase

Benton and Assoc has initiated the planning phase of the Chatham Emergency interconnect. Construction permit has been applied for.

### **6.2 DRAFT CAPITAL IMPROVEMENT PLAN**

The CIP is a planning document that includes all projects anticipated to exceed \$5,000 in cost over the next five years. The CIP is an ongoing process and will be refined from time to time as projects are completed and new issues are identified.





ILLINOIS ENVIRONMENTAL PROTECTION AGENCY  
DIVISION OF PUBLIC WATER SUPPLIES

South San Joaquin Water Commission - 1670080

January 2021

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY  
DIVISION OF PUBLIC WATER SUPPLIES

MONTHLY IRON REMOVAL AND ION EXCHANGE SOFTENING REPORT  
South Sangamon Water Commission - IL 1670080  
January 2021

Pumping Totals												Chemicals Applied						UF Filters						Softeners								
Time	Hours	Raw	Well	UF	Plant	HS	Lagoon	Sodium	Sodium	Ammonium	Fluorosilicic	Sodium	Hours since previous	Wash	Water	Water	Water	Water	Water	Water	Water	Regeneration										
Date Meter Read	Filter Ran	Prod. (Mgal)	Filtrated (Mgal)	Water Pumped (Mgal)	Pumpage (Mgal)	mg/l	Amt. as Cl	Amnt.	Used Calc	Used Calc	Used Calc	Phosphate	Bisulfite Pond	backwash	Water	Water	Water	Water	Water	Water	Water	Regeneration at mid-day indicate hours previous blowing.										
1	7:00	15.6	1,415	1,295	0.014	1,186	0.074	28	0.47	0	0.00	197	230	0	0.00	34	0.65	32	4.07	20	1266	0.66	0.66	0.046	0.696	0.369	4.30	0	0	0		
2	7:00	14.8	1,375	1,085	0.004	1,028	0.051	20	0.35	0	0.00	163	239	0	0.00	25	0.55	26	1.00	10	944	0.66	0.66	0.046	0.696	0.369	4.30	0	0	0		
3	7:00	15.0	1,759	1,293	0.005	1,122	0.053	26	0.53	0	0.00	196	239	0	0.00	32	0.65	64	2.26	0	0.00	0.66	0.66	0.048	0.698	0.370	4.30	0	0	0		
4	7:00	16.9	1,625	1,283	0.004	1,146	0.067	19	0.28	0	0.00	196	239	0	0.00	21	0.42	49	1.69	0	0.00	0.66	0.66	0.048	0.698	0.370	4.30	0	0	0		
5	7:00	14.4	1,354	1,245	0.018	1,006	0.088	23	0.41	0	0.00	190	239	0	0.00	27	0.61	49	1.93	15	821	0.66	0.66	0.078	0.814	0.431	3.80	0	0	0		
6	7:00	16.3	1,370	1,107	0.009	1,130	0.103	23	0.40	0	0.00	169	239	0	0.00	27	0.54	64	2.24	0	0.00	0.66	0.66	0.093	0.724	0.383	4.10	51.0	4562	21700		
7	7:00	16.6	1,400	1,204	0.009	1,092	0.084	16	0.27	0	0.00	184	239	0	0.00	31	0.65	3	1.11	2	1.02	0.66	0.66	0.080	0.787	0.417	4.80	30.0	6843	32550		
8	7:00	16.2	1,539	1,443	0.013	1,166	0.094	24	0.37	0	0.00	221	239	0	0.00	27	0.53	7	0.24	3	1.54	0.66	0.66	0.094	0.943	0.500	3.60	41.0	4562	21700		
9	7:00	14.5	1,332	1,187	0.012	1,057	0.077	22	0.40	0	0.00	182	230	0	0.00	25	0.54	7	0.26	4	-2.51	0.66	0.66	0.067	0.776	0.411	4.30	0	0	0		
10	7:00	15.4	1,386	1,100	0.009	1,129	0.078	25	0.43	0	0.00	168	239	0	0.00	28	0.57	9	0.32	1	0.62	0.66	0.66	0.068	0.719	0.381	4.10	41.0	4562	21700		
11	7:00	15.5	1,419	1,244	0.015	1,106	0.082	27	0.46	0	0.00	183	230	0	0.00	30	0.62	10	0.36	0	0.00	0.66	0.66	0.072	0.813	0.431	53.0	32.0	4562	21700		
12	7:00	16.1	1,429	1,312	0.006	1,066	0.089	25	0.42	0	0.00	193	230	0	0.00	28	0.60	9	0.33	2	1.07	0.66	0.66	0.075	0.858	0.454	3.80	41.0	48.0	6843	32550	
13	7:00	14.8	1,362	1,253	0.016	1,075	0.096	25	0.44	0	0.00	194	230	0	0.00	28	0.59	12	0.44	0	0.00	0.66	0.66	0.076	0.819	0.434	4.80	36.0	4562	21700		
14	7:00	16.5	1,446	1,224	0.012	1,146	0.068	22	0.36	0	0.00	180	220	0	0.00	25	0.50	13	0.45	0	0.00	0.66	0.66	0.063	0.800	0.424	4.00	0	0	0		
15	7:00	14.9	1,219	1,198	0.005	1,040	0.084	23	0.45	0	0.00	176	220	0	0.00	27	0.59	23	0.88	0	0.00	0.66	0.66	0.095	0.783	0.415	4.80	0	0	0		
16	7:00	15.5	1,265	1,039	0.021	0.999	0.015	23	0.44	0	0.00	153	220	0	0.00	28	0.64	58	2.30	0	0.00	0.66	0.66	0.015	0.679	0.360	3.80	0	0	0		
17	7:00	15.2	1,216	1,102	0.000	1,035	0.027	23	0.45	0	0.00	162	220	0	0.00	28	0.62	72	2.75	0	0.00	0.66	0.66	0.013	0.720	0.382	3.90	0	0	0		
18	7:00	15.6	1,252	1,070	0.009	1,054	0.017	25	0.48	0	0.00	157	220	0	0.00	29	0.63	12	0.45	0	0.00	0.66	0.66	0.012	0.699	0.371	4.20	0	0	0		
19	7:00	16.9	1,363	1,191	0.007	1,144	0.031	22	0.39	0	0.00	175	220	0	0.00	26	0.52	8	0.28	0	0.00	0.66	0.66	0.017	0.778	0.413	96.0	34.0	45.0	6843	32550	
20	7:00	18.1	1,433	1,238	0.014	1,208	0.025	22	0.37	0	0.00	182	220	0	0.00	27	0.51	10	0.33	0	0.00	0.66	0.66	0.015	0.809	0.429	4.00	40.0	4562	21700		
21	7:00	16.4	1,284	1,125	0.013	1,069	0.025	21	0.39	0	0.00	165	220	0	0.00	27	0.58	9	0.33	0	0.00	0.66	0.66	0.015	0.735	0.390	4.30	17.0	4562	21700		
22	7:00	16.0	1,279	1,147	0.004	1,074	0.024	23	0.43	0	0.00	168	220	0	0.00	28	0.60	68	2.51	0	0.00	0.66	0.66	0.014	0.750	0.397	24.0	77.0	4562	21700		
23	7:00	16.9	1,280	1,150	0.008	1,080	0.026	32	0.59	0	0.00	166	220	0	0.00	26	0.55	11	0.40	0	0.00	0.66	0.66	0.021	0.739	0.391	3.80	0	0	0		
24	7:00	17.6	1,456	1,178	0.007	1,042	0.052	23	0.38	0	0.00	173	220	0	0.00	29	0.63	17	0.65	0	0.00	0.66	0.66	0.082	0.770	0.408	4.00	0	0	0		
25	7:00	17.1	1,255	1,170	0.000	1,082	0.045	23	0.44	0	0.00	172	220	0	0.00	29	0.61	40	1.46	2	213	0.66	0.66	0.040	0.765	0.405	102.0	228.1	4562	10550		
26	7:00	18.5	1,451	1,194	0.005	1,160	0.028	21	0.35	0	0.00	175	220	0	0.00	26	0.51	66	2.25	0	0.00	0.66	0.66	0.014	0.780	0.414	71.0	136.0	6843	32550		
27	7:00	16.4	1,366	1,178	0.017	1,071	0.055	23	0.46	0	0.00	173	220	0	0.00	28	0.60	68	2.51	0	0.00	0.66	0.66	0.030	0.770	0.408	3.40	77.0	4562	21700		
28	7:00	16.6	1,345	1,160	0.004	1,054	0.061	22	0.39	0	0.00	170	220	0	0.00	26	0.56	20	0.75	5	-3.93	0.66	0.66	0.051	0.758	0.402	66.0	42.0	4562	21700		
29	7:00	15.9	1,338	1,163	0.011	1,014	0.071	23	0.41	0	0.00	171	220	0	0.00	27	0.61	9	0.35	3	203	0.66	0.66	0.061	0.760	0.403	44.0	72.0	4562	21700		
30	7:00	17.2	1,401	1,207	0.010	1,119	0.069	22	0.38	0	0.00	177	220	0	0.00	27	0.55	9	0.32	2	139	0.66	0.66	0.064	0.789	0.418	40.0	40.0	228.1	10550		
31	7:00	15.7	1,328	1,186	0.005	0.998	0.069	22	0.40	0	0.00	170	215	0	0.00	27	0.62	10	0.40	30	2085	0.66	0.66	0.059	0.775	0.411	37.0	43.0	4562	21700		
Total		499.4	42,468	36,911	0.287	33,698	1,825	716	1,274	0	0	548.7	937	0	0	82	1,790	307	28.50	81	5433	0.66	0.66	1,550	24,125	12,986	69.0	74.0	228.1	10550		
Ave.		16.1	1,360	1,191	0.009	1,087	0.059	23	0.41	0	0.00	177	223	0	0.00	27	0.58	26.0	0.95	26	1.77	0.66	0.66	0.050	0.778	0.412	62.7	38.7	4562	19850		
Max		18.5	1,625	1,443	0.021	1,208	0.103	32	0.59	0	0	221	230	0	0	34	0.65	72	2.75	30	2085	0.66	0.66	0.053	0.943	0.500	114.0	71.0	136.0	94.0	9,24	43,400
Min		14.4	1,175	1,039	0.000	0.998	0.015	16.0	0.27	0	0.00	152,509	2.15	0	0.00	21	0.42	3	0.11	5	3.93	0.66	0.66	0.012	0.679	0.360	29.0	17.0	30.0	41.0	0	0

FLUORIDATION

Pre-reactor Membrane Backwash Post Stabilizer Type of Chlorine Used Sodium Hypochlorite 2.5% Hydrofluoric Acid 19% F Fluoride Analyzer Used Hatch CL7(2) & 550c Chlorine Analyzers Used Hatch 2200 SPADNS method Post Cleanwell Post Cleanwell Lagoon Effluent

Identify in the information in this report is complete and accurate to the best of my knowledge.  
Reported by: \_\_\_\_\_ Date: \_\_\_\_\_ Illinois Operator Certification# \_\_\_\_\_ 25349899  
Data Bacterial Test 1/28/2021

