



Monthly Operating Report

December:2022

So. Sangamon
Water Commission
January 17th, 2023

SSWC

9199 Buckhart Rd Rochester IL 62563

TABLE OF CONTENTS

SECTION	PAGE NO.
Executive Summary.....	ES-1
1. SAFETY	1-1
1.1 Safety Training	1-1
1.2 Lost time Accidents	1-1
1.3 Safety Audit	1-1
1.4 Miscellaneous Safety.....	1-1
2. COMPLIANCE, FLOWS AND LOADINGS	2-2
2.1 Compliance	2-2
2.2 Influent flows and loadings	2-2
2.3 Effluent Concentrations	2-2
2.4 Lagoon Discharge Concentrations	2-4
3. OPERATIONS.....	3-1
3.1 Events impacting operations	3-1
3.2 Emergency & Service calls.....	3-1
3.3 Emergency Call-outs	3-1
3.4 Customer Inquiries	3-1
4. MAINTENANCE AND REPAIR.....	4-7
4.1 Preventative and predictive maintenance.....	4-7
4.2 Corrective repairs	4-7
5. PROJECT MANAGEMENT & SUPPORT.....	5-1
5.1 Staffing & Training.....	5-1
5.2 Corporate Support.....	5-2
5.3 Budget.....	5-3
6. CAPITAL PLANNING	6-1
6.1 Approved CIP Projects Current status.....	6-1
6.2 Draft Capital Improvement Plan	6-1

LIST OF TABLES

TABLE	PAGE NO.
Table 2.2 Influent Concentrations and Flow.....	2-2
Table 2.3 Finished Water Quality.....	2-2
Table 2.4 Weekly Grab Sample Analysis Results.....	2-4
Table 4.1 Budget Table.....	5-3

EXECUTIVE SUMMARY

Safety. Safety is the number one priority at South Sangamon. We have instituted a monthly safety meeting for operations staff at the plant. There were no lost time accidents in the month of December 2022.

Compliance. The finished water quality was within regulatory limits and all reporting and sampling requirements were met for the month. A copy of the Operations Report submitted to the Illinois Environmental Protection Agency is available at www.sswc.us.

During the month of December 2022, the plant pumped 44.246 million gallons from the well field and 36.245 million gallons of finished water. This is .3 million gallons less than December of 2021.

The SSWC plant has been removed from Critical Review status.

Operations. There was 0 emergency call-outs for the month. There were numerous customer inquiry for the month.

Maintenance and Repair. For the month of December 2022, there were 31 inspections, 3 preventative and multiple corrective maintenance activity completed. There was 1 repair activities performed .

Budget. Passed at April 18th 2022 meeting.

Capital Planning.

Chatham emergency interconnect

Onsite fuel storage tanks

Detention Tank

1. SAFETY

1.1 SAFETY TRAINING

At South Sangamon we strive to provide a safe working environment for all employees. This is accomplished with daily safety meetings and open communication.

1.2 LOST TIME ACCIDENTS

There were 0 lost time accidents in the month of December 2022.

1.3 SAFETY AUDIT

No safety audits to date.

1.4 MISCELLANEOUS SAFETY

No notable safety issues

2. COMPLIANCE, FLOWS AND LOADINGS

2.1 COMPLIANCE

The finished water quality was within regulatory limits and all Bacteriological testing was completed for the month of December. A copy of the Operations Report to the Illinois Environmental Protection Agency (IEPA) is available on the SSWC website.

2.2 INFLUENT FLOWS AND LOADINGS

The total gallons pumped from the well field were 44.246 MG. The influent parameters were all within the normal range.

The influent flow and loadings are summarized below in Table 2.2

Table 2.2 Influent Concentrations and Flow								
	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Well Flow Gals (MGD).
Max.	7.2	15.7	3.43	.335	-	365	340	1.708
Min.	6.9	11.8	.37	.168	-	280	300	.573
Avg.	7.1	13.7	.93	.257	-	340	310	1.427
Total	-	-	-	-	-	-	-	44.246

2.3 EFFLUENT CONCENTRATIONS

The facility filtered 39.058 MG during the month with a daily average of 1.260 MG and a min/max .526/ 1.517 MG.

Table 2.3 Finished Water Quality										
	Free CL2	Total CL2	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Phosphate
Max.	.09	3.90	7.8		0.02	0.064	.88	360	320	4.03
Min.	0.04	2.56	7.4		0.01	0.004	0.43	90	280	2.01
Avg.	0.06	3.23	7.6		0.01	0.021	0.72	138	302	2.46
MCL	-	-	-	-	1.00	-	4.00	-	-	-
SMCL	-	-	-	-	0.30	0.050	2.00	-	-	-

Finished Water Flow Comparison for FY 2022

Time Period	21-22	20-21	19-20
Jan 2022- Dec 2022	410,415,216	417,875,114	393,895,696
Increase for the same period last year		-7.5 MG	24 MG

FINISHED WATER PUMPING HISTORY						
	2022	2021	2020	2019	2018	2017
Jan	32,322,270	31,456,987	30,073,516	28,823,375	30,556,824	30,449,215
Feb	32,451,653	30,638,842	28,797,693	28,625,431	25,617,914	27,373,232
Mar	33,909,417	33,633,244	30,339,298	31,237,000	28,217,699	30,068,363
Apr	31,991,050	33,214,211	31,542,650	28,418,249	27,110,578	29,625,797
May	37,459,417	35,932,776	34,673,848	33,045,927	33,304,196	32,120,873
June	38,496,145	37,616,256	17,414,377	33,460,303	34,040,000	39,931,402
July	38,861,790	39,001,640	44,237,066	23,742,374	41,178,722	42,164,927
Aug	36,977,913	39,953,900	39,638,063	25,018,633	35,176,238	38,760,634
Sept	32,355,302	38,935,839	38,674,095	34,234,782	34,754,000	39,896,986
Oct	29,576,287	34,918,955	34,597,739	30,769,238	30,353,482	33,506,605
Nov	35,563,717	31,181,005	32,325,040	30,877,400	30,464,000	28,617,333
Dec	30,450,255	31,391,459	31,582,311	29,703,954	31,930,000	28,808,037
	-----	-----	-----	-----	-----	-----
Totals	410,415,216	417,875,114	393,895,696	357,956,666	382,703,653	401,323,404
Avg	1.12 MGD	1.15 MGD	1.08 MGD	.981 MGD	1.05 MGD	1.10 MGD

2.4 LAGOON DISCHARGE CONCENTRATIONS

The results for the NPDES lagoon discharge permit are summarized below.

Table 2.4 Weekly Grab Sample Analysis Results

Lagoon Effluent Results						
Date	Fe (mg/l)	Mn (mg/l)	Chloride (mg/l)	Cl² (mg/l)	pH (S.U.)	TSS (mg/l)
Dec 5th 2022	.27	.197	369	.01	7.5	<4
Minimum	.27	.197	369	.01	7.5	<4
Maximum	.27	.197	369	.01	7.5	<4
Average	.27	.197	369	.01	7.5	<4
Monthly Avg Limit	2.000	1.000				15
Daily Limit	4.000	2.000	500	0.05	6.0-9.0	30

The Chloride sample for the month, performed by the Springfield Metropolitan Sanitary District, was below 30,000 mg/l for the month of December 2022. The limit for chloride discharge to the sanitary district is 30,000 mg/L.

3. OPERATIONS

3.1 EVENTS IMPACTING OPERATIONS

There was 0 incident that impacted the operation of the plant.

3.2 EMERGENCY & SERVICE CALLS

Service Calls:

- There was 0 emergency call out for the month.

3.3 EMERGENCY CALL-OUTS

There was 0 emergency call out for the month.

3.4 CUSTOMER INQUIRIE

There were numerous customer inquiries.

OTHER WORK PERFORMED


Trouble shooting all trains
Trouble shooting of CIP skid and CIP procedure
Inspected distribution mains
Inspected booster station
Flushed air system
Trouble shooting of Ion exchange system
Repair of air compressors
Customer service



Plant compressor #2 went down during the month of December. Plant staff piped in portable compressors to help with air pressure.



After inspection it was found that the motor starter and the compressor control module had both went bad. Parts were ordered. The compressor is also blowing oil and has been for sometime. Option are being explored.



New motor start and control module have arrived and have been installed.



Replacement pump and motor have arrived

4. MAINTENANCE AND REPAIR

4.1 PREVENTATIVE AND PREDICTIVE MAINTENANCE

For the month of December 2022, there were 31 inspections, 3 preventative and multiple corrective maintenance activity completed.

4.2 CORRECTIVE REPAIR

Pulling and cleaning pre filters on all 3 filter trains on weekly basis

CIP train 1,2 and 3

Purged air control system

Air Compressor service

Repair of train #3

Repair of train #2

Air Compressor repair

5. PROJECT MANAGEMENT & SUPPORT

5.1 STAFFING & TRAINING

- Staff member training has been continuous and ongoing.
- Operator and Asst. Operator have been studying for EPA licensing test.

5.2 OPERATIONAL SUPPORT

The following individuals, either on-site or remotely, provided assistance in operation and/or maintenance of the plant during the month of December 2022.

- Kevin Canham
- Stephen Bivin
- Katie Krall
- Dan (SCADAware)
- Joe Lee
- Kevin Garmin (SCADAware)

5.3 BUDGET

Table 5.3 Operating Budget

Table 5.3 Budget Table

Budget Table was removed: see clerks report

6. CAPITAL PLANNING

6.1 APPROVED CIP PROJECTS CURRENT STATUS

Pigging project construction complete. Awaiting first pigging before completely releasing contractor.

Benton and Assoc put the Chatham Interconnect out for bid. There were 2 bids; The bid was awarded to Petersburg Plumbing.

Train #2 upgrade repair has been completed and train #2 online.

Meter Project progressing, All meter bases and registers are on site. 5 cell meters have been installed.

6.2 DRAFT CAPITAL IMPROVEMENT PLAN

The CIP is a planning document that includes all projects anticipated to exceed \$5,000 in cost over the next five years. The CIP is an ongoing process and will be refined from time to time as projects are completed and new issues are identified.

1. Second Torray filter train has been installed
2. Onsite fuel storage tanks have arrived on site and pumps have been installed
3. BOP CPU upgrade has been completed
4. Second raw water detention tank
5. SSWC/Chatham interconnect

South Sangamon Water Commission - IL 1670080 December 2022

Time	Hours	Pumping Totals					Chemicals Applied												UF Filters													Softeners				
		Raw	Well	UF	Plant	HS	Legion	Sodium Permanganate			Sodium Bisulfite BW			Sodium Hypochlorite			Ammonium Sulfate			Fluorosisic Acid			Phosphate			Sodium Bisulfite Pond			Hours since previous backwash				Water Served (Mgal)	Water Bypassed (Mgal)	Each day/indicate total number of hours since previous regeneration.	Regeneration
		Well	Plant	Filled	Pumpage	Plant	Effluent	Amnt	Used	Calc	Amnt	Used	Calc	Amnt	Used	Calc	Amnt	Used	Calc	Amnt	Used	Calc	Amnt	Used	Calc	1	2	3	4	Gal	Gal	Gal				
		Pod.	Pod.	(Mgal)	(Mgal)	(Mgal)	(Mgal)	lbs.	lbs.	lbs.	lbs.	lbs.	lbs.	lbs.	lbs.	lbs.	lbs.	lbs.	lbs.	as F	as NH3	as P04	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l			

CHLORINATION				FLUORINATION		SODIUM BISULFITE					
Type of Chlorine Used	Sodium Hypochlorite 12.5 %	Type of Fluoride Used	Hydrofluoric Acid 19 %	Amnt	Used	Calc	Amnt	Used	Calc		
Chlorine Analyzers Usat. Hach CLT 72 & 550scc		Fluoride Analyzer Usat. Hach 2200, SPADMS method		16.0	16.0	16.0	16.0	16.0	16.0		
Pre-erator				20.0	20.0	20.0	20.0	20.0	20.0		
Membrane Backwash				40.0	40.0	40.0	40.0	40.0	40.0		
Post Solener				12.5	12.5	12.5	12.5	12.5	12.5		
Post Solener				20.0	20.0	20.0	20.0	20.0	20.0		
Post Cleanell				10.0	10.0	10.0	10.0	10.0	10.0		
Post Cleanell				10.0	10.0	10.0	10.0	10.0	10.0		
Legion Effluent				4.0	4.0	4.0	4.0	4.0	4.0		
Certify that the information in this report is complete and accurate to the best of my knowledge.											
Reported by:			Date:			Date			Date		
Illnos Operator Certification I-2534-1959			15/2023			12/20/2022			12/20/2022		

