



SSWC

9199 Buckhart Rd Rochester IL 62563

Monthly Operating Report

July:2023

So. Sangamon
Water Commission
August 21st, 2023

TABLE OF CONTENTS

SECTION	PAGE NO.
Executive Summary.....	ES-1
1. SAFETY	1-1
1.1 Safety Training	1-1
1.2 Lost time Accidents	1-1
1.3 Safety Audit	1-1
1.4 Miscellaneous Safety.....	1-1
2. COMPLIANCE, FLOWS AND LOADINGS	2-2
2.1 Compliance	2-2
2.2 Influent flows and loadings	2-2
2.3 Effluent Concentrations	2-2
2.4 Lagoon Discharge Concentrations	2-4
3. OPERATIONS.....	3-1
3.1 Events impacting operations	3-1
3.2 Emergency & Service calls	3-1
3.3 Emergency Call-outs	3-1
3.4 Customer Inquiries	3-1
4. MAINTENANCE AND REPAIR.....	4-9
4.1 Preventative and predictive maintenance.....	4-9
4.2 Corrective repairs	4-9
5. PROJECT MANAGEMENT & SUPPORT	5-1
5.1 Staffing & Training.....	5-1
5.2 Corporate Support.....	5-2
5.3 Budget	5-3
6. CAPITAL PLANNING	6-1
6.1 Approved CIP Projects Current status.....	6-1
6.2 Draft Capital Improvement Plan	6-1

LIST OF TABLES

TABLE	PAGE NO.
Table 2.2 Influent Concentrations and Flow	2-2
Table 2.3 Finished Water Quality	2-2
Table 2.4 Weekly Grab Sample Analysis Results	2-4
Table 4.1 Budget Table.....	5-3

EXECUTIVE SUMMARY

Safety. Safety is the number one priority at South Sangamon. We have instituted a monthly safety meeting for operations staff at the plant. There were no lost time accidents in the month of July 2023.

Compliance. The finished water quality was within regulatory limits and all reporting and sampling requirements were met for the month. A copy of the Operations Report submitted to the Illinois Environmental Protection Agency is available at www.sswc.us

During the month of July 2023, the plant pumped 53.16 million gallons from the well field and 46.133 million gallons of finished water. This is 4.7 million gallons more than July 2022.

The SSWC plant has been removed from Critical Review status.

Operations. There was 4 emergency call-outs for the month. There were numerous customer inquiry for the month.

Maintenance and Repair. For the month of July 2023, there were 31 inspections, 3 preventative and multiple corrective maintenance activity completed. There was 4 repair activities performed .

Budget. Passed at April 17th 2023 meeting.

Capital Planning.

Chatham emergency interconnect

Onsite fuel storage tanks

Detention Tank

1. SAFETY

1.1 SAFETY TRAINING

At South Sangamon we strive to provide a safe working environment for all employees. This is accomplished with daily safety meetings and open communication.

1.2 LOST TIME ACCIDENTS

There were 0 lost time accidents in the month of July 2023.

1.3 SAFETY AUDIT

No safety audits to date.

1.4 MISCELLANEOUS SAFETY

No notable safety issues

2. COMPLIANCE, FLOWS AND LOADINGS

2.1 COMPLIANCE

The finished water quality was within regulatory limits and all Bacteriological testing was completed for the month of July. A copy of the Operations Report to the Illinois Environmental Protection Agency (IEPA) is available on the SSWC website.

2.2 INFLUENT FLOWS AND LOADINGS

The total gallons pumped from the well field were 53.160 MG. The influent parameters were all within the normal range.

The influent flow and loadings are summarized below in Table 2.2

Table 2.2 Influent Concentrations and Flow								
	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Well Flow Gals (MGD).
Max.	7.6	15.7	3.34	.330	-	385	365	2.001
Min.	6.9	14.2	.36	.121	-	300	300	1.014
Avg.	7.18	14.8	.70	.199	-	340	323	1.715
Total	-	-	-	-	-	-	-	53.160

2.3 EFFLUENT CONCENTRATIONS

The facility filtered 46.133 MG during the month with a daily average of 1.488 MG and a min/max .658/ 1.745 MG.

Table 2.3 Finished Water Quality										
	Free CL2	Total CL2	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Phosphate
Max.	.10	3.85	7.8		0.08	0.037	0.96	160	338	2.56
Min.	0.03	1.10	7.1		0.01	0.004	0.45	100	300	1.84
Avg.	0.07	3.13	7.6		0.01	0.014	0.69	121	308	2.19
MCL	-	-	-	-	1.00	-	4.00	-	-	-
SMCL	-	-	-	-	0.30	0.050	2.00	-	-	-

Finished Water Flow Comparison for FY 2022-23

Time Period	22-23	21-22	20-21
Aug 2022- July-2023	417,244,575	421,872,900	418,311,204
Increase for the same period last year		-4.6 MG	3.6 MG

FINISHED WATER PUMPING HISTORY						
	2022-23	2021-22	2020-21	2019-20	2018-19	2017-18
Aug	36,977,913	39,953,900	39,638,063	25,018,633	35,176,238	38,760,634
Sept	32,355,302	38,935,839	38,674,095	34,234,782	34,754,000	39,896,986
Oct	29,576,287	34,918,955	34,597,739	30,769,238	30,353,482	33,506,605
Nov	35,563,717	31,181,005	32,325,040	30,877,400	30,464,000	28,617,333
Dec	30,450,255	31,391,459	31,582,311	29,703,954	31,930,000	28,808,037
Jan	37,721,005	32,322,270	31,456,987	30,073,516	28,823,375	30,556,824
Feb	33,481,076	32,451,653	30,638,842	28,797,693	28,625,431	25,617,914
Mar	36,781,261	33,909,417	33,633,244	30,339,298	31,237,000	28,217,699
Apr	36,832,617	31,991,050	33,214,211	31,542,650	28,418,249	27,110,578
May	43,484,155	37,459,417	35,932,776	34,673,848	33,045,927	33,304,196
June	22,455,176	38,496,145	37,616,256	17,414,377	33,460,303	34,040,000
July	41,565,811	38,861,790	39,001,640	44,237,066	23,742,374	41,178,722
	-----	-----	-----	-----	-----	-----
Totals	417,244,575	421,872,900	418,311,204	367,682,455	370,030,379	389,615,528
Avg	1.14 MGD	1.16 MGD	1.15 MGD	1.01 MGD	1.01 MGD	1.07 MGD

2.4 LAGOON DISCHARGE CONCENTRATIONS

The results for the NPDES lagoon discharge permit are summarized below.

Table 2.4 Weekly Grab Sample Analysis Results

Lagoon Effluent Results						
Date	Fe (mg/l)	Mn (mg/l)	Chloride (mg/l)	Cl ² (mg/l)	pH (S.U.)	TSS (mg/l)
July 21st, 2023						
Minimum	.04	.232	200.8	.05	7.7	7.2
Maximum	.04	.232	200.8	.05	7.7	7.2
Average	.04	.232	200.8	.05	7.7	7.2
Monthly Avg Limit	2.000	1.000				15
Daily Limit	4.000	2.000	500	0.05	6.0-9.0	30

The Chloride sample for the month, performed by the Springfield Metropolitan Sanitary District, was below 30,000 mg/l for the month of July 2023. The limit for chloride discharge to the sanitary district is 30,000 mg/L.

3. OPERATIONS

3.1 EVENTS IMPACTING OPERATIONS

There were over 200 incident that impacted the operation of the plant.

Backwash low flow

Ion exchange alarm

Westech filters comm loss

Power surge

Power Sag

Power Outages

Ion Exchange Brine Pump

Well comm loss Alarm

Westech production Failure

Train #3 damage

3.2 EMERGENCY & SERVICE CALLS

Service Calls:

- There was 1 emergency call out for the month.

3.3 EMERGENCY CALL-OUTS

There was 4 emergency call out for the month.

3.4 CUSTOMER INQUIRIE

There were numerous customer inquiries.

OTHER WORK PERFORMED

Inspected distribution mains

Inspected booster station

Customer service


Air Compressor research

SCADA programming

New Berlin Booster station trouble shooting


Cell Transmitter Installation

A leak was detected at the Neuman residence. After excavating the service line Steve Ray plumbing attempted to fix the leak but found that there were multiple leaks in the line.





A new tap was required at the Neuman residence.



A new service line was bored in under Mansion Road.



Eric from Hach was onsite to repair the Monochloramine analyzer. He was not able to repair it on location. The monochloramine analyzer has been boxed to ship back to the manufacturer for repair for the third time.



A new sump pump was installed in the New Berlin Booster station



Filter train #3 was damaged when a filter comm loss occurred causing the train over pressurizer.

4. MAINTENANCE AND REPAIR

4.1 PREVENTATIVE AND PREDICTIVE MAINTENANCE

For the month of July 2023, there were 31 inspections, 3 preventative and multiple corrective maintenance activity completed.

4.2 CORRECTIVE REPAIR

Pulling and cleaning pre filters on all 3 filter trains on weekly basis

CIP train 1,2 and 3

Purged air control system

Air Compressor service

Raw water line flushing

Detention tank flush

Flushing Air Lines

Maintenance of New Berlin Booster Station

Meter Transmitter Replacement

Well Communication Repair

Train #3 Repair

Sump Replacement

Service Line Replacement

5. PROJECT MANAGEMENT & SUPPORT

5.1 STAFFING & TRAINING

- Staff member training has been continuous and ongoing.
- Operator and Asst. Operator have been studying for EPA licensing test.

5.2 OPERATIONAL SUPPORT

The following individuals, either on-site or remotely, provided assistance in operation and/or maintenance of the plant during the month of July 2023.

- Kevin Canham
- Stephen Bivin
- Katie Krall
- Dan (SCADAware)
- Joe Lee Electric
- Kevin Garmin (SCADAware)
- Petersburg Plumbing

5.3 BUDGET

Table 5.3 Operating Budget

Table 5.3 Budget Table

Budget Table was removed: see clerks report

6. CAPITAL PLANNING

6.1 APPROVED CIP PROJECTS CURRENT STATUS

Pigging project construction complete. Awaiting first pigging before completely releasing contractor.

The Chatham /South Sangamon emergency interconnect is progressing. There was a preconstruction meeting in February. Petersburg Plumbing has pushed back the construction start date.

Meter Project progressing, All meter bases and registers are on site. 13 cell meters have been installed.

6.2 DRAFT CAPITAL IMPROVEMENT PLAN

The CIP is a planning document that includes all projects anticipated to exceed \$5,000 in cost over the next five years. The CIP is an ongoing process and will be refined from time to time as projects are completed and new issues are identified.

1. Second Torray filter train has been installed
2. Onsite fuel storage tanks have arrived on site and pumps have been installed
3. BOP CPU upgrade has been completed
4. Second raw water detention tank
5. SSWC/Chatham interconnect

South Sangamon Water Commission - IL1670080

July 2023

Page 2 of 2

Physical and Chemical Tests																												Membrane Integrity									
Raw														Pre UF Membrane				Post UF Membrane				Post IEX				Finished								Post Filter			
Date	pH	Temp deg. C	Alk. mg/L	Hard. mg/L	Total mg/L	Turbidity	Fe mg/L	Mn mg/L	Total Soluble mg/L	Total Turbidity				Total Fe mg/L	Mn mg/L	Total Hard. mg/L	Total Fe mg/L	Mn mg/L	Total Fluoride mg/L	Ortho Phosphate mg/L	Free Ammonia mg/L	Mono-Chloramine mg/L	F mg/L	T mg/L	Distribution		Bank 1	Bank 2	Bank 3								
										Alk. mg/L	Hard. mg/L	NTU	Fe mg/L												Mn mg/L	Chloride mg/L				1	2	3	4	F mg/L	T mg/L		
1	7.20	14.4	320	372	0.70	0.216		0.291	0.067			0.030	0.37		7.70	0.39	314	116	0.02	0.010	0.50	2.14	0.01	1.94	0.05	2.94											
2	7.20	14.6	310	366	0.66	0.216		0.284	0.061			0.044	0.39		7.60	0.37	310	118	0.01	0.014	0.56	2.51	0.01	1.84	0.04	2.74											
3	7.60	15.3	300	340	0.44	0.203		0.321	0.046	0.02	0.019	0.36		7.20	0.38	300	110	0.01	0.010	0.70	2.47	0.01	2.05	0.09	3.08												
4	7.30	14.5	310	352	0.56	0.198		0.287	0.041	0.01	0.010	0.33		7.60	0.38	310	110	0.01	0.012	0.81	2.36	0.01	2.15	0.04	3.11												
5	7.10	14.2	310	350	0.50	0.185		0.304	0.052	0.01	0.033	0.35		7.50	0.38	300	100	0.01	0.004	0.78	2.10	0.01	2.21	0.05	3.15												
6	7.10	14.9	310	345	1.29	0.330		0.590	0.024	0.01	0.030	0.38		7.50	0.42	300	120	0.01	0.007	0.73	2.14	0.01	3.07	0.10	3.10												
7	7.20	14.5	310	340	3.34	0.277		0.577	0.048	0.01	0.028	0.36		7.50	0.40	300	100	0.02	0.012	0.88	2.08	0.02	1.81	0.08	3.14												
8	7.10	14.4	310	340	2.30	0.219		0.298	0.052	0.01	0.032	0.32		7.50	0.34	300	100	0.01	0.020	0.70	2.56	0.01	1.64	0.08	3.08												
9	7.10	14.3	310	345	1.16	0.221		0.280	0.044	0.01	0.027	0.30		7.50	0.40	300	110	0.01	0.024	0.88	2.38	0.01	2.30	0.09	3.11												
10	7.20	15.7	360	310	0.66	0.212		0.336	0.049	0.02	0.032	0.30		7.70	0.38	300	160	0.02	0.015	0.72	2.34	0.02	2.66	0.09	3.24												
11	7.20	14.6	360	310	0.66	0.212		0.317	0.042	0.02	0.041	0.32		7.70	0.36	310	140	0.01	0.016	0.45	2.36	0.01	4.30	0.08	3.30												
12	7.20	14.8	365	310	0.62	0.210		0.350	0.044	0.02	0.024	0.40		7.60	0.42	300	100	0.02	0.010	0.61	2.52	0.01	3.00	0.08	3.50												
13	7.10	14.8	360	310	0.55	0.210		0.324	0.046	0.01	0.027	0.42		7.60	0.40	300	100	0.02	0.009	0.69	2.10	0.01	2.79	0.10	3.52												
14	7.10	15.3	360	385	0.41	0.203		0.318	0.037	0.02	0.037	0.40		7.60	0.37	300	100	0.02	0.037	0.78	2.04	0.01	2.09	0.09	2.84	pass	pass										
15	7.20	14.4	358	300	0.48	0.214		0.309	0.041	0.01	0.029	0.40		7.70	0.38	320	100	0.01	0.019	0.69	2.11	0.01	2.11	0.05	2.88												
16	7.20	14.6	360	310	0.54	0.217		0.322	0.048	0.01	0.024	0.40		7.70	0.41	320	104	0.01	0.011	0.84	2.10	0.01	2.80	0.03	2.96												
17	7.10	14.2	318	342	0.46	0.199		0.341	0.067	0.01	0.032	0.38		7.60	0.46	308	120	0.01	0.012	0.96	1.97	0.01	2.80	0.05	3.36												
18	7.20	15.1	310	340	0.49	0.192		0.336	0.036	0.01	0.042	0.40		7.80	0.42	310	100	0.01	0.013	0.82	2.02	0.01	2.81	0.07	3.60												
19	7.20	14.9	320	330	0.47	0.177		0.320	0.036	0.02	0.080	0.41		7.60	0.36	310	120	0.02	0.015	0.75	2.08	0.01	2.52	0.10	3.38												
20	7.20	14.9	310	355	0.42	0.184		0.320	0.039	0.01	0.061	0.44		7.60	0.40	310	110	0.01	0.010	0.71	2.13	0.01	0.75	0.07	1.10												
21	7.20	15.2	310	340	0.41	0.168		0.287	0.043	0.01	0.098	0.38		7.70	0.34	310	160	0.01	0.018	0.74	2.21	0.01	2.35	0.07	2.68												
22	7.20	14.9	310	350	0.36	0.172		0.280	0.034	0.01	0.060	0.36		7.60	0.38	300	140	0.01	0.021	0.88	2.10	0.01	2.56	0.08	2.94												
23	7.20	15.1	310	360	0.45	0.197		0.312	0.037	0.01	0.040	0.37		7.60	0.40	310	140	0.01	0.018	0.72	2.07	0.01	2.75	0.07	3.42												
24	7.10	14.7	310	345	0.36	0.183		0.286	0.047	0.02	0.068	0.02		7.60	0.43	310	160	0.01	0.007	0.88	2.07	0.01	2.70	0.08	3.64												
25	7.20	14.9	320	340	0.57	0.174		0.393	0.050	0.01	0.065	0.01		7.70	0.40	310	120	0.02	0.009	0.67	2.02	0.01	3.53	0.05	3.86												
26	7.20	15.5	310	340	0.44	0.187		0.312	0.039	0.01	0.057	0.01		7.70	0.38	310	140	0.01	0.013	0.53	1.95	0.01	3.46	0.09	3.80												
27	7.20	15.3	310	345	0.66	0.174		0.309	0.051	0.02	0.062	0.02		7.70	0.40	310	140	0.08	0.006	0.78	2.32	0.02	2.75	0.05	3.88												
28	7.20	15.5	310	330	0.39	0.179		0.287	0.046	0.01	0.063	0.01		7.70	0.42	310	145	0.01	0.015	0.64	2.02	0.01	1.59	0.09	1.52	pass	pass										
29	7.10	14.6	316	342	0.61	0.169		0.309	0.041	0.01	0.055	0.01		7.60	0.41	320	140	0.01	0.019	0.77	2.00	0.01	1.84	0.06	3.46												
30	7.20	14.5	320	340	0.37	0.121		0.288	0.006	0.01	0.076	0.01		7.10	0.30	338	142	0.01	0.007	0.76	1.84	0.01	1.91	0.05	3.22												
31	6.90	14.4	325	350	0.42	0.165		0.309	0.031	0.01	0.069	0.36		7.60	0.31	310	100	0.01	0.008	0.55	1.97	0.01	1.70	0.10	3.37												
Ave.	7.18	14.8	323	340	0.70	0.195	#DM01	0.329	0.043	0.01	0.045	0.29	#####	7.59	0.39	308	121	0.01	0.014	0.69	2.16	0.01	2.41	0.07	3.13	#DM01	#DM01	#DM01	#DM01								
Max	7.60	15.7	385	385	3.34	0.330	0.00	0.590	0.067	0.02	0.098	0.44	0	0	0	0	0	0	0.96	2.56	0.02	4.30	0.10	3.88	0.00	0.00	0.00	0.00	0.00	0.00							
Min	6.90	14.2	300	300	0.36	0.121	0.00	0.00	0.260	0.006	0.01	0.010	0.01	0	0	0	0	0	0.04	1.84	0.01	0.75	0.10	3.03	1.10	0.00	0.00	0.00	0.00	0.00							
Remarks:																																					
Lagoon Effluent Tests		pH	Temp °C	T Chlor	Mn mg/L	Fe mg/L	Chloride mg/L	TSS mg/L	Distribution Stability Tests										pH	Temp °C	Alkalinity mg/L as CaCO3	Calcium mg/L	Chloride mg/L	Sulfate mg/L													
Monthly									Every Two Weeks																												
Date		7/20/2023	7.7	23.2	0.05	0.232	0.04	200.8	7.2											7.5	19.6	430	280	49	57												
Date																																					
Date																																					

