

Monthly Operating Report

September:2023



So. Sangamon
Water Commission
October 16th, 2023

SSWC

9199 Buckhart Rd Rochester IL 62563

TABLE OF CONTENTS

SECTION	PAGE NO.
Executive Summary.....	ES-1
1. SAFETY	1-1
1.1 Safety Training	1-1
1.2 Lost time Accidents	1-1
1.3 Safety Audit	1-1
1.4 Miscellaneous Safety.....	1-1
2. COMPLIANCE, FLOWS AND LOADINGS	2-2
2.1 Compliance	2-2
2.2 Influent flows and loadings	2-2
2.3 Effluent Concentrations	2-2
2.4 Lagoon Discharge Concentrations	2-4
3. OPERATIONS.....	3-1
3.1 Events impacting operations	3-1
3.2 Emergency & Service calls.....	3-1
3.3 Emergency Call-outs	3-1
3.4 Customer Inquiries	3-1
4. MAINTENANCE AND REPAIR.....	4-8
4.1 Preventative and predictive maintenance.....	4-8
4.2 Corrective repairs	4-8
5. PROJECT MANAGEMENT & SUPPORT.....	5-1
5.1 Staffing & Training	5-1
5.2 Corporate Support.....	5.2
5.3 Budget	5-3
6. CAPITAL PLANNING	6-1
6.1 Approved CIP Projects Current status.....	6-1
6.2 Draft Capital Improvement Plan	6-1

LIST OF TABLES

TABLE	PAGE NO.
Table 2.2 Influent Concentrations and Flow.....	2-2
Table 2.3 Finished Water Quality.....	2-2
Table 2.4 Weekly Grab Sample Analysis Results.....	2-4
Table 4.1 Budget Table.....	5-3

EXECUTIVE SUMMARY

Safety. Safety is the number one priority at South Sangamon. We have instituted a monthly safety meeting for operations staff at the plant. There were no lost time accidents in the month of September 2023.

Compliance. The finished water quality was within regulatory limits and all reporting and sampling requirements were met for the month. A copy of the Operations Report submitted to the Illinois Environmental Protection Agency is available at www.sswc.us

During the month of September 2023, the plant pumped 49.371 million gallons from the well field and 44.449 million gallons of finished water. This is 4.25 million gallons more than September 2022.

The SSWC plant has been removed from Critical Review status.

Operations. There was 0 emergency call-outs for the month. There were numerous customer inquiry for the month.

Maintenance and Repair. For the month of September 2023, there were 30 inspections, 3 preventative and multiple corrective maintenance activity completed. There was 4 repair activities performed .

Budget. Passed at April 17th 2023 meeting.

Capital Planning.

Chatham emergency interconnect

Onsite fuel storage tanks

Detention Tank

Well #11

1. SAFETY

1.1 SAFETY TRAINING

At South Sangamon we strive to provide a safe working environment for all employees. This is accomplished with daily safety meetings and open communication.

1.2 LOST TIME ACCIDENTS

There were 0 lost time accidents in the month of September 2023.

1.3 SAFETY AUDIT

No safety audits to date.

1.4 MISCELLANEOUS SAFETY

No notable safety issues

2. COMPLIANCE, FLOWS AND LOADINGS

2.1 COMPLIANCE

The finished water quality was within regulatory limits and all Bacteriological testing was completed for the month of September. A copy of the Operations Report to the Illinois Environmental Protection Agency (IEPA) is available on the SSWC website.

2.2 INFLUENT FLOWS AND LOADINGS

The total gallons pumped from the well field were 49.371 MG. The influent parameters were all within the normal range.

The influent flow and loadings are summarized below in Table 2.2

Table 2.2 Influent Concentrations and Flow

	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Well Flow Gals (MGD)
Max.	7.3	16.4	1.46	.216	-	365	320	1.955
Min.	7.1	14.2	.19	.125	-	340	118	1.356
Avg.	7.2	15.1	.54	.178	-	354	308	1.646
Total	-	-	-	-	-	-	-	49.371

2.3 EFFLUENT CONCENTRATIONS

The facility filtered 44.449 MG during the month with a daily average of 1.482 MG and a min/max 1.124/ 2.003 MG.

Table 2.3 Finished Water Quality

	Free CL2	Total CL2	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Phosphate
Max.	2.88	4.46	7.9		0.02	0.044	.99	240	358	2.39
Min.	0.05	3.19	7.6		0.01	0.006	0.60	100	310	1.67
Avg.	0.25	3.58	7.7		0.01	0.018	0.81	129	319	1.96
MCL	-	-	-	-	1.00	-	4.00	-	-	-
SMCL	-	-	-	-	0.30	0.050	2.00	-	-	-

Finished Water Flow Comparison for FY 2022-23

Time Period	22-23	21-22	20-21
Oct 2022- Sept-2023	426,359,500	412,316,376	418,888,785
Increase for the same period last year		14 MG	-.6.6 MG

FINISHED WATER PUMPING HISTORY						
	2022-23	2021-22	2020-21	2019-20	2018-19	2017-18
Oct	29,576,287	34,918,955	34,597,739	30,769,238	30,353,482	33,506,605
Nov	35,563,717	31,181,005	32,325,040	30,877,400	30,464,000	28,617,333
Dec	30,450,255	31,391,459	31,582,311	29,703,954	31,930,000	28,808,037
Jan	37,721,005	32,322,270	31,456,987	30,073,516	28,823,375	30,556,824
Feb	33,481,076	32,451,653	30,638,842	28,797,693	28,625,431	25,617,914
Mar	36,781,261	33,909,417	33,633,244	30,339,298	31,237,000	28,217,699
Apr	36,832,617	31,991,050	33,214,211	31,542,650	28,418,249	27,110,578
May	43,484,155	37,459,417	35,932,776	34,673,848	33,045,927	33,304,196
June	22,455,176	38,496,145	37,616,256	17,414,377	33,460,303	34,040,000
July	41,565,811	38,861,790	39,001,640	44,237,066	23,742,374	41,178,722
Aug	39,770,720	36,977,913	39,953,900	39,638,063	25,018,633	35,176,238
Sept	38,677,420	32,355,302	38,935,839	38,674,095	34,234,782	34,754,000
	-----	-----	-----	-----	-----	-----
Totals	426,359,500	412,316,376	418,888,785	386,741,198	359,353,556	380,888,146
Avg	1.17 MGD	1.13 MGD	1.15 MGD	1.06 MGD	.982 MGD	1.04 MGD

2.4 LAGOON DISCHARGE CONCENTRATIONS

The results for the NPDES lagoon discharge permit are summarized below.

Table 2.4 Weekly Grab Sample Analysis Results

Lagoon Effluent Results						
Date	Fe (mg/l)	Mn (mg/l)	Chloride (mg/l)	Cl ² (mg/l)	pH (S.U.)	TSS (mg/l)
September 18th,2023						
Minimum	.31	.02	466.5	.02	7.7	16
Maximum	.31	.02	466.5	.02	7.7	16
Average	.31	.02	466.5	.02	7.7	16
Monthly Avg Limit	2.000	1.000				15
Daily Limit	4.000	2.000	500	0.05	6.0-9.0	30

The Chloride sample for the month, performed by the Springfield Metropolitan Sanitary District, was below 30,000 mg/l for the month of September 2023. The limit for chloride discharge to the sanitary district is 30,000 mg/L.

3. OPERATIONS

3.1 EVENTS IMPACTING OPERATIONS

There were over 100 incident that impacted the operation of the plant.

Backwash low flow alarms

Ion exchange alarm

Westech filters comm loss

Power surge

Power Sag

Power Outages

Ion Exchange Brine Pump

Well comm loss Alarm

3.2 EMERGENCY & SERVICE CALLS

Service Calls:

- There was 0 emergency call out for the month.

3.3 EMERGENCY CALL-OUTS

There was 0 emergency call out for the month.

3.4 CUSTOMER INQUIRIES

There were numerous customer inquiries.

OTHER WORK PERFORMED

Inspected distribution mains

Inspected booster station

Customer service

Air Compressor research

SCADA programming

New Berlin Booster station trouble shooting

Cell Transmitter Installation

Tractor Maintenance

Well #11 Raw main Locate



New compressor has arrived on site



Pressure air tank that arrived last month has been temporarily installed until the rest of the system is installed.



The new air drier for the air control system

4. MAINTENANCE AND REPAIR

4.1 PREVENTATIVE AND PREDICTIVE MAINTENANCE

For the month of September 2023, there were 30 inspections, 3 preventative and multiple corrective maintenance activity completed.

4.2 CORRECTIVE REPAIR AND MAINTENANCE

Pulling and cleaning pre filters on all 3 filter trains on weekly basis

CIP train 1,2 and 3

Purged air control system

Air Compressor service

Raw water line flushing

Detention tank flush

Flushing Air Lines

Maintenance of New Berlin Booster Station

Meter Transmitter Replacement

Unloading New Compressor

Unloading New Air Drier

Air compressor Repar

5. PROJECT MANAGEMENT & SUPPORT

5.1 STAFFING & TRAINING

- Staff member training has been continuous and ongoing.
- Operator and Asst. Operator have been studying for EPA licensing test.

5.2 OPERATIONAL SUPPORT

The following individuals, either on-site or remotely, provided assistance in operation and/or maintenance of the plant during the month of September 2023.

- Kevin Canham
- Stephen Bivin
- Katie Krall
- Dan (SCADAware)
- Joe Lee Electric
- Kevin Garmin (SCADAware)

5.3 BUDGET

Table 5.3 Operating Budget

Table 5.3 Budget Table

Budget Table was removed: see clerks report

6. CAPITAL PLANNING

6.1 APPROVED CIP PROJECTS CURRENT STATUS

Pigging project construction complete. Awaiting first pigging before completely releasing contractor.

The Chatham /South Sangamon emergency interconnect is progressing. There was a preconstruction meeting in February. Petersburg Plumbing has pushed back the construction start date.

Meter Project progressing, All meter bases and registers are on site. 17 cell meters have been installed.

Meco Engineering has provided us with initial plans for well #11

6.2 DRAFT CAPITAL IMPROVEMENT PLAN

The CIP is a planning document that includes all projects anticipated to exceed \$5,000 in cost over the next five years. The CIP is an ongoing process and will be refined from time to time as projects are completed and new issues are identified.

1. Second Torray filter train has been installed- completed
2. Onsite fuel storage tanks have arrived on site and pumps have been installed-completed
3. BOP CPU upgrade has been completed-completed
4. Second raw water detention tank
5. SSWC/Chatham interconnect
6. Well #11

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES

MONTHLY IRON REMOVAL AND ION EXCHANGE SOFTENING REPORT

South Sangamon Water Commission - IL 1670080
September 2023

Page 1 of 2

Date	Netter Filter Read	Hours	Pumping Totals			Chemicals Applied						UF Filters			Softeners			Regeneration					
			Raw	Well	UF	Plant	HS	Lagoon	Sodium Permanganate	Sodium Bisulfite BW	Sodium Hypochlorite	Ammonium Sulfate	Fluorosilicic Acid	Phosphate	Sodium Bisulfite Pond	Hours since previous backwash	Wash Water	Water Softened	Water Bypassed	Water	Water		
			Used	(Mgal)	(Mgal)	Filtrated	Water Pumped	Effluent	Amt	Amt	Amt	Amt	Amt	Amt	Amt	Bank#	(Mgal)	(Mgal)	(Mgal)	Gal.	Gal.		
1	7300	18.9	1,732	1,551	0.014	1,451	0.089	22	0.30	0.00	482	436	77	1.19	44	0.69	34	0.93	0	0.00	0.66	0.66	
2	7300	20.9	1,901	1,687	0.020	1,631	0.091	25	0.32	0.00	550	439	78	1.11	48	0.67	10	0.24	0	0.00	0.66	0.66	
3	7300	21.1	1,917	1,696	0.015	1,564	0.097	21	0.26	0.00	514	434	47	0.66	38	0.55	12	0.30	0	0.00	0.66	0.66	
4	7300	17.7	1,550	1,392	0.006	1,382	0.066	19	0.29	0.00	422	434	60	1.03	38	0.64	14	0.40	0	0.00	0.66	0.66	
5	7300	21.4	1,951	1,718	0.008	1,650	0.106	21	0.26	0.00	429	374	61	0.85	41	0.57	16	0.38	0	0.00	0.66	0.66	
6	7300	21.5	1,955	1,749	0.023	1,631	0.090	22	0.27	0.00	500	438	61	0.84	43	0.61	20	0.49	0	0.00	0.66	0.66	
7	7300	21.4	1,929	1,724	0.015	1,655	0.098	19	0.24	0.00	468	437	52	0.72	43	0.59	21	0.50	0	0.00	0.66	0.66	
8	7300	17.9	1,605	1,439	0.014	1,336	0.087	20	0.26	0.00	456	478	34	0.57	38	0.55	27	0.89	0	0.00	0.66	0.66	
9	7300	18.3	1,691	1,513	0.019	1,413	0.079	24	0.34	0.00	560	535	41	0.65	47	0.76	10	0.28	0	0.00	0.66	0.66	
10	7300	20.8	1,804	1,676	0.012	1,556	0.075	17	0.23	0.00	400	358	23	0.33	33	0.48	42	1.07	0	0.00	0.66	0.66	
11	7300	16.7	1,488	1,314	0.000	1,262	0.061	18	0.29	0.00	440	502	26	0.47	37	0.67	13	0.41	0	0.00	0.66	0.66	
12	7300	21.3	1,890	1,670	0.000	1,631	0.083	19	0.24	0.00	451	405	32	0.46	38	0.54	16	0.38	0	0.00	0.66	0.66	
13	7300	16.8	1,470	1,302	0.005	1,281	0.083	13	0.24	0.00	374	431	20	0.37	32	0.54	15	0.46	0	0.00	0.66	0.66	
14	7300	16.4	1,469	2,003	0.019	1,131	0.075	18	0.29	0.00	385	288	13	0.16	31	0.62	17	0.59	0	0.00	0.66	0.66	
15	7300	15.5	1,356	1,124	0.005	1,219	0.070	22	0.39	0.00	521	635	29	0.62	44	0.82	20	0.65	0	0.00	0.66	0.66	
16	7300	21.0	1,887	1,677	0.022	1,593	0.097	23	0.29	0.00	465	416	0	0.00	45	0.64	43	1.07	0	0.00	0.66	0.66	
17	7300	21.5	1,934	1,736	0.017	1,641	0.095	20	0.00	0.00	466	420	0	0.00	38	0.53	74	1.78	0	0.00	0.66	0.66	
18	7300	15.7	1,444	1,298	0.005	1,161	0.084	17	0.28	0.00	389	449	0	0.00	32	0.65	72	2.55	0	0.00	0.66	0.66	
19	7300	20.5	1,805	1,561	0.022	1,476	0.080	21	0.28	0.00	410	334	18	0.28	35	0.54	77	2.06	0	0.00	0.66	0.66	
20	7300	16.9	1,416	1,265	0.008	1,181	0.070	20	0.34	0.00	470	537	32	0.61	39	0.75	10	0.34	0	0.00	0.66	0.66	
21	7300	21.0	1,799	1,589	0.015	1,474	0.088	21	0.28	0.00	504	475	44	0.66	42	0.65	10	0.27	0	0.00	0.66	0.66	
22	7300	17.5	1,491	1,323	0.014	1,245	0.074	12	0.19	0.00	335	340	12	0.22	22	0.40	8	0.25	0	0.00	0.66	0.66	
23	7300	17.0	1,423	1,257	0.016	1,205	0.065	19	0.32	0.00	486	579	26	0.50	37	0.70	13	0.43	0	0.00	0.66	0.66	
24	7300	17.2	1,458	1,310	0.004	1,191	0.073	19	0.31	0.00	416	476	56	1.03	34	0.65	15	0.50	0	0.00	0.66	0.66	
25	7300	16.7	1,428	1,231	0.017	1,153	0.076	16	0.27	0.00	330	402	46	0.90	32	0.63	12	0.41	0	0.00	0.66	0.66	
26	7300	20.5	1,742	1,540	0.021	1,459	0.075	19	0.26	0.00	450	418	64	1.00	36	0.56	16	0.43	0	0.00	0.66	0.66	
27	7300	17.3	1,457	1,287	0.005	1,215	0.078	18	0.30	0.00	404	470	56	1.04	36	0.67	19	0.62	0	0.00	0.66	0.66	
28	7300	16.8	1,411	1,319	0.019	1,173	0.067	16	0.27	0.00	370	420	49	0.88	32	0.62	20	0.67	0	0.00	0.66	0.66	
Total	563.5	49,371	44,449	0,390	41,421	0,014	1,245	0,073	16	0,25	0,00	204	237	30	0,72	29	0,53	34	1,08	0	0,00	0,66	0,66
Ave.	18.8	1,646	1,442	0,013	1,381	0,080	19,3	0,080	0,00	470	405	0	#D/W/0	1,140	#D/W/0	791	#D/W/0	0	#D/W/0	0,66	#D/W/0	0,66	#D/W/0
Max	21.5	1,955	2,003	0,023	1,655	0,106	25,0	0,070	0	470	405	0	#D/W/0	78	#D/W/0	81	#D/W/0	0	#D/W/0	0,66	#D/W/0	0,66	#D/W/0
Min	15.5	1,356	1,124	0,000	1,116	0,061	12,0	0,070	0	470	405	0	#D/W/0	204	#D/W/0	22	#D/W/0	8	#D/W/0	0,66	#D/W/0	0,66	#D/W/0
1	1	20 % Sodium Permanganate	Pre-treater	Membrane Backwash	Type of Chlorine Used	Sodium Hypochlorite 12.5%	Fluoride Used	Hydrofluoric Acid 19% F	Chlorination														
2	2	40 % Bleach/Solution	Post-Soilener	Post-Soilener	Chlorine Analyzers Used:	Hach Cl 17 (2) & 5560sc	Fluoride Analyzer Used:	Hach 2200, SPADNS method															
3	3	12.5 % Sodium Hypochlorite Solution	Post-Soilener	Post-Soilener																			
4	4	20 % Ammonium Sulfate Solution	Post-Chemical Acid	Post-Chemical Acid																			
5	5	19 % Fluorostabilized Acid Solution	Post-Cleanwell	Post-Cleanwell																			
6	6	33 % Phosphate Solution	Lagoon Effluent	Lagoon Effluent																			
7	7	40 % Bleach/Solution																					

South Sangamon Water Commission September 2023 Monthly Operating Report

1	Identify all information in this report is complete and accurate to the best of my knowledge.	
2	Reported by:	Illinois Operator Certification ID: 25249899
3	Date:	10/13/2023
4	Date Bacterial Test:	9/19/2023

