



Monthly Operating Report

October:2025

So. Sangamon
Water Commission
November 17th, 2025

SSWC

9199 Buckhart Rd Rochester IL 62563

TABLE OF CONTENTS

SECTION	PAGE NO.
Executive Summary.....	ES-1
1. SAFETY	1-1
1.1 Safety Training	1-1
1.2 Lost time Accidents	1-1
1.3 Safety Audit	1-1
1.4 Miscellaneous Safety.....	1-1
2. COMPLIANCE, FLOWS AND LOADINGS	2-2
2.1 Compliance	2-2
2.2 Influent flows and loadings	2-2
2.3 Effluent Concentrations	2-2
2.4 Lagoon Discharge Concentrations	2-4
3. OPERATIONS.....	3-1
3.1 Events impacting operations	3-1
3.2 Emergency & Service calls	3-1
3.3 Emergency Call-outs	3-1
3.4 Customer Inquiries	3-1
4. MAINTENANCE AND REPAIR.....	4-6
4.1 Preventative and predictive maintenance.....	4-6
4.2 Corrective repairs	4-6
5. PROJECT MANAGEMENT & SUPPORT	5-1
5.1 Staffing & Training.....	5-1
5.2 Corporate Support.....	5-2
5.3 Budget.....	5-3
6. CAPITAL PLANNING	6-1
6.1 Approved CIP Projects Current status.....	6-1
6.2 Draft Capital Improvement Plan	6-1

LIST OF TABLES

TABLE	PAGE NO.
Table 2.2 Influent Concentrations and Flow.....	2-2
Table 2.3 Finished Water Quality.....	2-2
Table 2.4 Weekly Grab Sample Analysis Results.....	2-4
Table 4.1 Budget Table.....	5-3

EXECUTIVE SUMMARY

Safety. Safety is the number one priority at South Sangamon. We have instituted a monthly safety meeting for operations staff at the plant. There were no lost time accidents in the month of October 2025.

Compliance. The finished water quality was within regulatory limits and all reporting and sampling requirements were met for the month. A copy of the Operations Report submitted to the Illinois Environmental Protection Agency is available at www.sswc.us

During the month of October 2025, the plant pumped 48.937 million gallons from the well field and 40.1 million gallons of finished water. This is 3.185 million gallons more than October 2024.

The SSWC plant has been removed from Critical Review status.

Operations. There was 0 emergency call-outs for the month. There were numerous customer inquiry for the month.

Maintenance and Repair. For the month of October 2025, there were 31 inspections, 3 preventative and multiple corrective maintenance activity completed. There were 3 repair activities performed.

Budget. Passed at March 17th 2025 meeting.

Capital Planning.

Detention Tank

Well #12

1. SAFETY

1.1 SAFETY TRAINING

At South Sangamon we strive to provide a safe working environment for all employees. This is accomplished with daily safety meetings and open communication.

1.2 LOST TIME ACCIDENTS

There were 0 lost time accidents in the month of October 2025.

1.3 SAFETY AUDIT

No safety audits to date.

1.4 MISCELLANEOUS SAFETY

No notable safety issues

2. COMPLIANCE, FLOWS AND LOADINGS

2.1 COMPLIANCE

The finished water quality was within regulatory limits and all Bacteriological testing was completed for the month of October. A copy of the Operations Report to the Illinois Environmental Protection Agency (IEPA) is available on the SSWC website.

2.2 INFLUENT FLOWS AND LOADINGS

The total gallons pumped from the well field were 48.937 MG. The influent parameters were all within the normal range.

The influent flow and loadings are summarized below in Table 2.2

Table 2.2 Influent Concentrations and Flow								
	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Well Flow Gals (MGD).
Max.	7.4	16.3	1.34	.327	-	400	300	1.881
Min.	7.2	14.5	.36	.220	-	280	280	0.693
Avg.	7.31	15.3	.64	.279	-	374	289	1.579
Total	-	-	-	-	-	-	-	48.937

2.3 EFFLUENT CONCENTRATIONS

The facility filtered 43.473 MG during the month with a daily average of 1.402 MG and a min/max 1.141/1.645 MG.

Table 2.3 Finished Water Quality										
	Free CL2	Total CL2	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Phosphate
Max.	0.16	4.60	7.8		0.01	0.047	0.91	300	320	2.49
Min.	0.04	2.08	7.5		0.01	0.011	0.41	110	240	2.01
Avg.	0.10	2.93	7.68		0.01	0.026	0.74	177	286	2.20
MCL	-	-	-	-	1.00	-	4.00	-	-	-
SMCL	-	-	-	-	0.30	0.050	2.00	-	-	-

Finished Water Flow Comparison for FY 2025

Time Period	2024-25	2023-24	2022-23
Nov 2024-Oct 2025	412,145,583	414,997,165	429,516,437
Increase for the same period last year		-2.85 MG	-14.5 MG

FINISHED WATER PUMPING HISTORY						
	2024-25	2023 -24	2022-23	2021-22	2020-21	2019-20
Nov	28,768,567	30,061,570	35,563,717	31,181,005	32,325,040	30,877,400
Dec	32,675,158	31,818,986	30,450,255	31,391,459	31,582,311	29,703,954
Jan	33,741,476	33,807,516	37,721,005	32,322,270	31,456,987	30,073,516
Feb	29,167,378	29,777,768	33,481,076	32,451,653	30,638,842	28,797,693
Mar	31,913,792	31,222,925	36,781,261	33,909,417	33,633,244	30,339,298
Apr	31,328,823	31,707,537	36,832,617	31,991,050	33,214,211	31,542,650
May	36,216,393	36,629,959	43,484,155	37,459,417	35,932,776	34,673,848
June	36,297,369	40,285,085	22,455,176	38,496,145	37,616,256	17,414,377
July	33,897,659	38,944,142	41,565,811	38,861,790	39,001,640	44,237,066
Aug	43,119,702	38,576,284	39,770,720	36,977,913	39,953,900	39,638,063
Sept	37,181,554	37,258,390	38,677,420	32,355,302	38,935,839	38,674,095
Oct	37,837,812	34,907,003	32,733,224	29,576,287	34,918,955	34,597,739
	-----	-----	-----	-----	-----	-----
Totals	412.145.583	414,997,165	429,516,437	406,973,708	419,210,001	390,569,699
Avg	1.13 MGD	1.14 MGD	1.18 MGD	1.11 MGD	1.15 MGD	1.07 MGD

2.4 LAGOON DISCHARGE CONCENTRATIONS

The results for the NPDES lagoon discharge permit are summarized below.

Table 2.4 Weekly Grab Sample Analysis Results

Lagoon Effluent Results						
Date	Fe (mg/l)	Mn (mg/l)	Chloride (mg/l)	Cl² (mg/l)	pH (S.U.)	TSS (mg/l)
October 8 th , 2025						
Minimum	.16	.274	760	.002	7.5	<4
Maximum	.16	.274	760	.002	7.5	<4
Average	.16	.274	760	.002	7.5	<4
Monthly Avg Limit	2.000	1.000				15
Daily Limit	4.000	2.000	500	0.05	6.0-9.0	30

The Chloride sample for the month, performed by the Springfield Metropolitan Sanitary District, was below 30,000 mg/l for the month of October 2025. The limit for chloride discharge to the sanitary district is 30,000 mg/L. SSWC had a Chloride excursion in the month of October. SSWC has received a notice of violation for our discharge limits. Negotiations with the EPA to change our discharge limit for Chloride are underway.

3. OPERATIONS

3.1 EVENTS IMPACTING OPERATIONS

There were over 50 incident that impacted the operation of the plant.

Power surge

Power Sag

Ion Exchange Troubleshooting

Comm Loss Alarms

Well #8

BOP Communications with HMI

HSP VFD Install

Comm Card Failure

3.2 EMERGENCY & SERVICE CALLS

Service Calls:

- There was 0 emergency call outs for the month.

3.3 EMERGENCY CALL-OUTS

There was 0 emergency call out for the month.

3.4 CUSTOMER INQUIRIE

There were numerous customer inquiries.

OTHER WORK PERFORMED

Inspected distribution mains

Inspected booster station

SCADA programming

Softener Repairs

Filter Train Repair

Lightning Strike Repair

Insurance Claim

Well #8 cleaning and repair



The IIDNR came out for a CREP survey and noticed agricultural encroachment on SSWC land. I survey was performed for the well # 11 construction. MECOs survey crew came back out and reset survey marks.



Well meters were ordered to repair damage done from lightning strike. The wrong size meters were shipped the first time.



The new 6” meters have arrived and installation has been scheduled



Well 8s VFD was damaged from the lightning strike. After its replacement it was found the motor was damaged as well. The pump and motor were replaced and a cleaning was performed at the same time.

4. MAINTENANCE AND REPAIR

4.1 PREVENTATIVE AND PREDICTIVE MAINTENANCE

For the month of October 2025, there were 31 inspections, 3 preventative and multiple corrective maintenance activities completed.

4.2 CORRECTIVE REPAIR AND MAINTENANCE

Pulling and cleaning pre filters on all 3 filter trains on weekly basis

CIP train 1,2 and 3

Purged air control system

Raw water line flushing

Detention tank flush

Flushing Air Lines

Maintenance of New Berlin Booster Station

Air compressor Maintenance

Well #8 repair and cleaning

Brine Solution Sampling

HSP #3 VFD Install

BOP Repair

5. PROJECT MANAGEMENT & SUPPORT

5.1 STAFFING & TRAINING

- Staff member training has been continuous and ongoing.
- Operator and Asst. Operator have been studying for EPA licensing test.

5.2 OPERATIONAL SUPPORT

The following individuals, either on-site or remotely, provided assistance in operation and/or maintenance of the plant during the month of October 2025.

- Kevin Canham
- Stephen Bivin
- Katie Krall
- Dan (SCADAware)
- Joe Lee Electric
- Kevin Garmin (SCADAware)
- Brotke Well and Pump

5.3 BUDGET

Table 5.3 Operating Budget

Table 5.3 Budget Table

Budget Table was removed: see clerks report

6. CAPITAL PLANNING

6.1 APPROVED CIP PROJECTS CURRENT STATUS

Pigging project construction complete. First pig was scheduled. Issues were discovered. First pig was attempted but was not able to be performed.

The Chatham /South Sangamon emergency interconnect construction is complete. After many failed attempts; start has been completed.

Meter Project progressing, All meter bases and registers are on site. all cell meters have been installed.

Operating permit for well #11 was denied and resubmitted with requested materials.

SCADAware has completed the radio comms for well #11. Unable to test until we receive the operating permit.

6.2 DRAFT CAPITAL IMPROVEMENT PLAN

The CIP is a planning document that includes all projects anticipated to exceed \$5,000 in cost over the next five years. The CIP is an ongoing process and will be refined from time to time as projects are completed and new issues are identified.

1. Onsite fuel storage tanks have arrived on site and pumps have been installed-completed
2. BOP CPU upgrade-completed
3. Second raw water detention tank
4. SSWC/Chatham interconnect-completed
5. Well #11-construction complete
6. SCADA computer upgrade are complete
7. Well #12

Pumping Totals										Chemicals Applied										UF Filters										Softeners										Regeneration	
Date	Time	Raw Well	UF Filtered (Mgal)	Plant Water (Mgal)	HS Pumpage (Mgal)	Lagoon Effluent (Mgal)	Sodium Permanganate		Sodium Bisulfite BW		Sodium Hypochlorite		Ammonium Sulfate		Fluorosilicic Acid		Phosphate		Sodium Bisulfite Pond		Hours since previous backwash			Wash Water (Mgal)	Softened Water (Mgal)	Bypassed Water (Mgal)	Each day indicate total number of hours since previous regeneration.				Salt Used (lbs)	Washed Gal									
							Amnt Used (lbs)	Calc (mg/as)	Amnt Used (lbs)	Calc (mg/as)	Amnt Used (lbs)	Calc (mg/as)	Amnt Used (lbs)	Calc (mg/as)	Amnt Used (lbs)	Calc (mg/as)	Amnt Used (lbs)	Calc (mg/as)	Bank #	1	2	3	4																		
1	7:00	217	1878	1645	0.009	1.518	0.095	63	0.80	0	0.00	548	4.99	3	0.04	45	0.68	9	0.23	0	0.00	0.66	0.66	0.66	0.66	0.76	1.075	0.570	60.0	74.0	51.0	40.0	9124	43400							
2	7:00	199	1656	1468	0.012	1.332	0.072	54	0.78	0	0.00	488	4.98	4	0.07	36	0.62	12	0.36	0	0.00	0.66	0.66	0.66	0.66	0.66	0.959	0.509	34.0	28.0	20.0	6843	32550								
3	7:00	178	1489	1319	0.013	1.272	0.080	53	0.85	0	0.00	482	5.48	7	0.13	38	0.71	13	0.42	0	0.00	0.66	0.66	0.66	0.66	0.66	0.862	0.457	37.0	24.0	24.0	6843	32550								
4	7:00	215	1830	1615	0.009	1.481	0.083	59	0.77	0	0.00	564	5.23	3	0.04	42	0.65	16	0.43	0	0.00	0.66	0.66	0.66	0.66	0.66	1.056	0.559	28.0	35.0	24.0	9124	43400								
5	7:00	220	1846	1668	0.009	1.567	0.088	53	0.89	0	0.00	510	4.76	2	0.03	39	0.57	18	0.45	0	0.00	0.66	0.66	0.66	0.66	0.66	1.050	0.586	31.0	25.0	24.0	6843	32550								
6	7:00	207	1740	1512	0.011	1.423	0.088	46	0.63	0	0.00	458	4.54	6	0.10	37	0.59	21	0.58	0	0.00	0.66	0.66	0.66	0.66	0.66	0.988	0.524	31.0	36.0	24.0	250	9124	43400							
7	7:00	218	1793	1556	0.018	1.431	0.086	32	0.43	0	0.00	578	5.57	7	0.11	44	0.70	75	2.07	0	0.00	0.66	0.66	0.66	0.66	0.66	1.017	0.539	30.0	24.0	25.0	6843	32550								
8	7:00	205	1706	1534	0.010	1.454	0.073	49	0.69	0	0.00	386	3.58	4	0.06	28	0.44	68	1.85	0	0.00	0.66	0.66	0.66	0.66	0.66	1.003	0.531	40.0	28.0	28.0	6843	32550								
9	7:00	199	1620	1400	0.006	1.355	0.080	63	0.93	0	0.00	498	5.22	0	0.00	39	0.66	5	0.15	0	0.00	0.66	0.66	0.66	0.66	0.66	0.915	0.485	34.0	39.0	28.0	6843	32550								
10	7:00	192	1551	1369	0.010	1.204	0.063	51	0.79	0	0.00	400	4.38	2	0.04	31	0.59	11	0.36	0	0.00	0.66	0.66	0.66	0.66	0.66	0.895	0.474	28.0	28.0	28.0	6843	32550								
11	7:00	204	1616	1412	0.005	1.404	0.077	57	0.85	0	0.00	466	4.91	3	0.05	35	0.57	11	0.31	0	0.00	0.66	0.66	0.66	0.66	0.66	0.923	0.489	38.0	43.0	43.0	6843	32550								
12	7:00	201	1704	1501	0.003	1.378	0.090	56	0.79	0	0.00	472	4.71	3	0.05	36	0.60	22	0.63	0	0.00	0.66	0.66	0.66	0.66	0.66	0.915	0.520	43.0	56.0	36.0	6843	32550								
13	7:00	191	1615	1449	0.010	1.261	0.076	82	1.22	0	0.00	542	5.61	4	0.07	41	0.73	13	0.40	0	0.00	0.66	0.66	0.66	0.66	0.66	0.947	0.502	40.0	38.0	14.0	6843	32550								
14	7:00	220	1881	1641	0.011	1.550	0.083	63	0.80	0	0.00	554	5.06	10	0.15	44	0.65	17	0.43	0	0.00	0.66	0.66	0.66	0.66	0.66	0.979	1.073	0.588	34.0	41.0	28.0	6843	32550							
15	7:00	192	1644	1433	0.010	1.268	0.088	49	0.71	0	0.00	440	4.60	6	0.10	33	0.58	15	0.46	0	0.00	0.66	0.66	0.66	0.66	0.66	0.937	0.496	33.0	24.0	28.0	6843	32550								
16	7:00	183	1552	1383	0.012	1.278	0.069	44	0.68	0	0.00	414	4.49	5	0.09	31	0.55	26	0.80	0	0.00	0.66	0.66	0.66	0.66	0.66	0.904	0.479	49.0	23.0	29.0	6843	32550								
17	7:00	87	693	1174	0.000	0.661	0.067	48	1.66	0	0.00	434	5.54	0	0.00	36	1.24	5	0.30	0	0.00	0.66	0.66	0.66	0.66	0.66	0.767	0.407	44.0	29.0	33.0	6843	32550								
18	7:00	220	1644	1392	0.010	1.291	0.063	43	0.63	0	0.00	416	4.48	6	0.10	32	0.56	8	0.25	0	0.00	0.66	0.66	0.66	0.66	0.66	0.949	0.488	44.0	22.0	29.0	6843	32550								
19	7:00	198	1547	1359	0.009	1.289	0.078	44	0.68	0	0.00	426	4.70	5	0.09	35	0.61	10	0.30	0	0.00	0.66	0.66	0.66	0.66	0.66	0.910	0.482	29.0	31.0	6843	32550									
20	7:00	184	1432	1266	0.010	1.247	0.069	42	0.70	0	0.00	480	5.68	0	0.00	37	0.68	10	0.32	0	0.00	0.66	0.66	0.66	0.66	0.66	0.927	0.439	37.0	47.0	23.0	6843	32550								
21	7:00	193	1624	1408	0.008	1.261	0.070	6	0.09	0	0.00	388	3.91	1	0.02	28	0.51	9	0.28	0	0.00	0.66	0.66	0.66	0.66	0.66	0.921	0.488	15.0	26.0	28.0	6843	32550								
22	7:00	182	1530	1362	0.007	1.264	0.080	13	0.20	0	0.00	348	3.83	-2	-0.04	32	0.58	10	0.31	0	0.00	0.66	0.66	0.66	0.66	0.66	0.890	0.472	34.0	37.0	37.0	6843	32550								
23	7:00	174	1423	1224	0.012	1.158	0.063	57	0.68	0	0.00	432	5.29	0	0.00	32	0.63	10	0.34	0	0.00	0.66	0.66	0.66	0.66	0.66	0.853	0.800	0.424	37.0	31.0	4562	21700								
24	7:00	1472	1315	0.003	1.173	0.084	54	0.92	0	0.00	414	4.72	3	0.05	32	0.62	12	0.40	0	0.00	0.66	0.66	0.66	0.66	0.66	0.700	0.859	0.456	41.0	42.0	33.0	6843	32550								
25	7:00	186	1474	1228	0.005	1.234	0.068	51	0.83	0	0.00	416	5.08	2	0.04	30	0.55	15	0.48	0	0.00	0.66	0.66	0.66	0.66	0.66	0.803	0.425	32.0	26.0	40.0	6843	32550								
26	7:00	181	1470	1280	0.011	1.143	0.078	57	0.93	0	0.00	462	5.41	2	0.04	34	0.68	61	2.11	0	0.00	0.66	0.66	0.66	0.66	0.66	0.837	0.443	48.0	23.0	46.0	6843	32550								
27	7:00	191	1537	1360	0.003	1.284	0.075	62	0.97	0	0.00	534	5.88	1	0.02	32	0.57	105	3.24	0	0.00	0.66	0.66	0.66	0.66	0.66	0.889	0.471	42.0	23.0	46.0	6843	32550								
28	7:00	193	1576	1360	0.010	1.267	0.078	44	0.67	0	0.00	346	3.81	2	0.04	28	0.50	7	0.22	0	0.00	0.66	0.66	0.66	0.66	0.66	0.889	0.471	52.0	28.0	45.0	6843	32550								
29	7:00	164	1365	1214	0.006	1.116	0.068	59	1.04	0	0.00	498	6.15	7	0.14	40	0.82	8	0.28	0	0.00	0.66	0.66	0.66	0.66	0.66	0.793	0.421	35.0	43.0	45.0	6843	32550								
30	7:00	206	1684	1546	0.007	1.366	0.092	42	0.60	0	0.00	360	3.49	2	0.03	27	0.44	7	0.20	0	0.00	0.66	0.66	0.66	0.66	0.66	1.010	0.536	39.0	47.0	30.0	6843	32550								
31	7:00	176	1405	1141	0.011	1.159	0.056	54	0.92	0	0.00	506	6.85	3	0.06	37	0.73	9	0.31	0	0.00	0.66	0.66	0.66	0.66	0.66	0.851	0.746	0.395	65.0	28.0	22.0	14.0	2281	10850						
Total																																									
Ave.																																									
Max																																									
Min																																									

CHLORINATION		FLUORIDATION	
1	20% Sodium Permanganate	Post-erator	
2	40% Bisulfite Solution	Membrane Backwash	
3	12.5% Sodium Hypochlorite Solution	Post Softener	
4	20% Ammonium Sulfate Solution	Post Cleanwell	
5	10% Fluorosilicic Acid Solution	Post Cleanwell	
6	33% Phosphate Solution	Post Cleanwell	
7	40% Bisulfite Solution		

