



Monthly Operating Report

July:2026



So. Sangamon
Water Commission
August 17th, 2026



SSWC

9199 Buckhart Rd Rochester IL 62563

TABLE OF CONTENTS

SECTION	PAGE NO.
Executive Summary.....	ES-1
1. SAFETY	1-1
1.1 Safety Training	1-1
1.2 Lost time Accidents	1-1
1.3 Safety Audit	1-1
1.4 Miscellaneous Safety.....	1-1
2. COMPLIANCE, FLOWS AND LOADINGS	2-2
2.1 Compliance	2-2
2.2 Influent flows and loadings	2-2
2.3 Effluent Concentrations	2-2
2.4 Lagoon Discharge Concentrations	2-4
3. OPERATIONS.....	3-1
3.1 Events impacting operations	3-1
3.2 Emergency & Service calls	3-1
3.3 Emergency Call-outs	3-1
3.4 Customer Inquiries	3-1
4. MAINTENANCE AND REPAIR.....	4-5
4.1 Preventative and predictive maintenance.....	4-5
4.2 Corrective repairs	4-5
5. PROJECT MANAGEMENT & SUPPORT	5-1
5.1 Staffing & Training.....	5-1
5.2 Corporate Support.....	5-2
5.3 Budget	5-3
6. CAPITAL PLANNING	6-1
6.1 Approved CIP Projects Current status.....	6-1
6.2 Draft Capital Improvement Plan	6-1

LIST OF TABLES

TABLE	PAGE NO.
Table 2.2 Influent Concentrations and Flow.....	2-2
Table 2.3 Finished Water Quality.....	2-2
Table 2.4 Weekly Grab Sample Analysis Results.....	2-4
Table 4.1 Budget Table.....	5-3

EXECUTIVE SUMMARY

Safety. Safety is the number one priority at South Sangamon. We have instituted a monthly safety meeting for operations staff at the plant. There were no lost time accidents in the month of July 2026.

Compliance. The finished water quality was within regulatory limits and all reporting and sampling requirements were met for the month. A copy of the Operations Report submitted to the Illinois Environmental Protection Agency is available at www.sswc.us

During the month of July 2026, the plant pumped 32.444 million gallons from the well field and 29.120 million gallons of finished water. This is 6.5 million gallons less than July 2025.

The SSWC plant has been removed from Critical Review status.

Operations. There was 1 emergency call-outs for the month. There were numerous customer inquiry for the month.

Maintenance and Repair. For the month of July 2026, there were 31 inspections, 3 preventative and multiple corrective maintenance activity completed. There were Numerous repair activities performed.

Budget. Passed at March 16th 2026 meeting.

Capital Planning.

Detention Tank

Well #12

1. SAFETY

1.1 SAFETY TRAINING

At South Sangamon we strive to provide a safe working environment for all employees. This is accomplished with daily safety meetings and open communication.

1.2 LOST TIME ACCIDENTS

There were 0 lost time accidents in the month of July 2026.

1.3 SAFETY AUDIT

No safety audits to date.

1.4 MISCELLANEOUS SAFETY

No notable safety issues

2. COMPLIANCE, FLOWS AND LOADINGS

2.1 COMPLIANCE

The finished water quality was within regulatory limits and all Bacteriological testing was completed for the month of July. A copy of the Operations Report to the Illinois Environmental Protection Agency (IEPA) is available on the SSWC website.

The EPA has mandated that SSWC deliver a public notification for failure to sample for Chlordane. Upon review, Chlordane had been sampled for and not detected. The public notification requirement had already been issued so the requirement to notify stands. SSWC has included the notification in its CCR.

2.2 INFLUENT FLOWS AND LOADINGS

The total gallons pumped from the well field were 32.444 MG. The influent parameters were all within the normal range.

The influent flow and loadings are summarized below in Table 2.2

Table 2.2 Influent Concentrations and Flow								
	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Well Flow Gals (MGD).
Max.	7.50	16.9	5.82	1.360	-	394	300	1.681
Min.	7.1	14.4	.47	.180	-	356	256	0.050
Avg.	7.3	16.3	.96	.209	-	386	283	1.047
Total	-	-	-	-	-	-	-	32.444

2.3 EFFLUENT CONCENTRATIONS

The facility filtered 30.873 MG during the month with a daily average of .996 MG and a min/max..030/ 1.579MG.

Table 2.3 Finished Water Quality										
	Free CL2	Total CL2	pH	Temp	Iron	Manganese	Fluoride	Hardness	Alkalinity	Phosphate
Max.	1.02	3.72	8.0		0.03	0.060	.99	210	292	2.63
Min.	0.06	1.37	7.2		0.01	0.001	0.32	70	220	.45
Avg.	0.12	3.11	7.66		0.02	0.025	0.70	129	278	2.04
MCL	-	-	-	-	1.00	-	4.00	-	-	-
SMCL	-	-	-	-	0.30	0.050	2.00	-	-	-

Finished Water Flow Comparison for FY 2025-26

Time Period	2025-26	2024-25	2023-24
Aug 2025-July 2026	376,160,081	404,748,292	415,436,852
Increase for the same period last year		-28 MG	10.7MG

FINISHED WATER PUMPING HISTORY						
	2025-26	2024-25	2023-24	2022-23	2021-22	2020-21
Aug	43,119,702	38,576,284	39,770,720	36,977,913	39,953,900	39,638,063
Sept	37,181,554	37,258,390	38,677,420	32,355,302	38,935,839	38,674,095
Oct	37,837,812	34,907,003	32,733,224	29,576,287	34,918,955	34,597,739
Nov	32,837,339	28,768,567	30,061,570	35,563,717	31,181,005	32,325,040
Dec	35,792,889	32,675,158	31,818,986	30,450,255	31,391,459	31,582,311
Jan	34,401,288	33,741,476	33,807,516	37,721,005	32,322,270	31,456,987
Feb	30,485,408	29,167,378	29,777,768	33,481,076	32,451,653	30,638,842
Mar	32,732,477	31,913,792	31,222,925	36,781,261	33,909,417	33,633,244
Apr	29,072,947	31,328,823	31,707,537	36,832,617	31,991,050	33,214,211
May	37,243,452	36,216,393	36,629,959	43,484,155	37,459,417	35,932,776
June	25,455,213	36,297,369	40,285,085	22,455,176	38,496,145	37,616,256
July	27,116,020	33,897,659	38,944,142	41,565,811	38,861,790	39,001,640
	-----	-----	-----	-----	-----	-----
Totals	376,160,081	404,748,292	415,436,852	417,244,575	421,872,900	418,311,204
Avg	1.03 MGD	1.11 MGD	1.14 MGD	1.14 MGD	1.15 MGD	1.15 MGD

2.4 LAGOON DISCHARGE CONCENTRATIONS

The results for the NPDES lagoon discharge permit are summarized below.

Table 2.4 Weekly Grab Sample Analysis Results

Lagoon Effluent Results						
Date	Fe (mg/l)	Mn (mg/l)	Chloride (mg/l)	Cl ² (mg/l)	pH (S.U.)	TSS (mg/l)
July 16 th 2026	.11	.134	207.3	.03	7.1	<4
Minimum	.11	.134	207.3	.03	7.1	<4
Maximum	.11	.134	207.3	.03	7.1	<4
Average	.11	.134	207.3	.03	7.1	<4
Monthly Avg Limit	2.000	1.000				15
Daily Limit	4.000	2.000	500	0.05	6.0-9.0	30

The Chloride sample for the month was unable to be drawn as the outfall was submerged

The limit for chloride discharge to the sanitary district is 30,000 mg/L. SSWC received a notice of violation for our discharge limits. A plan has been implemented to assure compliance in the future.

SSWC has entered into a Compliance Commitment Agreement with the IEPA due to a Manganese excursion at our outfall. A plan has been initiated to remove solids from the lagoon basins. SSWC is awaiting sample results before moving on to the next phase of the plan.

3. OPERATIONS

3.1 EVENTS IMPACTING OPERATIONS

There were over 50 incident that impacted the operation of the plant.

Power surge

Power Sag

Power Outage

Ion Exchange Troubleshooting

Expansion Joint Failure

Groove Lock Connection Failure

Air Line Leak

Storm Damage

Filter Train Backwash Drain Line Damage

3.2 EMERGENCY & SERVICE CALLS

Service Calls:

- There was 0 emergency call outs for the month.

3.3 EMERGENCY CALL-OUTS

There was 1 emergency call out for the month.

3.4 CUSTOMER INQUIRIE

There were numerous customer inquiries.

OTHER WORK PERFORMED

Inspected distribution mains

Inspected booster station

SCADA programming

Softener Repairs

Insurance Claim

Scada repair



The backwash drain line for filter trains 1 and 2 had a catastrophic failure. Repairs not able to be conducted until after July 4th weekend.



The Monday after July 4th, the repairs were made and trains 1 and 2 were put back in service.



The check valves for the lagoon effluent have arrived on site.

4. MAINTENANCE AND REPAIR

4.1 PREVENTATIVE AND PREDICTIVE MAINTENANCE

For the month of July 2026, there were 31 inspections, 3 preventative and multiple corrective maintenance activities completed.

4.2 CORRECTIVE REPAIR AND MAINTENANCE

Pulling and cleaning pre filters on all 3 filter trains on weekly basis

CIP train 1,2 and 3

Purged air control system

Raw water line flushing

Detention tank flush

Flushing Air Lines

Maintenance of New Berlin Booster Station

Air compressor Maintenance

Brine Solution Sampling

Manual CIPs

Manual Maintenance Cleans

Filter Train Leak Repair

Softener Repair

Water Line Flushing

Backwash Drain Line repair

5. PROJECT MANAGEMENT & SUPPORT

5.1 STAFFING & TRAINING

- Staff member training has been continuous and ongoing.
- Operator and Asst. Operator have been studying for EPA licensing test.

5.2 OPERATIONAL SUPPORT

The following individuals, either on-site or remotely, provided assistance in operation and/or maintenance of the plant during the month of July 2026.

- Kevin Canham
- Stephen Bivin
- Katie Krall
- Dan (SCADAware)
- Joe Lee Electric
- Kevin Garmin (SCADAware)
- EL Pruitt

5.3 BUDGET

Table 5.3 Operating Budget

Table 5.3 Budget Table

Budget Table was removed: see clerks report

6. CAPITAL PLANNING

6.1 APPROVED CIP PROJECTS CURRENT STATUS

Pigging project construction complete. First pig was scheduled. Issues were discovered. First pig was attempted but was not able to be performed.

The Chatham /South Sangamon emergency interconnect construction is complete. After many failed attempts; start has been completed.

Meter Project progressing, All meter bases and registers are on site. all cell meters have been installed.

Operating permit for well #11 has been approved and well #11 is in service.

6.2 DRAFT CAPITAL IMPROVEMENT PLAN

The CIP is a planning document that includes all projects anticipated to exceed \$5,000 in cost over the next five years. The CIP is an ongoing process and will be refined from time to time as projects are completed and new issues are identified.

1. Onsite fuel storage tanks have arrived on site and pumps have been installed-completed
2. BOP CPU upgrade-completed
3. Second raw water detention tank
4. SSWC/Chatham interconnect-completed
5. Well #11-construction complete
6. SCADA computer upgrade are complete
7. Well #12

[illegible]

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY

DIVISION OF PUBLIC WATER SUPPLIES

MONTHLY IRON REMOVAL AND ION EXCHANGE SOFTENING REPORT

South Sangamon Water Commission - IL 1670080

July 2026

Pumping Totals										Chemicals Applied										UF Filters										Softeners									
Date Meter Read	Time Filter Run	Hours Filtered (Mgal)	Raw Prod. (Mgal)	UF Plant (Mgal)	HS Pumpage (Mgal)	Lagoon Effluent (Mgal)	Sodium Permanganate		Sodium Bisulfite BW		Sodium Hypochlorite		Ammonium Sulfate		Fluorosilicic Acid		Phosphate		Sodium Bisulfite Pond		Hours since previous backwash				Wash Water (M gal)	Water Softened (M gal)	Bypassed Water (M gal)	Water Used for regeneration at mid-day following previous hours (M gal)	Regeneration										
							Am't lbs.	Calc mg/l as NaHCO ₃	Am't lbs.	Calc mg/l as Cl ₂	Am't lbs.	Calc mg/l as NaOCl	Am't lbs.	Calc mg/l as NH ₃	Am't lbs.	Calc mg/l as F	Am't lbs.	Calc mg/l as PO ₄	Am't lbs.	Calc mg/l	1	2	3	4					1	2	3	4	Salt lbs.	Washed Water lbs.					
1	7:00	13.8	1,122	1,072	0.003	0.928	0.992	39	0.83	0	0.00	312	4.36	104	233	25	0.61	9	0.38	0	0.00	0.66	0.66	0.66	0.66	0.371	0.701	0.701	30.0	49.0	44.0	44.0	9124	43400					
2	7:00	15.1	1,251	0.988	0.016	1.037	0.952	39	0.75	0	0.00	302	4.58	118	286	27	0.59	10	0.38	0	0.00	0.66	0.66	0.66	0.66	0.342	0.646	0.646	30.0	49.0	44.0	44.0	9124	43400					
3	7:00	10.0	0.726	1.014	0.000	0.560	0.959	13	0.43	0	0.00	84	1.24	42	0.99	6	0.24	4	0.27	0	0.00	0.66	0.66	0.66	0.66	0.059	0.663	0.663	0.351	0.663	0.663	0.351	0	0					
4	7:00	1.8	0.052	0.030	0.020	0.040	0.068	0	0.00	0	0.00	16	7.99	3	2.40	-2	-1.14	0	0.00	0	0.00	0.66	0.66	0.66	0.66	0.008	0.020	0.010	0.000	0.020	0.010	0.000	0	0					
5	7:00	1.7	0.117	0.035	0.000	0.035	0.000	1	0.20	0	0.00	44	18.84	4	2.74	0	0.00	0	0.00	0	0.00	0.66	0.66	0.66	0.66	0.000	0.023	0.012	0.012	0.023	0.012	0.000	0	0					
6	7:00	2.8	0.033	0.058	0.000	0.052	0.000	2	0.90	0	0.00	0	0.00	3	1.24	1	0.44	0	0.00	0	0.00	0.66	0.66	0.66	0.66	0.000	0.038	0.020	0.000	0.038	0.020	0.000	0	0					
7	7:00	1.6	0.050	0.041	0.000	0.016	0.019	1	0.48	0	0.00	62	22.68	1	0.58	1	1.42	0	0.00	0	0.00	0.66	0.66	0.66	0.66	0.000	0.027	0.014	0.014	0.027	0.014	0.000	148.0	9124	43400				
8	7:00	11.9	0.826	0.935	0.013	0.755	0.952	41	1.19	0	0.00	380	6.09	129	331	38	1.15	8	0.42	0	0.00	0.66	0.66	0.66	0.66	0.042	0.611	0.611	0.324	21.0	25.0	0	4562	21700					
9	7:00	14.5	1.033	1.025	0.006	0.916	0.959	32	0.76	0	0.00	276	4.04	84	197	22	0.55	1	0.04	0	0.00	0.66	0.66	0.66	0.66	0.045	0.670	0.670	0.355	22.0	43.0	43.0	6843	33550					
10	7:00	16.1	1.143	1.031	0.011	1.041	0.977	31	0.65	0	0.00	404	5.87	89	207	24	0.53	5	0.19	0	0.00	0.66	0.66	0.66	0.66	0.063	0.674	0.674	0.357	28.0	41.0	30.0	6843	33550					
11	7:00	16.8	1.201	1.261	0.012	1.081	0.977	34	0.68	0	0.00	364	4.33	111	211	32	0.87	8	0.29	0	0.00	0.66	0.66	0.66	0.66	0.057	0.824	0.824	0.437	29.0	35.0	45.0	4562	21700					
12	7:00	13.6	0.979	1.261	0.004	0.905	0.862	14	0.34	0	0.00	170	2.02	54	103	14	0.35	4	0.17	0	0.00	0.66	0.66	0.66	0.66	0.057	0.824	0.824	0.437	29.0	54.0	0	2281	10850					
13	7:00	11.5	0.851	0.684	0.000	0.612	0.035	25	0.70	0	0.00	436	9.84	100	381	29	0.81	8	0.39	0	0.00	0.66	0.66	0.66	0.66	0.021	0.434	0.434	0.316	34.0	0	0	6843	33550					
14	7:00	14.9	1.063	0.911	0.022	0.955	0.954	23	0.52	0	0.00	324	5.33	101	266	25	0.60	8	0.33	0	0.00	0.66	0.66	0.66	0.66	0.040	0.595	0.595	0.316	34.0	17.0	79.0	6843	33550					
15	7:00	14.1	0.984	0.781	0.007	0.882	0.950	17	0.41	0	0.00	216	4.15	-8	-0.55	17	0.44	5	0.22	0	0.00	0.66	0.66	0.66	0.66	0.036	0.510	0.510	0.271	24.0	39.0	44.0	6843	33550					
16	7:00	9.9	0.365	0.742	0.011	0.530	0.969	18	0.74	0	0.00	228	4.81	60	194	19	0.82	7	0.52	0	0.00	0.66	0.66	0.66	0.66	0.059	0.485	0.485	0.257	23.0	0	0	40.0	4562	21700				
17	7:00	15.6	0.836	0.742	0.008	0.748	0.978	20	0.57	0	0.00	258	5.21	66	213	20	0.61	7	0.37	0	0.00	0.66	0.66	0.66	0.66	0.059	0.485	0.485	0.257	24.0	49.0	39.0	38.0	9124	43400				
18	7:00	14.1	0.886	0.849	0.017	0.807	0.958	19	0.51	0	0.00	264	4.66	75	212	20	0.56	9	0.44	0	0.00	0.66	0.66	0.66	0.66	0.056	0.555	0.555	0.294	24.0	0	0	0	0	0				
19	7:00	11.8	1.062	0.871	0.002	0.977	0.955	27	0.59	0	0.00	388	6.68	107	295	28	0.68	11	0.45	0	0.00	0.66	0.66	0.66	0.66	0.038	0.589	0.589	0.302	37.0	48.0	35.0	34.0	9124	43400				
20	7:00	16.3	1.123	1.121	0.011	1.026	0.958	24	0.51	0	0.00	360	4.81	107	229	28	0.62	36	1.39	0	0.00	0.66	0.66	0.66	0.66	0.048	0.733	0.733	0.388	30.0	33.0	45.0	4562	21700					
21	7:00	19.0	1.330	1.217	0.007	1.260	0.981	33	0.57	0	0.00	470	5.79	134	264	32	0.58	-3	-0.08	0	0.00	0.66	0.66	0.66	0.66	0.062	0.795	0.795	0.422	45.0	59.0	29.0	29.0	9124	43400				
22	7:00	17.7	1.277	1.217	0.016	1.214	0.081	44	0.83	0	0.00	524	6.45	150	296	38	0.73	38	1.24	0	0.00	0.66	0.66	0.66	0.66	0.062	0.795	0.795	0.422	45.0	21.0	21.0	21.0	9124	43400				
23	7:00	21.7	1.681	1.579	0.016	1.510	0.014	51	0.73	0	0.00	578	5.49	160	243	43	0.65	-9	-0.24	0	0.00	0.66	0.66	0.66	0.66	0.085	1.032	1.032	0.547	37.0	31.0	23.0	24.0	9124	43400				
24	7:00	20.5	1.594	1.579	0.016	1.409	0.995	41	0.62	0	0.00	466	4.71	125	190	34	0.55	8	0.22	0	0.00	0.66	0.66	0.66	0.66	0.085	1.032	1.032	0.547	37.0	24.0	24.0	24.0	4562	21700				
25	7:00	19.7	1.338	1.467	0.006	1.440	0.073	46	0.72	0	0.00	522	5.33	130	213	40	0.63	11	0.30	0	0.00	0.66	0.66	0.66	0.66	0.054	0.959	0.959	0.508	34.0	36.0	24.0	25.0	9124	43400				
26	7:00	18.3	1.393	1.229	0.012	1.240	0.072	39	0.67	0	0.00	462	5.63	116	226	35	0.64	10	0.32	0	0.00	0.66	0.66	0.66	0.66	0.072	0.803	0.803	0.426	42.0	48.0	32.0	32.0	6843	33550				
27	7:00	18.3	1.468	1.229	0.010	1.333	0.986	15	0.26	0	0.00	634	7.73	132	258	33	0.56	10	0.30	0	0.00	0.66	0.66	0.66	0.66	0.062	0.976	0.976	0.517	71.0	34.0	24.0	25.0	9124	43400				
28	7:00	20.3	1.578	1.493	0.007	1.397	0.981	51	0.78	0	0.00	504	5.06	161	259	39	0.64	13	0.37	0	0.00	0.66	0.66	0.66	0.66	0.062	0.976	0.976	0.517	71.0	34.0	24.0	25.0	9124	43400				
29	7:00	17.9	1.391	1.466	0.015	1.234	0.986	46	0.79	0	0.00	478	4.89	129	211	40	0.74	16	0.51	0	0.00	0.66	0.66	0.66	0.66	0.062	0.958	0.958	0.508	35.0	30.0	23.0	23.0	9124	43400				
30	7:00	21.8	1.668	1.487	0.014	1.562	0.995	54	0.78	0	0.00	526	5.30	153	247	38	0.55	14	0.35	0	0.00	0.66	0.66	0.66	0.66	0.090	0.972	0.972	0.515	71.0	21.0	21.0	21.0	21.0	0	0			
31	7:00	19.8	1.566	1.478	0.003	1.398	0.980	46	0.70	0	0.00	490	4.97	130	211	36	0.59	19	0.54	0	0.00	0.66	0.66	0.66	0.66	0.061	0.966	0.966	0.512	35.0	40.0	47.0	25.0	9124	43400				
Total		442.9	32.44	30.873	0.285	29.120	1.939	886	19.22	0	0	0.00	10572	188.67	2680	66.93	784	17.41	267	10.10	0	0.00				1.565	20.178	10.695	726	761	760	744	182794	803200					
Ave.		14.3	1.047	0.996	0.009	0.939	0.963	28.6	0.62	0	0	0.341	6.09	92	2.16	25.3	0.56	8.6	0.33	0	0.00	0.66	0.66	0.66	0.66	0.051	0.651	0.651	0.345	38.2	44.8	40.0	39.2	5444.97	30880.8				
Max		21.8	1.681	1.579	0.022	1.562	1.004	54.0	1.19	0	0	634	22.66	161	361.57	43	1.42	38	1.39	0	0.00	0.66	0.66	0.66	0.66	0.1032	0.547	0.547	0.547	134.0	147.0	150.0	148.0	9.124	43.400				
Min		1.6	0.050	0.030	0.000	0.016	0.000	0.0	0.00	0	0	0	0.00	-18	-0.55	-2	-1.14	-9	-0.24	0	0.00	0.66	0.66	0.66	0.66	0.000	0.020	0.010	0.010	21.0	12.0	17.0	21.0	0	0				
1	20	% Sodium Permanganate				Post aerator																																	
2	40	% Bisulfite/Sulfon				Membrane Backwash																																	
3	12.5	% Sodium Hypochlorite Solution				Post Softener																																	
4	20	% Ammonium Sulfate Solution				Post Clearwell																																	
5	19	% Fluorosilicic Acid Solution				Post Clearwell																																	

